

OHA - Drinking Water Services - Surface Water Quality Data Form
 Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: Wallowa
 Month/Year: May-22


System Name: City of Joseph ID#: 41 00414 WTP : TP -

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1			0.11				0.11
2			0.13				0.13
3			0.13				0.13
4			0.13				0.13
5			0.15				0.15
6			0.10				0.10
7			0.13				0.13
8			0.10				0.10
9			0.15				0.15
10			0.12				0.12
11			0.09				0.09
12			0.15				0.15
13			0.12				0.12
14			0.11				0.11
15			0.12				0.12
16			0.15				0.15
17			0.11				0.11
18			0.13				0.13
19			0.13				0.13
20			0.12				0.12
21			0.11				0.10
22			0.17				0.19
23			0.14				0.14
24			0.14				0.14
25			0.12				0.12
26			0.10				0.11
27			0.18				0.18
28			0.09				0.09
29			0.12				0.12
30			0.12				0.12
31			0.15				0.15

Slow Sand/Membrane/DE Filtration/Unfiltered	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? ² Yes	CT's met everyday? (see back) Yes	All Cl2 residual at entry point ≥ 0.2 mg/l? Yes
All daily turbidity readings ≤ 5 NTU? Yes		

Notes:

PRINTED NAME: Levi Tickner

SIGNATURE: 

DATE: 6/10/2022

PHONE #: (541) 760-9362

T-008780

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- :
 Disinfection *Giardia* Log Inactiv: 1.0

System Name: City of Joseph ID#: 41 00414 Month/Year: May-22

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/l]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.51	1775	905.3	10.0	7.38	41.7	YES	260
2	0.47	1792	842.2	9.9	7.37	41.6	YES	260
3	0.44	1775	781.0	9.8	7.19	39.2	YES	260
4	0.5	1744	872.0	9.6	6.88	36.0	YES	280
5	0.5	1701	850.5	10.2	7.26	39.4	YES	280
6	0.4	1937	774.8	10.5	7.49	41.4	YES	250
7	0.48	1877	901.0	10.7	7.46	40.8	YES	250
8	0.47	1846	867.6	10.6	7.68	44.3	YES	250
9	0.49	1941	951.1	10.6	7.08	36.1	YES	250
10	0.49	1609	788.4	10.0	7.21	39.2	YES	290
11	0.5	1592	796.0	10.2	7.35	40.7	YES	290
12	0.49	1707	836.4	10.2	8.02	51.5	YES	295
13	0.5	1686	843.0	10.2	7.34	40.5	YES	295
14	0.53	1652	875.6	10.9	8.32	54.9	YES	295
15	0.54	1612	870.5	10.9	7.32	38.6	YES	295
16	0.53	1592	843.8	11.4	7.35	37.8	YES	295
17	0.47	1611	757.2	11.3	8.23	51.4	YES	295
18	0.52	1611	837.7	11.1	7.86	46.0	YES	295
19	0.53	1586	840.6	11.7	7.09	33.9	YES	300
20	0.5	1610	805.0	11.2	7.87	45.7	YES	300
21	0.51	1599	815.5	11.5	7.83	44.2	YES	300
22	0.51	1567	799.2	12.1	7.94	44.2	YES	300
23	0.49	1537	753.1	11.7	7.86	44.0	YES	300
24	0.51	1679	856.3	12.1	7.39	36.5	YES	305
25	0.49	1560	764.4	12.2	8.33	50.3	YES	305
26	0.57	1527	870.4	12.7	7.73	39.6	YES	300
27	0.48	1504	721.9	13.3	8.44	48.9	YES	300
28	0.49	1698	832.0	12.1	7.28	35.1	YES	300
29	0.46	1637	753.0	12.7	7.64	37.8	YES	300
30	0.5	1635	817.5	11.8	7.89	44.2	YES	300
31	0.5	1608	804.0	11.7	7.40	37.5	YES	300

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:
 dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350