

OHA - Drinking Water Services - Surface Water Quality Data Form
 Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems


County: Wallowa
 Month/Year: Jun-22

System Name: City of Joseph ID#: 41 00414 WTP : TP -

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1			0.17				0.17
2			0.15				0.15
3			0.22				0.22
4			0.18				0.18
5			0.08				0.08
6			0.08				0.08
7			0.13				0.13
8			0.13				0.13
9			0.14				0.14
10			0.20				0.20
11			0.16				0.16
12			0.17				0.17
13			0.10				0.10
14			0.08				0.08
15			0.12				0.12
16			0.14				0.14
17			0.27				0.27
18			0.58				0.58
19			0.13				0.13
20			0.25				0.25
21			0.21				0.21
22			0.20				0.20
23			0.13				0.13
24			0.16				0.16
25			0.25				0.25
26			0.10				0.10
27			0.21				0.21
28			0.09				0.09
29			0.16				0.16
30			0.14				0.14
31							

Slow Sand/Membrane/DE Filtration/Unfiltered	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings \leq 1 NTU? ² Yes	CT's met everyday? (see back) Yes	All Cl2 residual at entry point \geq 0.2 mg/l? Yes
All daily turbidity readings \leq 5 NTU? Yes		

Notes: Slow sand filter plant was offline for cleaning and ripening from 6/1/2022 to 6/16/2022

PRINTED NAME: Levi Tickner
 SIGNATURE: 
 PHONE #: (541) 760-9362
 DATE: 7/7/2022
 CERT #: T-008780

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- : _____

System Name: City of Joseph ID#: 41 00414 Month/Year: Jun-22 Disinfection *Giardia* Log Inactiv: 1.0

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/l]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1								
2								
3								
4								
5								
6								
7								
8								
9								
10								
11								
12								
13								
14								
15								
16	0.38	1456	553.3	13.1	7.69	37.2	YES	347
17	0.37	1586	586.8	13.6	8.29	44.8	YES	319
18	0.39	1521	593.2	12.6	8.05	44.0	YES	340
19	0.25	1457	364.3	12.3	7.73	39.4	YES	355
20	0.31	1291	400.2	12.5	7.82	40.3	YES	400
21	0.35	1218	426.3	12.4	8.07	44.5	YES	420
22	0.32	1236	395.5	12.7	7.92	41.2	YES	413
23	0.41	1310	537.1	12.6	7.76	39.6	YES	388
24	0.42	1127	473.3	13.0	7.59	36.3	YES	453
25	0.53	1023	542.2	13.6	8.47	48.8	YES	483
26	0.57	1036	590.5	13.3	7.90	40.5	YES	470
27	0.59	986	581.7	14.1	7.52	33.5	YES	482
28	0.59	981	578.8	14.2	7.71	35.7	YES	481
29	0.67	1005	673.4	14.6	7.84	36.8	YES	478
30	0.64	995	636.8	13.9	7.58	34.9	YES	477
31								

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:
 dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350