

OHA - Drinking Water Services - Surface Water Quality Data Form
 Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: Wallowa
 Month/Year: Jul-22


System Name: City of Joseph ID#: 41 00414 WTP: TP -

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1			0.24				0.24
2			0.12				0.12
3			0.13				0.13
4			0.16				0.16
5			0.12				0.12
6			0.14				0.14
7			0.16				0.16
8			0.12				0.12
9			0.11				0.11
10			0.15				0.15
11			0.22				0.22
12			0.14				0.14
13			0.13				0.13
14			0.12				0.12
15			0.16				0.16
16			0.17				0.17
17			0.12				0.12
18			0.13				0.13
19			0.13				0.13
20			0.14				0.14
21			0.17				0.17
22			0.13				0.13
23			0.14				0.14
24			0.12				0.12
25			0.16				0.16
26			0.13				0.13
27			0.15				0.15
28			0.15				0.15
29			0.11				0.11
30			0.08				0.08
31			0.12				0.12

Slow Sand/Membrane/DE Filtration/Unfiltered	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings \leq 1 NTU? ² Yes	CT's met everyday? (see back) Yes	All Cl2 residual at entry point \geq 0.2 mg/l? Yes
All daily turbidity readings \leq 5 NTU? Yes		

Notes:

PRINTED NAME: Levi Tickner

SIGNATURE:  DATE: 8/10/2022

PHONE #: (541) 760-9362 CERT #: T-008780

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- :
 Disinfection *Giardia* Log
 Inactiv: 1.0

System Name: ID#: 41 Month/Year:

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/l]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.61	1005	613.1	13.6	7.79	38.3	YES	472
2	0.57	1018	580.3	13.7	7.64	35.9	YES	478
3	0.56	1021	571.8	13.9	7.51	33.7	YES	477
4	0.53	994	526.8	14.2	7.85	37.3	YES	478
5	0.5	1007	503.5	13.8	7.72	36.4	YES	477
6	0.48	1041	499.7	14.0	7.58	34.0	YES	478
7	0.5	993	496.5	14.2	7.65	34.5	YES	478
8	0.51	963	491.1	14.5	7.72	34.8	YES	479
9	0.48	1003	481.4	15.1	7.68	32.8	YES	477
10	0.48	961	461.3	15.1	7.73	33.4	YES	480
11	0.5	1022	511.0	15.3	7.64	32.0	YES	478
12	0.5	961	480.5	13.9	7.63	35.0	YES	480
13	0.58	575	333.5	14.0	7.63	35.1	YES	820
14	0.54	812	438.5	14.6	7.60	33.2	YES	600
15	0.54	795	429.3	14.9	7.57	32.1	YES	613
16	0.63	791	498.3	14.5	8.31	43.8	YES	616
17	0.52	790	410.8	14.5	7.59	33.2	YES	616
18	0.57	746	425.2	14.6	7.67	34.1	YES	653
19	0.54	619	334.3	14.3	8.32	44.1	YES	780
20	0.51	602	307.0	14.8	7.88	36.2	YES	800
21	0.54	619	334.3	14.8	7.65	33.3	YES	780
22	0.51	653	333.0	15.3	7.92	35.5	YES	740
23	0.47	651	306.0	15.1	7.76	33.8	YES	735
24	0.47	610	286.7	15.1	7.65	32.4	YES	790
25	0.46	651	299.5	15.3	7.71	32.7	YES	740
26	0.45	587	264.2	15.5	7.64	31.4	YES	815
27	0.55	623	342.7	15.8	7.64	31.1	YES	775
28	0.56	571	319.8	15.8	7.74	32.3	YES	793
29	0.56	700	392.0	16.2	7.99	34.5	YES	680
30	0.55	695	382.3	16.6	7.79	31.2	YES	676
31	0.55	665	365.8	16.6	7.63	29.4	YES	728

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:
 dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350