


OHA - Drinking Water Services - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: **Wallowa**
 Month/Year: **Mar-23**

System Name: **City of Joseph** ID#: **41 00414** WTP: **TP -**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1			0.08				0.08
2			0.08				0.08
3			0.13				0.13
4			0.17				0.17
5			0.18				0.18
6			0.07				0.07
7			0.11				0.11
8			0.11				0.11
9			0.15				0.15
10			0.10				0.10
11			0.10				0.10
12			0.12				0.12
13			0.12				0.12
14			0.13				0.13
15			0.15				0.15
16			0.11				0.11
17			0.12				0.12
18			0.12				0.12
19			0.14				0.14
20			0.10				0.10
21			0.11				0.11
22			0.09				0.09
23			0.15				0.15
24			0.07				0.07
25			0.16				0.16
26			0.17				0.17
27			0.11				0.11
28			0.08				0.08
29			0.14				0.14
30			0.14				0.14
31			0.08				0.08

0.08		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? ²	Yes	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU?	Yes	Yes	Yes

Notes:	PRINTED NAME: Levi Tickner 	
	SIGNATURE:	4/10/2023
	PHONE #: (541)760-9362	CERT #: T-008780

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP: :
 Disinfection *Giardia* Log
 Inactiv: 1.0

System Name: City of Joseph ID#: 41 00414 Month/Year: Mar-23

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]							
1	0.51	1660	846.6	5.3	7.68	63.6	YES	310
2	0.51	1816	926.2	4.8	7.61	64.1	YES	284
3	0.5	1710	855.0	5.3	8.49	85.4	YES	301
4	0.5	1703	851.5	5.4	8.23	77.1	YES	302
5	0.5	1798	899.0	5.5	7.75	64.2	YES	287
6	0.45	1598	719.1	5.3	7.42	57.5	YES	322
7	0.48	1608	771.8	5.5	7.60	60.7	YES	320
8	0.51	1559	795.1	5.4	8.11	73.9	YES	330
9	0.49	1542	755.6	5.4	7.62	61.6	YES	335
10	0.52	1586	824.7	5.4	7.62	61.8	YES	325
11	0.52	1536	798.7	5.4	7.63	62.1	YES	335
12	0.5	1585	792.5	5.6	7.65	61.5	YES	325
13	0.52	1622	843.4	5.9	7.66	60.7	YES	318
14	0.52	1588	825.8	6.1	7.52	56.9	YES	325
15	0.49	1590	779.1	6.0	7.63	59.4	YES	324
16	0.49	1611	789.4	6.1	7.70	60.5	YES	320
17	0.51	1608	820.1	6.2	7.82	62.9	YES	320
18	0.43	1582	680.3	6.3	7.35	52.3	YES	325
19	0.49	1613	790.4	6.5	7.57	56.2	YES	320
20	0.5	1638	819.0	6.5	7.56	56.0	YES	315
21	0.5	1615	807.5	6.6	7.59	56.3	YES	320
22	0.5	1611	805.5	6.5	7.19	49.1	YES	320
23	0.57	1825	1040.3	7.1	8.00	63.6	YES	283
24	0.46	1720	791.2	6.8	7.58	55.1	YES	300
25	0.48	1692	812.2	6.7	7.67	57.4	YES	304
26	0.45	1608	723.6	6.7	8.45	76.0	YES	320
27	0.46	1605	738.3	6.8	7.66	56.7	YES	320
28	0.53	1636	867.1	6.9	8.71	83.2	YES	315
29	0.47	1638	769.9	6.6	7.69	58.1	YES	315
30	0.49	1669	817.8	6.7	7.70	58.1	YES	310
31	0.45	1586	713.7	6.8	7.70	57.4	YES	325

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:
 dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350