


OHA - Drinking Water Services - Surface Water Quality Data Form
 Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: Wallowa
 Month/Year: Oct-24

System Name:	City of Joseph		ID#: 41	00414		WTP : TP -	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1			0.10				0.10
2			0.09				0.09
3			0.08				0.08
4			0.10				0.10
5			0.08				0.08
6			0.08				0.08
7			0.06				0.06
8			0.10				0.10
9			0.06				0.06
10			0.07				0.07
11			0.09				0.09
12			0.08				0.08
13			0.10				0.10
14			0.07				0.07
15			0.07				0.07
16			0.09				0.09
17			0.14				0.14
18			0.09				0.09
19			0.11				0.11
20			0.12				0.12
21			0.09				0.09
22			0.09				0.09
23			0.12				0.12
24			0.12				0.12
25			0.10				0.10
26			0.11				0.11
27			0.09				0.09
28			0.12				0.12
29			0.10				0.10
30			0.15				0.15
31			0.07				0.07

Slow Sand/Membrane/DE Filtration/Unfiltered		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings \leq 1 NTU? ²	Yes	CT's met everyday? (see back)	All Cl ₂ residual at entry point \geq 0.2 mg/l?
All daily turbidity readings \leq 5 NTU?	Yes	Yes	Yes
Notes:	PRINTED NAME: Levi Tickner		
	SIGNATURE: 	DATE: 11/10/2024	
	PHONE #: (541)760-9362	CERT #: T- 008780	

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- :
 Disinfection *Giardia* Log
 Inactiv: 1.0

System Name: City of Joseph ID#: 41 00414 Month/Year: Oct-24

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/l]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.5	2493	1246.5	16.6	7.57	28.6	YES	210
2	0.57	2157	1229.5	16.4	7.69	30.5	YES	241
3	0.59	2280	1345.2	16.0	7.60	30.4	YES	225
4	0.58	1934	1121.7	16.0	7.77	32.3	YES	270
5	0.55	1578	867.9	15.8	7.53	29.9	YES	325
6	0.54	1710	923.4	16.0	7.68	31.1	YES	300
7	0.57	1368	779.8	16.1	7.56	29.7	YES	375
8	0.6	1282	769.2	15.3	7.56	31.4	YES	400
9	0.58	1465	849.7	15.6	7.69	32.2	YES	350
10	0.56	700	392.0	15.7	7.77	32.9	YES	720
11	0.57	571	325.5	15.5	7.64	31.8	YES	900
12	0.56	1927	1079.1	15.4	7.57	31.2	YES	275
13	0.58	2154	1249.3	15.4	7.60	31.6	YES	250
14	0.58	1973	1144.3	15.5	7.62	31.6	YES	260
15	0.58	2187	1268.5	15.4	7.60	31.6	YES	240
16	0.63	2086	1314.2	15.1	7.38	29.9	YES	250
17	0.5	1604	802.0	14.9	7.73	34.0	YES	325
18	0.52	1655	860.6	14.6	7.61	33.2	YES	315
19	0.55	1282	705.1	14.2	7.79	36.6	YES	400
20	0.61	1262	769.8	14.2	7.52	33.3	YES	420
21	0.61	1514	923.5	14.1	7.64	35.1	YES	350
22	0.58	1860	1078.8	14.0	7.59	34.5	YES	285
23	0.57	2137	1218.1	13.7	7.60	35.3	YES	240
24	0.61	2943	1795.2	13.5	7.50	34.7	YES	180
25	0.57	2582	1471.7	13.1	7.68	37.9	YES	192
26	0.59	3158	1863.2	12.9	7.85	40.9	YES	157
27	0.61	3350	2043.5	12.9	7.49	35.9	YES	148
28	0.64	3612	2311.7	12.7	7.61	38.2	YES	142
29	0.69	3309	2283.2	13.4	7.27	32.3	YES	155
30	0.59	3717	2193.0	13.3	7.52	35.3	YES	138
31	0.66	3226	2129.2	13.1	7.30	33.2	YES	159

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:
 dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350