

OHA - Drinking Water Services - Surface Water Quality Data Form
 Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: **Wallowa**
 Month/Year: **Jan-25**


System Name: **City of Joseph** ID#: **41 00414** WTP : **TP -**

| Day | 12 AM [NTU] | 4 AM [NTU] | 8 AM [NTU] | NOON [NTU] | 4 PM [NTU] | 8 PM [NTU] | Highest Reading of the day ¹ [NTU] |
|-----|-------------|------------|------------|------------|------------|------------|---|
| 1 | | | 0.11 | | | | 0.11 |
| 2 | | | 0.13 | | | | 0.13 |
| 3 | | | 0.15 | | | | 0.15 |
| 4 | | | 0.16 | | | | 0.16 |
| 5 | | | 0.17 | | | | 0.17 |
| 6 | | | 0.16 | | | | 0.16 |
| 7 | | | 0.14 | | | | 0.14 |
| 8 | | | 0.19 | | | | 0.19 |
| 9 | | | 0.14 | | | | 0.14 |
| 10 | | | 0.15 | | | | 0.15 |
| 11 | | | 0.17 | | | | 0.17 |
| 12 | | | 0.08 | | | | 0.08 |
| 13 | | | 0.10 | | | | 0.10 |
| 14 | | | 0.09 | | | | 0.09 |
| 15 | | | 0.10 | | | | 0.10 |
| 16 | | | 0.10 | | | | 0.10 |
| 17 | | | 0.17 | | | | 0.17 |
| 18 | | | 0.21 | | | | 0.21 |
| 19 | | | 0.18 | | | | 0.18 |
| 20 | | | 0.17 | | | | 0.17 |
| 21 | | | 0.16 | | | | 0.16 |
| 22 | | | 0.21 | | | | 0.21 |
| 23 | | | 0.22 | | | | 0.22 |
| 24 | | | 0.19 | | | | 0.19 |
| 25 | | | 0.18 | | | | 0.18 |
| 26 | | | 0.20 | | | | 0.20 |
| 27 | | | 0.26 | | | | 0.26 |
| 28 | | | 0.19 | | | | 0.19 |
| 29 | | | 0.20 | | | | 0.20 |
| 30 | | | 0.12 | | | | 0.12 |
| 31 | | | 0.13 | | | | 0.13 |

| Slow Sand/Membrane/DE Filtration/Unfiltered | Monthly Summary (Answer Yes or No) | |
|--|--|--|
| 95% of daily turbidity readings ≤ 1 NTU? ² Yes | CT's met everyday? (see back) Yes | All Cl2 residual at entry point ≥ 0.2 mg/l? Yes |
| All daily turbidity readings ≤ 5 NTU? Yes | | |

Notes:

PRINTED NAME: **Levi Tickner**

SIGNATURE: 

DATE: **2/10/2025**

PHONE #: **(541) 760-9362**

CERT #: **T-008780**

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- :

Disinfection *Giardia* Log

System Name:

City of Joseph

ID#: 41

00414

Month/Year: Jan-25

Inactiv:

1.0

| Date / Time | Minimum Cl ₂ Residual at 1st User (C) ³ | Contact Time (T) | Actual CT | Temp | pH | Required CT | CT Met? ³ | Peak Hourly Demand Flow |
|-------------|---|------------------|-----------|-------|------|-------------|----------------------|-------------------------|
| | [ppm or mg/l] | [minutes] | C X T | [° C] | | formula | Yes / No | [GPM] |
| 1 | 0.62 | 3481 | 2158.2 | 7.6 | 7.81 | 57.7 | YES | 140 |
| 2 | 0.56 | 3432 | 1921.9 | 7.7 | 7.61 | 53.0 | YES | 142 |
| 3 | 0.51 | 5048 | 2574.5 | 6.5 | 7.39 | 52.8 | YES | 105 |
| 4 | 0.57 | 4819 | 2746.8 | 6.7 | 7.91 | 63.3 | YES | 110 |
| 5 | 0.53 | 4908 | 2601.2 | 6.4 | 7.65 | 58.5 | YES | 108 |
| 6 | 0.58 | 6544 | 3795.5 | 6.4 | 7.65 | 58.8 | YES | 81 |
| 7 | 0.53 | 5700 | 3021.0 | 6.4 | 7.68 | 59.1 | YES | 93 |
| 8 | 0.6 | 4417 | 2650.2 | 6.4 | 7.79 | 62.0 | YES | 120 |
| 9 | 0.56 | 4417 | 2473.5 | 6.1 | 7.59 | 58.6 | YES | 120 |
| 10 | 0.61 | 4240 | 2586.4 | 6.1 | 7.69 | 61.1 | YES | 125 |
| 11 | 0.57 | 4417 | 2517.7 | 5.8 | 7.62 | 60.5 | YES | 120 |
| 12 | 0.6 | 3029 | 1817.4 | 6.0 | 7.74 | 62.6 | YES | 175 |
| 13 | 0.63 | 4650 | 2929.5 | 5.9 | 7.58 | 59.7 | YES | 114 |
| 14 | 0.57 | 4863 | 2771.9 | 5.9 | 7.76 | 63.3 | YES | 109 |
| 15 | 0.53 | 2718 | 1440.5 | 5.8 | 7.77 | 63.6 | YES | 195 |
| 16 | 0.56 | 5580 | 3124.8 | 5.9 | 7.76 | 63.2 | YES | 95 |
| 17 | 0.57 | 4417 | 2517.7 | 6.4 | 8.01 | 67.0 | YES | 120 |
| 18 | 0.55 | 4819 | 2650.5 | 6.0 | 7.85 | 64.8 | YES | 110 |
| 19 | 0.55 | 4819 | 2650.5 | 5.8 | 7.78 | 64.0 | YES | 110 |
| 20 | 0.54 | 4733 | 2555.8 | 5.6 | 7.79 | 65.0 | YES | 112 |
| 21 | 0.52 | 4417 | 2296.8 | 6.1 | 8.80 | 90.9 | YES | 120 |
| 22 | 0.44 | 4775 | 2101.0 | 6.0 | 7.80 | 62.8 | YES | 111 |
| 23 | 0.48 | 4819 | 2313.1 | 6.1 | 7.74 | 61.3 | YES | 110 |
| 24 | 0.55 | 4077 | 2242.4 | 5.6 | 7.74 | 63.9 | YES | 130 |
| 25 | 0.6 | 4417 | 2650.2 | 5.1 | 7.63 | 63.9 | YES | 120 |
| 26 | 0.64 | 4417 | 2826.9 | 5.5 | 7.67 | 63.4 | YES | 120 |
| 27 | 0.73 | 3733 | 2725.1 | 5.2 | 7.77 | 67.9 | YES | 142 |
| 28 | 0.7 | 2650 | 1855.0 | 5.6 | 7.70 | 64.1 | YES | 200 |
| 29 | 0.76 | 3313 | 2517.9 | 5.2 | 7.67 | 65.7 | YES | 160 |
| 30 | 0.68 | 3118 | 2120.2 | 5.4 | 7.71 | 65.1 | YES | 170 |
| 31 | 0.69 | 2945 | 2032.1 | 5.6 | 7.66 | 63.1 | YES | 180 |

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350