


OHA - Drinking Water Services - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: Wallowa
Month/Year: May-25

System Name:		City of Joseph		ID#: 41 00414		WTP : TP -	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1			0.11				0.11
2			0.13				0.13
3			0.08				0.08
4			0.10				0.10
5			0.09				0.09
6			0.07				0.07
7			0.04				0.04
8			0.03				0.03
9			0.03				0.03
10			0.04				0.04
11			0.05				0.05
12			0.03				0.03
13			0.03				0.03
14			0.14				0.14
15			0.12				0.12
16			0.09				0.09
17			0.09				0.09
18			0.10				0.10
19			0.20				0.20
20			0.10				0.10
21			0.16				0.16
22			0.12				0.12
23			0.19				0.19
24			0.13				0.13
25			0.13				0.13
26			0.15				0.15
27			0.08				0.08
28							OFF
29							OFF
30							OFF
31							OFF

Slow Sand/Membrane/DE Filtration/Unfiltered		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings $\leq$ 1 NTU? ²	Yes	CT's met everyday? (see back)	All Cl2 residual at entry point $\geq$ 0.2 mg/l?
All daily turbidity readings $\leq$ 5 NTU?	Yes	YES	YES
Notes:		PRINTED NAME: Levi Tickner	
		SIGNATURE: 	DATE: 6/10/2025
		PHONE #: (541) 760-9362	CERT #: T-008780

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form
WTP- :

System Name:	City of Joseph	ID#: 41	00414	Month/Year: May-25	Disinfection <i>Giardia</i> Log	Inactiv:	1.0
---------------------	-----------------------	----------------	--------------	---------------------------	--	-----------------	------------

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.37	514	190.2	12.4	7.69	39.1	YES	972
2	0.39	514	200.5	12.3	7.30	34.5	YES	972
3	0.46	514	236.4	13.5	7.27	31.3	YES	972
4	0.44	514	226.2	13.6	7.27	31.0	YES	972
5	0.38	514	195.3	13.1	7.29	32.1	YES	972
6	0.36	514	185.0	12.3	7.33	34.7	YES	972
7	0.38	514	195.3	10.6	7.40	39.8	YES	972
8	0.41	514	210.7	11.6	7.41	37.5	YES	972
9	0.52	514	267.3	11.8	7.40	37.4	YES	972
10	0.56	514	287.8	12.2	7.38	36.3	YES	972
11	0.6	514	308.4	12.1	7.37	36.6	YES	972
12	0.68	514	349.5	12.1	7.36	36.8	YES	972
13	0.57	514	293.0	11.9	7.37	37.0	YES	972
14	0.6	514	308.4	13.3	7.77	38.8	YES	972
15	0.53	527	279.3	12.8	7.69	38.6	YES	972
16	0.53	543	287.8	12.9	7.73	38.9	YES	972
17	0.58	518	300.4	13.2	7.60	36.6	YES	972
18	0.93	518	481.7	14.5	7.59	34.8	YES	972
19	0.59	815	480.9	12.6	7.70	39.5	YES	972
20	0.81	504	408.2	14.2	7.60	35.1	YES	972
21	0.53	505	267.7	12.7	8.06	44.5	YES	972
22	0.9	510	459.0	15.1	7.46	31.7	YES	972
23	0.87	508	442.0	15.0	7.63	33.9	YES	972
24	0.57	527	300.4	13.3	8.11	43.8	YES	972
25	0.58	527	305.7	14.0	7.57	34.3	YES	972
26	0.6	510	306.0	14.7	7.63	33.5	YES	972
27	0.51	536	273.4	14.7	8.34	43.1	YES	972
28								
29								
30								
31								

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350