


**OHA - Drinking Water Services - Surface Water Quality Data Form**  
**Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**

County: **Wallowa**  
 Month/Year: **Jun-25**

| System Name: |                | City of Joseph |               | ID#: 41 00414 |               | WTP : TP -    |                                               |
|--------------|----------------|----------------|---------------|---------------|---------------|---------------|-----------------------------------------------|
| Day          | 12 AM<br>[NTU] | 4 AM<br>[NTU]  | 8 AM<br>[NTU] | NOON<br>[NTU] | 4 PM<br>[NTU] | 8 PM<br>[NTU] | Highest Reading of the day <sup>1</sup> [NTU] |
| 1            |                |                | 0.14          |               |               |               | 0.14                                          |
| 2            |                |                | 0.09          |               |               |               | 0.09                                          |
| 3            |                |                | 0.09          |               |               |               | 0.09                                          |
| 4            |                |                | 0.08          |               |               |               | 0.08                                          |
| 5            |                |                | 0.08          |               |               |               | 0.08                                          |
| 6            |                |                | 0.03          |               |               |               | 0.03                                          |
| 7            |                |                | 0.04          |               |               |               | 0.04                                          |
| 8            |                |                | 0.03          |               |               |               | 0.03                                          |
| 9            |                |                | 0.03          |               |               |               | 0.03                                          |
| 10           |                |                | 0.04          |               |               |               | 0.04                                          |
| 11           |                |                | 0.03          |               |               |               | 0.03                                          |
| 12           |                |                | 0.14          |               |               |               | 0.14                                          |
| 13           |                |                | 0.16          |               |               |               | 0.16                                          |
| 14           |                |                | 0.14          |               |               |               | 0.14                                          |
| 15           |                |                | 0.11          |               |               |               | 0.11                                          |
| 16           |                |                | 0.09          |               |               |               | 0.09                                          |
| 17           |                |                | 0.08          |               |               |               | 0.08                                          |
| 18           |                |                | 0.03          |               |               |               | 0.03                                          |
| 19           |                |                | 0.04          |               |               |               | 0.04                                          |
| 20           |                |                | 0.03          |               |               |               | 0.03                                          |
| 21           |                |                | 0.03          |               |               |               | 0.03                                          |
| 22           |                |                | 0.03          |               |               |               | 0.03                                          |
| 23           |                |                | 0.04          |               |               |               | 0.04                                          |
| 24           |                |                | 0.05          |               |               |               | 0.05                                          |
| 25           |                |                | 0.03          |               |               |               | 0.03                                          |
| 26           |                |                | 0.09          |               |               |               | 0.09                                          |
| 27           |                |                | 0.16          |               |               |               | 0.16                                          |
| 28           |                |                | 0.17          |               |               |               | 0.17                                          |
| 29           |                |                | 0.23          |               |               |               | 0.23                                          |
| 30           |                |                | 0.03          |               |               |               | 0.03                                          |
| 31           |                |                |               |               |               |               |                                               |

|                                                            |            |                                                                                                        |                                                  |
|------------------------------------------------------------|------------|--------------------------------------------------------------------------------------------------------|--------------------------------------------------|
| <b>Slow Sand/Membrane/DE Filtration/Unfiltered</b>         |            | <b>Monthly Summary (Answer Yes or No)</b>                                                              |                                                  |
| 95% of daily turbidity readings $\leq$ 1 NTU? <sup>2</sup> | <b>Yes</b> | CT's met everyday? (see back)                                                                          | All Cl2 residual at entry point $\geq$ 0.2 mg/l? |
| All daily turbidity readings $\leq$ 5 NTU?                 | <b>Yes</b> | <b>YES</b>                                                                                             | <b>YES</b>                                       |
| <b>Notes:</b>                                              |            | <b>PRINTED NAME:</b> Levi Tickner                                                                      |                                                  |
|                                                            |            | <b>SIGNATURE:</b>  | <b>DATE:</b> 7/10/2025                           |
|                                                            |            | <b>PHONE #:</b> ( 541 ) 760-9362                                                                       | <b>CERT #:</b> T-008780                          |

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> Filtered systems only.

**OHA - Drinking Water Services - Surface Water Quality Data Form**
**WTP- :**

|                     |                       |                |              |                           |                                        |                 |            |
|---------------------|-----------------------|----------------|--------------|---------------------------|----------------------------------------|-----------------|------------|
| <b>System Name:</b> | <b>City of Joseph</b> | <b>ID#: 41</b> | <b>00414</b> | <b>Month/Year: Jun-25</b> | <b>Disinfection <i>Giardia</i> Log</b> | <b>Inactiv:</b> | <b>1.0</b> |
|---------------------|-----------------------|----------------|--------------|---------------------------|----------------------------------------|-----------------|------------|

| Date / Time | Minimum<br>Cl <sub>2</sub> Residual<br>at 1st User<br>( C ) <sup>3</sup> | Contact<br>Time<br>(T) | Actual CT    | Temp  | pH   | Required CT | CT Met? <sup>3</sup> | Peak Hourly Demand<br>Flow |
|-------------|--------------------------------------------------------------------------|------------------------|--------------|-------|------|-------------|----------------------|----------------------------|
|             | [ppm or mg/L]                                                            | [minutes]              | <b>C X T</b> | [° C] |      | formula     | Yes / No             | [GPM]                      |
| 1           | 0.36                                                                     | 526                    | 189.4        | 14.7  | 7.68 | 33.2        | YES                  | 972                        |
| 2           | 0.31                                                                     | 527                    | 163.4        | 14.7  | 7.76 | 34.0        | YES                  | 972                        |
| 3           | 0.37                                                                     | 520                    | 192.4        | 14.4  | 7.54 | 32.2        | YES                  | 972                        |
| 4           | 0.38                                                                     | 496                    | 188.5        | 14.5  | 7.74 | 34.5        | YES                  | 972                        |
| 5           | 0.37                                                                     | 510                    | 188.7        | 14.2  | 7.75 | 35.3        | YES                  | 972                        |
| 6           | 0.36                                                                     | 510                    | 183.6        | 14.3  | 7.49 | 31.8        | YES                  | 972                        |
| 7           | 0.38                                                                     | 483                    | 183.5        | 14.2  | 7.46 | 31.8        | YES                  | 972                        |
| 8           | 0.46                                                                     | 483                    | 222.2        | 14.5  | 7.46 | 31.4        | YES                  | 972                        |
| 9           | 0.49                                                                     | 483                    | 236.7        | 14.5  | 7.47 | 31.6        | YES                  | 972                        |
| 10          | 0.54                                                                     | 483                    | 260.8        | 14.8  | 7.43 | 30.7        | YES                  | 972                        |
| 11          | 0.59                                                                     | 483                    | 285.0        | 14.1  | 7.39 | 31.9        | YES                  | 972                        |
| 12          | 0.57                                                                     | 526                    | 299.8        | 14.4  | 7.39 | 31.2        | YES                  | 972                        |
| 13          | 0.51                                                                     | 516                    | 263.2        | 14.3  | 7.69 | 34.9        | YES                  | 972                        |
| 14          | 0.59                                                                     | 526                    | 310.3        | 14.0  | 7.82 | 37.6        | YES                  | 972                        |
| 15          | 0.59                                                                     | 518                    | 305.6        | 14.4  | 7.86 | 37.2        | YES                  | 972                        |
| 16          | 0.55                                                                     | 513                    | 282.2        | 14.4  | 7.51 | 32.5        | YES                  | 972                        |
| 17          | 0.52                                                                     | 503                    | 261.6        | 14.7  | 7.78 | 35.1        | YES                  | 972                        |
| 18          | 0.48                                                                     | 483                    | 231.8        | 14.0  | 7.44 | 32.3        | YES                  | 972                        |
| 19          | 0.46                                                                     | 483                    | 222.2        | 14.2  | 7.46 | 32.0        | YES                  | 972                        |
| 20          | 0.53                                                                     | 492                    | 260.8        | 14.1  | 7.45 | 32.4        | YES                  | 972                        |
| 21          | 0.54                                                                     | 527                    | 284.6        | 13.4  | 7.44 | 33.9        | YES                  | 972                        |
| 22          | 0.49                                                                     | 527                    | 258.2        | 13.2  | 7.43 | 34.0        | YES                  | 972                        |
| 23          | 0.5                                                                      | 526                    | 263.0        | 13.2  | 7.43 | 34.0        | YES                  | 972                        |
| 24          | 0.52                                                                     | 516                    | 268.3        | 13.5  | 7.42 | 33.3        | YES                  | 972                        |
| 25          | 0.48                                                                     | 517                    | 248.2        | 14.2  | 7.42 | 31.6        | YES                  | 972                        |
| 26          | 0.51                                                                     | 505                    | 257.6        | 15.0  | 7.67 | 33.0        | YES                  | 972                        |
| 27          | 0.52                                                                     | 492                    | 255.8        | 15.2  | 7.72 | 33.2        | YES                  | 972                        |
| 28          | 0.5                                                                      | 508                    | 254.0        | 15.2  | 7.94 | 36.0        | YES                  | 972                        |
| 29          | 0.48                                                                     | 483                    | 231.8        | 15.4  | 7.78 | 33.4        | YES                  | 972                        |
| 30          | 0.44                                                                     | 505                    | 222.2        | 15.0  | 7.46 | 30.3        | YES                  | 972                        |
| 31          |                                                                          |                        |              |       |      |             |                      |                            |

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

**Return by 10th of following month by email, fax, or mail to:**

dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350