

OHA - Drinking Water Services - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: **Wallowa**
 Month/Year: **Dec-25**

System Name:		City of Joseph		ID#: 41	00414	WTP : TP -	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1			0.03				0.03
2			0.03				0.03
3			0.03				0.03
4			0.09				0.09
5			0.09				0.09
6			0.12				0.12
7			0.09				0.09
8			0.11				0.11
9			0.13				0.13
10			0.17				0.17
11			0.03				0.03
12			0.02				0.02
13			0.03				0.03
14			0.03				0.03
15			0.02				0.02
16			0.03				0.03
17			0.03				0.03
18			0.03				0.03
19			0.14				0.14
20			0.14				0.14
21			0.11				0.11
22			0.15				0.15
23			0.10				0.10
24			0.10				0.10
25			0.11				0.11
26			0.11				0.11
27			0.13				0.13
28			0.12				0.12
29			0.03				0.03
30			0.01				0.01
31			0.02				0.02

Slow Sand/Membrane/DE Filtration/Unfiltered		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? ²	Yes	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU?	Yes	Yes	Yes

Notes:	PRINTED NAME: Levi Tickner	
	SIGNATURE: 	DATE: 1/10/2026
	PHONE #: (541)760-9362	CERT #:T-008780

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- :

System Name: City of Joseph	ID#: 41	00414	Month/Year:	Disinfection <i>Giardia</i> Log	Inactiv: 1.0
------------------------------------	----------------	--------------	--------------------	--	---------------------

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.39	542	211.4	7.9	7.60	51.1	YES	972
2	0.36	541	194.8	7.8	7.58	50.9	YES	972
3	0.42	544	228.5	7.8	7.59	51.4	YES	972
4	0.4	544	217.6	8.5	8.00	56.7	YES	972
5	0.45	545	245.3	6.9	7.71	57.2	YES	972
6	0.47	536	251.9	7.0	7.69	56.6	YES	972
7	0.45	544	244.8	7.1	7.54	53.1	YES	972
8	0.45	544	244.8	7.1	7.63	54.9	YES	972
9	0.39	527	205.5	7.3	7.54	52.1	YES	972
10	0.48	527	253.0	7.2	7.64	54.9	YES	972
11	0.52	536	278.7	5.7	7.49	57.8	YES	972
12	0.53	536	284.1	5.9	7.48	56.9	YES	972
13	0.51	536	273.4	6.0	7.48	56.4	YES	972
14	0.49	536	262.6	5.9	7.48	56.6	YES	972
15	0.52	540	280.8	5.8	7.48	57.2	YES	972
16	0.54	534	288.4	5.8	7.48	57.4	YES	972
17	0.51	510	260.1	5.9	7.48	56.8	YES	972
18	0.5	501	250.5	6.0	7.48	56.3	YES	972
19	0.45	527	237.2	6.8	8.50	76.8	YES	972
20	0.44	534	235.0	7.0	7.64	55.4	YES	972
21	0.45	538	242.1	6.6	7.65	57.2	YES	972
22	0.42	538	226.0	6.6	7.69	57.8	YES	972
23	0.41	538	220.6	6.2	7.91	64.2	YES	972
24	0.48	527	253.0	6.7	7.69	57.8	YES	972
25	0.5	538	269.0	6.6	7.45	53.5	YES	972
26	0.52	538	279.8	6.6	7.62	57.0	YES	972
27	0.52	538	279.8	6.4	8.67	84.8	YES	972
28	0.54	538	290.5	6.1	8.44	79.7	YES	972
29	0.56	538	301.3	4.2	7.49	64.3	YES	972
30	0.58	538	312.0	4.1	7.49	64.9	YES	972
31	0.57	540	307.8	4.0	7.48	65.0	YES	972

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350