


OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: Coos

Conventional or Direct Filtration

Month/Year: Oct-21

System Name:	Lakeside Water District		ID#4100	463	WTP: TP - A		
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	OFF	OFF	OFF	0.04	0.04	OFF	0.04
2	OFF	OFF	OFF	OFF	0.04	OFF	0.04
3	0.04	OFF	OFF	OFF	0.03	0.04	0.04
4	OFF	OFF	OFF	OFF	0.03	OFF	0.03
5	OFF	OFF	OFF	OFF	0.04	OFF	0.04
6	OFF	OFF	OFF	OFF	0.03	0.04	0.04
7	OFF	OFF	OFF	OFF	0.03	0.03	0.03
8	OFF	OFF	OFF	OFF	0.03	OFF	0.03
9	OFF	OFF	OFF	OFF	0.03	0.04	0.04
10	OFF	OFF	OFF	OFF	0.03	OFF	0.03
11	OFF	OFF	OFF	0.04	OFF	OFF	0.04
12	OFF	OFF	OFF	0.03	0.03	0.03	0.03
13	OFF	OFF	OFF	OFF	0.03	0.03	0.03
14	OFF	OFF	OFF	OFF	0.03	0.03	0.03
15	OFF	OFF	OFF	OFF	0.03	OFF	0.03
16	OFF	OFF	OFF	OFF	0.03	OFF	0.03
17	OFF	OFF	OFF	OFF	0.03	OFF	0.03
18	OFF	OFF	OFF	OFF	0.03	0.03	0.03
19	OFF	OFF	OFF	OFF	0.03	0.03	0.03
20	0.03	OFF	OFF	OFF	OFF	0.03	0.03
21	OFF	OFF	OFF	OFF	0.03	0.03	0.03
22	OFF	OFF	OFF	OFF	0.03	OFF	0.03
23	OFF	OFF	OFF	0.03	0.03	OFF	0.03
24	OFF	OFF	OFF	OFF	0.03	0.03	0.03
25	OFF	OFF	OFF	OFF	0.03	OFF	0.03
26	OFF	OFF	OFF	OFF	0.03	OFF	0.03
27	OFF	OFF	OFF	OFF	0.02	0.03	0.03
28	OFF	OFF	OFF	OFF	0.03	OFF	0.03
29	OFF	OFF	OFF	OFF	0.03	OFF	0.03
30	OFF	OFF	OFF	OFF	0.03	0.03	0.03
31	OFF	OFF	OFF	OFF	0.03	0.03	0.03

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings \leq 0.3 NTU?	YES	CT's met everyday? (see back)	All Cl2 residual at entry point \geq 0.2 mg/l?
All 4-hour turbidity readings \leq 1 NTU?	YES	YES	YES
All turbidity readings < IFE ² triggers	YES		
Notes:		PRINTED NAME: Marty Ball	
		SIGNATURE: 	
		PHONE@541-759-3602	
		DATE 11-1-2021	
		CERT#6276	

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A

System Name: Lakeside Water District ID#: 41 00463 Month/Year: Oct-21 Disinfection *Gardla* Log Inactiv: 0.5

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
10/1/14:30	1.13	55	62.2	18.9	7.05	10.8	YES	450
10/2/15:00	1.14	55	62.7	18.9	7.07	10.9	YES	450
10/3/15:00	1.15	55	63.3	18.9	7.04	10.8	YES	450
10/4/16:30	1.12	55	61.6	18.5	7.08	11.2	YES	450
10/5/15:00	1.17	55	64.4	18.5	7.05	11.2	YES	450
10/6/15:00	1.14	55	62.7	17.8	7.02	11.6	YES	450
10/7/15:00	1.06	55	58.3	17.9	7.10	11.7	YES	450
10/8/15:00	1.1	55	60.5	17.8	7.08	11.8	YES	450
10/9/15:30	1.1	55	60.5	17.6	7.05	11.8	YES	450
10/10/16:00	1.12	55	61.6	17.6	7.07	11.9	YES	450
10/11/14:30	1.14	55	62.7	17.3	7.10	12.3	YES	450
10/12/14:30	1.15	55	63.3	17.3	7.08	12.2	YES	450
10/13/16:00	1.17	55	64.4	17.2	7.10	12.4	YES	450
10/14/15:00	1.19	55	65.5	17.6	7.11	12.2	YES	450
10/15/16:00	1.15	55	63.3	17.5	7.02	11.8	YES	450
10/16/17:00	1.12	55	61.6	17.5	7.07	12.0	YES	450
10/17/15:30	1.12	55	61.6	16.9	7.09	12.6	YES	450
10/18/16:30	1.19	55	65.5	16.7	7.10	12.9	YES	450
10/19/15:00	1.13	55	62.2	16.4	7.17	13.4	YES	450
10/20/18:00	1.18	55	64.9	16.4	7.15	13.4	YES	450
10/21/15:30	1.27	55	69.9	17.5	7.15	12.6	YES	450
10/22/16:00	1.19	55	65.5	17.1	7.12	12.6	YES	450
10/23/15:30	1.13	55	62.2	17.0	7.10	12.5	YES	450
10/24/16:00	1.19	55	65.5	17.1	7.11	12.6	YES	450
10/25/15:30	1.1	55	60.5	17.2	7.06	12.2	YES	450
10/26/16:00	1.09	55	60.0	17.5	7.02	11.7	YES	450
10/27/17:00	1.15	55	63.3	17.3	7.07	12.2	YES	450
10/28/15:30	1.24	55	68.2	17.5	7.08	12.2	YES	450
10/29/15:00	1.18	55	64.9	17.3	7.05	12.1	YES	450
10/30/15:30	1.13	55	62.2	17.1	7.03	12.1	YES	450
10/31/15:30	1.12	55	61.6	17.2	7.05	12.1	YES	450

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2014