

OHA - Drinking Water Services - Turbidity Monitoring Report Form

County: Coos  
 Month/Year: Dec-22

Conventional or Direct Filtration

System Name:	Lakeside Water District			ID#4100	463	WTP : TP - A	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]
1	OFF	0.03	OFF	OFF	0.03	0.03	0.03
2	OFF	OFF	OFF	0.03	0.03	OFF	0.03
3	OFF	OFF	OFF	OFF	0.03	OFF	0.03
4	OFF	OFF	OFF	0.03	OFF	OFF	0.03
5	OFF	OFF	OFF	OFF	0.03	0.03	0.03
6	OFF	OFF	OFF	OFF	0.03	OFF	0.03
7	OFF	OFF	OFF	OFF	0.03	OFF	0.03
8	OFF	OFF	OFF	OFF	0.03	OFF	0.03
9	OFF	OFF	OFF	OFF	0.03	OFF	0.03
10	OFF	OFF	OFF	OFF	0.03	OFF	0.03
11	OFF	OFF	OFF	OFF	0.03	OFF	0.03
12	OFF	OFF	OFF	OFF	0.04	OFF	0.04
13	OFF	OFF	OFF	OFF	0.03	OFF	0.03
14	OFF	OFF	OFF	OFF	0.03	OFF	0.03
15	OFF	OFF	OFF	OFF	0.03	OFF	0.03
16	OFF	OFF	OFF	0.03	OFF	OFF	0.03
17	OFF	OFF	OFF	0.03	0.03	OFF	0.03
18	OFF	OFF	OFF	0.03	OFF	OFF	0.03
19	OFF	OFF	OFF	0.03	OFF	OFF	0.03
20	OFF	OFF	OFF	OFF	0.03	OFF	0.03
21	OFF	OFF	OFF	OFF	0.03	OFF	0.03
22	OFF	OFF	OFF	OFF	0.03	OFF	0.03
23	OFF	OFF	OFF	OFF	0.03	OFF	0.03
24	OFF	OFF	OFF	0.03	OFF	OFF	0.03
25	OFF	OFF	OFF	0.03	OFF	OFF	0.03
26	OFF	OFF	OFF	OFF	0.03	OFF	0.03
27	OFF	OFF	OFF	OFF	0.03	OFF	0.03
28	OFF	OFF	OFF	OFF	0.02	OFF	0.02
29	OFF	OFF	OFF	OFF	0.03	0.03	0.03
30	OFF	OFF	OFF	OFF	0.02	OFF	0.02
31	OFF	OFF	OFF	OFF	0.02	OFF	0.02

<b>Conventional or Direct Filtration</b>		<b>Monthly Summary (Answer Yes or No)</b>	
95% of 4-hour turbidity readings ≤ 0.3 NTU?	YES	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All 4-hour turbidity readings ≤ 1 NTU?	YES	YES	YES
All turbidity readings < IFE <sup>2</sup> triggers	YES		
<b>Notes:</b>		<b>PRINTED NAME: Marty Ball</b>	
		<b>SIGNATURE:</b>	<b>DATE =1-2-2023</b>
		<b>PHONE# 541-759-4602</b>	<b>cert#6276</b>

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> IFE = Indivd. Filter Effl. (333-061-0040(1)(e)(B&C))

Received Time Jan. 4. 2023 7:30AM No.9218

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - :	A
Disinfection <i>Giardia</i> Log Inactiv:	0.5

System Name:	Lakeside Water District	ID#: 41	00463	Month/Year:	Dec-22
--------------	-------------------------	---------	-------	-------------	--------

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
12/1/20:00	1.4	55	77.0	11.3	7.18	19.7	YES	450
12/2/12:00	1.15	55	63.3	10.8	6.95	18.3	YES	450
12/3/15:30	1.17	55	64.4	13.1	7.11	16.4	YES	450
12/4/12:00	1.2	55	66.0	12.8	7.09	16.7	YES	450
12/5/15:30	1.16	55	63.8	13.1	7.02	15.9	YES	450
12/6/15:30	1.11	55	61.1	10.5	7.12	19.7	YES	450
12/7/15:30	1.21	55	66.6	10.8	6.99	18.7	YES	450
12/8/15:00	1.06	55	58.3	10.7	7.19	19.8	YES	450
12/9/15:00	1.13	55	62.2	11.5	7.05	18.1	YES	450
12/10/15:00	1.18	55	64.9	11.3	7.04	18.3	YES	450
12/11/15:00	1.18	55	64.9	11.6	7.10	18.4	YES	450
12/12/15:30	1.09	55	60.0	10.0	7.15	20.5	YES	450
12/13/15:30	1.15	55	63.3	11.0	7.18	19.6	YES	450
12/14/15:30	1.09	55	60.0	10.5	7.19	20.2	YES	450
12/15/15:30	1.05	55	57.8	9.9	7.15	20.6	YES	450
12/16/14:30	1.26	55	69.3	10.8	7.09	19.5	YES	450
12/17/14:30	1.27	55	69.9	10.9	7.11	19.5	YES	450
12/18/14:30	1.16	55	63.8	10.7	7.08	19.3	YES	450
12/19/14:30	1.04	55	57.2	11.4	7.13	18.5	YES	450
12/20/15:30	1.21	55	66.6	10.9	7.17	19.8	YES	450
12/21/15:30	1.1	55	60.5	11.0	6.98	18.2	YES	450
12/22/15:00	1.14	55	62.7	9.3	7.09	21.2	YES	450
12/23/15:00	1.21	55	66.6	10.5	7.15	20.1	YES	450
12/24/14:00	1.15	55	63.3	10.3	7.12	20.1	YES	450
12/25/14:30	1.14	55	62.7	10.3	7.10	19.9	YES	450
12/26/15:00	1.11	55	61.1	11.5	7.06	18.1	YES	450
12/27/15:00	1.27	55	69.9	11.3	7.18	19.4	YES	450
12/28/15:00	1.22	55	67.1	10.1	7.01	19.7	YES	450
12/29/15:30	1.26	55	69.3	11.0	7.15	19.6	YES	450
12/30/15:00	1.13	55	62.2	11.8	7.27	19.1	YES	450
12/31/15:00	1.21	55	66.6	11.6	7.21	19.1	YES	450

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2014