

OHA - Drinking Water Services -Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: Coos
 Month/Year: Apr-23

System Name:	Lakeside Water Distrct		ID#4100	463	WTP : TP - A		
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	OFF	OFF	OFF	OFF	0.03	OFF	0.03
2	OFF	OFF	OFF	0.03	OFF	OFF	0.03
3	OFF	OFF	OFF	0.03	OFF	OFF	0.03
4	OFF	OFF	OFF	OFF	0.03	OFF	0.03
5	OFF	OFF	OFF	OFF	0.03	OFF	0.03
6	OFF	OFF	OFF	0.03	OFF	OFF	0.03
7	OFF	OFF	OFF	OFF	0.03	OFF	0.03
8	OFF	OFF	OFF	OFF	0.03	OFF	0.03
9	OFF	OFF	OFF	OFF	0.03	OFF	0.03
10	OFF	OFF	OFF	0.03	0.03	OFF	0.03
11	OFF	OFF	OFF	0.03	OFF	OFF	0.03
12	OFF	OFF	OFF	0.03	OFF	OFF	0.03
13	OFF	OFF	OFF	0.03	OFF	OFF	0.03
14	OFF	OFF	OFF	0.03	OFF	OFF	0.03
15	OFF	OFF	OFF	OFF	0.03	OFF	0.03
16	OFF	OFF	OFF	0.03	OFF	OFF	0.03
17	OFF	OFF	OFF	0.03	OFF	OFF	0.03
18	OFF	OFF	OFF	OFF	0.03	OFF	0.03
19	OFF	OFF	OFF	OFF	0.03	OFF	0.03
20	OFF	OFF	OFF	0.03	OFF	OFF	0.03
21	OFF	OFF	OFF	0.03	0.03	OFF	0.03
22	OFF	OFF	OFF	0.03	OFF	OFF	0.03
23	OFF	OFF	OFF	0.03	OFF	OFF	0.03
24	OFF	OFF	OFF	0.03	OFF	OFF	0.03
25	OFF	OFF	OFF	0.03	OFF	OFF	0.03
26	OFF	OFF	OFF	0.03	OFF	OFF	0.03
27	OFF	OFF	OFF	0.03	OFF	OFF	0.03
28	OFF	OFF	OFF	0.03	0.03	OFF	0.03
29	OFF	OFF	OFF	OFF	0.03	0.03	0.03
30	OFF	OFF	OFF	0.03	OFF	OFF	0.03
31							

Conventional or Direct Filtration			Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU?	YES	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?	
All 4-hour turbidity readings ≤ 1 NTU?	YES	YES	YES	
All turbidity readings < IFE ² triggers	YES			

Notes:	PRINTED NAME: Marty Ball	
	SIGNATURE: 	DATE 5-1-2023
	PHONE# 541-280-7794	CERT# 6276

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 6 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-001-0040(1)(a)(B&C))

RECEIVED

MAY 01 2023

**Certification
 Drinking Water Services**

Received Time May. 1. 2023 8:20AM No. 9508

OHA - Drinking Water Program - Surface Water Quality Data Form

System Name: Lakeside Water District						ID#: 41	00463	Month/Year: Apr-23	WTP - : A	Disinfection Log Inactiv: 0.5	Giardia
--------------------------------------	--	--	--	--	--	---------	-------	--------------------	-----------	-------------------------------	---------

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
4/1/15:00	1.07	55	58.9	11.0	7.19	19.5	YES	450
4/2/14:30	1.08	55	59.4	10.9	7.21	19.7	YES	450
4/3/14:30	1.07	55	58.9	10.9	7.25	20.0	YES	450
4/4/15:00	1.05	55	57.8	10.8	7.20	19.7	YES	450
4/5/15:00	1.02	55	56.1	11.9	7.18	18.2	YES	450
4/6/14:30	1.03	55	56.7	11.8	7.22	18.6	YES	450
4/7/15:00	1.09	55	60.0	11.9	7.12	18.0	YES	450
4/8/15:00	1.05	55	57.8	12.0	7.15	18.0	YES	450
4/9/15:00	1.11	55	61.1	11.9	7.15	18.2	YES	450
4/10/14:00	1.05	55	57.8	12.6	7.18	17.2	YES	450
4/11/14:30	1.04	55	57.2	11.9	7.20	18.4	YES	450
4/12/14:00	1.09	55	60.0	11.8	7.18	18.5	YES	450
4/13/14:30	1.07	55	58.9	11.7	7.16	18.4	YES	450
4/14/14:30	1.08	55	59.4	11.9	7.20	18.4	YES	450
4/15/15:00	1.08	55	59.4	11.8	7.14	18.2	YES	450
4/16/14:30	1.04	55	57.2	11.9	7.15	18.0	YES	450
4/17/14:00	1.03	55	56.7	12.1	7.04	17.1	YES	450
4/18/15:00	1.01	55	55.6	11.7	7.03	17.5	YES	450
4/19/15:00	1.08	55	59.4	11.9	7.08	17.7	YES	450
4/20/14:30	1.06	55	58.3	12.0	7.10	17.7	YES	450
4/21/14:00	1.04	55	57.2	11.7	7.14	18.2	YES	450
4/22/14:30	1.06	55	58.3	11.9	7.15	18.1	YES	450
4/23/14:30	1.16	55	63.8	11.9	7.17	18.4	YES	450
4/24/14:30	1.13	55	62.2	12.5	7.33	18.5	YES	450
4/25/14:30	1.08	55	59.4	12.1	7.38	19.4	YES	450
4/26/14:30	1.01	55	55.6	14.7	7.32	15.7	YES	450
4/27/14:30	1.12	55	61.6	14.7	7.16	14.9	YES	450
4/28/14:30	1.09	55	60.0	14.8	7.20	15.0	YES	450
4/29/15:00	1.1	55	60.5	14.9	7.19	14.9	YES	450
4/30/14:00	1.07	55	58.9	14.9	7.17	14.7	YES	450
31		55					NO	450

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2014