

OHA - Drinking Water Services - Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: **Coos**
 Month/Year: **Sep-24**

System Name:	Lakeside Water District		ID#4100	463	WTP: TP -			A
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]	
1	OFF	OFF	OFF	0.04	0.04	OFF	0.04	
2	OFF	OFF	OFF	0.04	0.04	OFF	0.04	
3	OFF	OFF	OFF	0.04	0.04	OFF	0.04	
4	OFF	OFF	OFF	0.04	0.04	OFF	0.04	
5	OFF	OFF	OFF	0.03	0.03	OFF	0.03	
6	OFF	OFF	OFF	0.04	0.03	OFF	0.04	
7	OFF	OFF	OFF	0.03	0.04	OFF	0.04	
8	OFF	OFF	OFF	OFF	0.04	0.04	0.04	
9	OFF	OFF	OFF	OFF	0.04	0.04	0.04	
10	OFF	OFF	OFF	0.04	0.04	OFF	0.04	
11	OFF	OFF	OFF	OFF	0.04	0.04	0.04	
12	OFF	OFF	OFF	OFF	0.04	0.04	0.04	
13	OFF	OFF	OFF	0.04	0.04	OFF	0.04	
14	OFF	OFF	OFF	0.04	0.04	OFF	0.04	
15	OFF	OFF	OFF	0.04	0.03	OFF	0.04	
16	OFF	OFF	OFF	0.04	0.03	OFF	0.04	
17	OFF	OFF	OFF	0.03	0.03	OFF	0.03	
18	OFF	OFF	OFF	0.04	0.04	OFF	0.04	
19	OFF	OFF	OFF	0.04	0.04	OFF	0.04	
20	OFF	OFF	OFF	0.04	0.04	OFF	0.04	
21	OFF	OFF	OFF	0.04	0.04	OFF	0.04	
22	OFF	OFF	OFF	0.04	0.04	OFF	0.04	
23	OFF	OFF	OFF	0.04	0.04	OFF	0.04	
24	OFF	OFF	OFF	0.04	0.04	OFF	0.04	
25	OFF	OFF	OFF	0.04	0.03	OFF	0.04	
26	OFF	OFF	OFF	0.04	0.04	OFF	0.04	
27	OFF	OFF	OFF	0.04	0.04	OFF	0.04	
28	OFF	OFF	OFF	0.04	0.04	OFF	0.04	
29	OFF	OFF	OFF	0.04	0.04	OFF	0.04	
30	OFF	OFF	OFF	0.04	0.04	OFF	0.04	
31								

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
85% of 4-hour turbidity readings ≤ 0.3 NTU?	YES	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All 4-hour turbidity readings ≤ 1 NTU?	YES	YES	YES
All turbidity readings < IFE ² triggers	YES		

Notes:

PRINTED NAME: Marty Ball
 SIGNATURE: 
 PHONE: 541-260-7794
 DATE: 10-2-2024
 CERT# 6276

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Eff. (393-081-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A

System Name: Lakeside Water District ID#: 41 00463 Month/Year: Sep-24 Disinfection G/ardis Log Inactiv: 0.5

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³ [ppm or mg/L]	Contact Time (T) [minutes]	Actual CT C X T	Temp [° C]	pH	Required CT formula	CT Met? ³ Yes / No	Peak Hourly Demand Flow [GPM]
9/1/13:30	1.15	55	63.3	22.9	7.19	8.7	YES	450
9/2/14:00	1.17	55	64.4	22.9	7.15	8.6	YES	450
9/3/13:30	1.1	55	60.5	21.3	7.14	9.5	YES	450
9/4/13:30	1.07	55	58.9	22.4	7.14	8.8	YES	450
9/5/14:30	1.14	55	62.7	21.7	6.94	8.6	YES	450
9/6/14:00	1.1	55	60.5	21.5	7.02	9.0	YES	450
9/7/14:00	1.08	55	59.4	21.4	7.05	9.1	YES	450
9/8/15:00	1.15	55	63.3	21.4	7.07	9.2	YES	450
9/9/15:00	1.28	55	70.4	22.8	7.18	8.9	YES	450
9/10/14:00	1.01	55	55.6	22.9	7.08	8.2	YES	450
9/11/15:30	1.07	55	58.9	21.4	7.14	9.4	YES	450
9/12/15:30	1.07	55	58.9	21.2	7.17	9.6	YES	450
9/13/14:30	1.27	55	69.9	21.0	7.01	9.4	YES	450
9/14/14:00	1.14	55	62.7	21.1	7.02	9.2	YES	450
9/15/14:00	1.14	55	62.7	21.2	7.03	9.2	YES	450
9/16/14:00	1.1	55	60.5	21.2	7.21	9.8	YES	450
9/17/14:00	1.12	55	61.6	21.0	7.14	9.7	YES	450
9/18/14:00	1.13	55	62.2	21.2	7.22	9.9	YES	450
9/19/14:00	1.21	55	66.6	21.1	7.18	9.9	YES	450
9/20/14:00	1.04	55	57.2	20.1	6.99	9.7	YES	450
9/21/14:00	1.13	55	62.2	20.8	7.04	9.5	YES	450
9/22/14:00	1.06	55	58.3	20.8	7.11	9.7	YES	450
9/23/14:30	1.15	55	63.3	20.5	7.11	10.0	YES	450
9/24/14:00	1.01	55	55.6	21.9	7.18	9.2	YES	450
9/25/14:00	1	55	55.0	20.6	7.03	9.4	YES	450
9/26/14:30	1.01	55	55.6	20.5	7.12	9.8	YES	450
9/27/14:30	1.02	55	58.1	20.2	7.12	10.1	YES	450
9/28/14:00	1.03	55	58.7	20.3	7.11	10.0	YES	450
9/29/14:00	1.02	55	58.1	20.3	7.12	10.0	YES	450
9/30/14:00	1.11	55	61.1	20.4	7.14	10.1	YES	450
31		55					NO	450

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2014