

OHA - Drinking Water Services -Turbidity Monitoring Report Form

Conventional or Direct Filtration

County: **Coos**
 Month/Year: **Feb-25**

System Name:	Lakeside Water District		ID#4100	463	WTP : TP - A		
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	OFF	OFF	OFF	OFF	0.04	OFF	0.04
2	OFF	OFF	OFF	OFF	0.04	OFF	0.04
3	OFF	OFF	OFF	OFF	0.04	OFF	0.04
4	OFF	OFF	OFF	OFF	0.05	OFF	0.05
5	OFF	OFF	OFF	0.04	OFF	OFF	0.04
6	OFF	OFF	OFF	0.05	OFF	OFF	0.05
7	OFF	OFF	OFF	OFF	0.05	OFF	0.05
8	OFF	OFF	OFF	OFF	0.04	OFF	0.04
9	OFF	OFF	OFF	0.04	0.04	OFF	0.04
10	OFF	OFF	OFF	0.05	0.05	OFF	0.05
11	OFF	OFF	OFF	0.04	OFF	OFF	0.04
12	OFF	OFF	OFF	0.04	OFF	OFF	0.04
13	OFF	OFF	OFF	OFF	0.05	0.05	0.05
14	OFF	OFF	OFF	0.05	OFF	OFF	0.05
15	OFF	OFF	OFF	0.05	0.05	OFF	0.05
16	OFF	OFF	OFF	OFF	0.04	OFF	0.04
17	OFF	OFF	OFF	OFF	0.05	OFF	0.05
18	OFF	OFF	OFF	OFF	0.05	0.05	0.05
19	OFF	OFF	OFF	OFF	0.05	OFF	0.05
20	OFF	OFF	OFF	OFF	0.05	0.05	0.05
21	OFF	OFF	OFF	0.05	OFF	OFF	0.05
22	OFF	OFF	OFF	0.05	OFF	OFF	0.05
23	OFF	OFF	OFF	0.05	OFF	OFF	0.05
24	OFF	OFF	OFF	0.05	OFF	OFF	0.05
25	OFF	OFF	OFF	0.05	OFF	OFF	0.05
26	OFF	OFF	OFF	0.05	OFF	OFF	0.05
27	OFF	OFF	OFF	0.06	OFF	OFF	0.06
28	OFF	OFF	OFF	OFF	0.05	OFF	0.05
29							
30							
31							

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU? YES	CT's met everyday? (see back) YES	All Cl2 residual at entry point ≥ 0.2 mg/l? YES
All 4-hour turbidity readings ≤ 1 NTU? YES		
All turbidity readings < IFE ² triggers YES		

Notes:	PRINTED NAME: Marty Ball
	SIGNATURE: 
	PHONE# 541-250-7784
	DATE= 3-2-2025
	CERT# 6276

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Eff. (333-061-0040(1)(e)(B&C))

Received Time Mar. 3. 2025 6:39AM No. 0878

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A

System Name: Lakeside Water District ID#: 41 00463 Month/Year: Feb-25 Disinfection *Giardia* Log Inactiv: 0.5

Data / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
2/1/15:00	1.05	55	57.8	9.8	7.11	20.4	YES	450
2/2/15:00	1.07	55	58.9	9.7	7.10	20.5	YES	450
2/3/15:00	1.15	55	63.3	11.0	7.14	19.3	YES	450
2/4/15:45	1.21	55	66.6	11.1	7.16	19.4	YES	450
2/5/14:30	1.22	55	67.1	10.5	7.18	20.4	YES	450
2/6/14:00	1.01	55	55.6	9.4	7.26	22.2	YES	450
2/7/15:30	1.12	55	61.6	10.4	7.19	20.4	YES	450
2/8/15:00	1.14	55	62.7	10.2	7.18	20.6	YES	450
2/9/12:30	1.01	55	55.6	10.3	7.10	19.6	YES	450
2/10/12:30	0.98	55	53.9	10.3	7.13	19.8	YES	450
2/11/14:00	0.95	55	52.3	10.4	7.10	19.4	YES	450
2/12/15:00	0.92	55	50.6	9.1	7.14	21.3	YES	450
2/13/14:30	1.05	55	57.8	10.4	7.18	20.1	YES	450
2/14/15:00	1.27	55	69.9	10.9	7.12	19.6	YES	450
2/15/13:30	1.19	55	65.5	10.8	7.13	19.6	YES	450
2/16/15:00	1.1	55	60.5	10.9	7.14	19.3	YES	450
2/17/15:00	1.1	55	60.5	10.9	7.17	19.5	YES	450
2/18/15:00	1.08	55	58.3	9.8	7.08	20.5	YES	450
2/19/15:00	1.1	55	60.5	10.3	7.12	19.9	YES	450
2/20/15:00	1.08	55	59.4	11.0	7.18	19.4	YES	450
2/21/14:00	1.14	55	62.7	11.4	7.27	19.6	YES	450
2/22/14:30	1.18	55	64.9	11.6	7.26	19.4	YES	450
2/23/14:30	1.09	55	60.0	11.5	7.21	19.0	YES	450
2/24/13/45	1.27	55	69.9	10.9	7.04	19.0	YES	450
2/25/14:30	1.11	55	61.1	11.4	7.14	18.7	YES	450
2/26/14:00	1.1	55	60.5	11.5	7.10	18.3	YES	450
2/27/14:00	1.21	55	66.6	11.6	7.12	18.6	YES	450
2/28/15:00	1.17	55	64.4	11.8	7.10	18.1	YES	450
29		55					NO	450
30		55					NO	450
31		55					NO	450

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2014