

## OHA - Drinking Water Services -Turbidity Monitoring Report Form


County: Coos

Conventional or Direct Filtration

Month/Year: Oct-25

| System Name: | Lakeside Water District | ID# 4100   | 463        | WTP : TP - A |            |            |                                               |
|--------------|-------------------------|------------|------------|--------------|------------|------------|-----------------------------------------------|
| Day          | 12 AM [NTU]             | 4 AM [NTU] | 8 AM [NTU] | NOON [NTU]   | 4 PM [NTU] | 8 PM [NTU] | Highest Reading of the Day <sup>1</sup> [NTU] |
| 1            | OFF                     | OFF        | OFF        | OFF          | 0.05       | OFF        | 0.05                                          |
| 2            | OFF                     | OFF        | OFF        | OFF          | OFF        | 0.04       | 0.04                                          |
| 3            | OFF                     | OFF        | OFF        | OFF          | 0.03       | OFF        | 0.03                                          |
| 4            | OFF                     | OFF        | OFF        | OFF          | 0.03       | OFF        | 0.03                                          |
| 5            | OFF                     | OFF        | OFF        | OFF          | 0.04       | 0.04       | 0.04                                          |
| 6            | OFF                     | OFF        | OFF        | OFF          | 0.04       | OFF        | 0.04                                          |
| 7            | OFF                     | OFF        | OFF        | OFF          | 0.04       | 0.04       | 0.04                                          |
| 8            | OFF                     | OFF        | OFF        | OFF          | 0.03       | OFF        | 0.03                                          |
| 9            | OFF                     | OFF        | OFF        | OFF          | 0.04       | OFF        | 0.04                                          |
| 10           | OFF                     | OFF        | OFF        | OFF          | 0.04       | OFF        | 0.04                                          |
| 11           | OFF                     | OFF        | OFF        | 0.04         | OFF        | OFF        | 0.04                                          |
| 12           | OFF                     | OFF        | OFF        | 0.04         | OFF        | OFF        | 0.04                                          |
| 13           | OFF                     | OFF        | OFF        | OFF          | 0.04       | OFF        | 0.04                                          |
| 14           | OFF                     | OFF        | OFF        | OFF          | 0.04       | OFF        | 0.04                                          |
| 15           | OFF                     | OFF        | OFF        | OFF          | 0.04       | OFF        | 0.04                                          |
| 16           | OFF                     | OFF        | OFF        | OFF          | 0.04       | OFF        | 0.04                                          |
| 17           | OFF                     | OFF        | OFF        | OFF          | 0.04       | OFF        | 0.04                                          |
| 18           | OFF                     | OFF        | OFF        | OFF          | 0.04       | OFF        | 0.04                                          |
| 19           | OFF                     | OFF        | OFF        | 0.04         | 0.04       | OFF        | 0.04                                          |
| 20           | OFF                     | OFF        | OFF        | 0.04         | 0.04       | OFF        | 0.04                                          |
| 21           | OFF                     | OFF        | OFF        | OFF          | 0.04       | 0.04       | 0.04                                          |
| 22           | OFF                     | OFF        | OFF        | OFF          | 0.04       | OFF        | 0.04                                          |
| 23           | OFF                     | OFF        | OFF        | 0.04         | OFF        | OFF        | 0.04                                          |
| 24           | OFF                     | OFF        | OFF        | OFF          | 0.04       | OFF        | 0.04                                          |
| 25           | OFF                     | OFF        | OFF        | 0.04         | OFF        | OFF        | 0.04                                          |
| 26           | OFF                     | OFF        | OFF        | OFF          | 0.04       | OFF        | 0.04                                          |
| 27           | OFF                     | OFF        | OFF        | 0.04         | OFF        | OFF        | 0.04                                          |
| 28           | OFF                     | OFF        | OFF        | 0.04         | OFF        | OFF        | 0.04                                          |
| 29           | OFF                     | OFF        | OFF        | OFF          | 0.04       | OFF        | 0.04                                          |
| 30           | OFF                     | OFF        | OFF        | 0.04         | OFF        | OFF        | 0.04                                          |
| 31           | OFF                     | OFF        | OFF        | OFF          | 0.04       | OFF        | 0.04                                          |

| Conventional or Direct Filtration                  |     | Monthly Summary (Answer Yes or No) |                                                     |
|----------------------------------------------------|-----|------------------------------------|-----------------------------------------------------|
| 95% of 4-hour turbidity readings $\leq$ 0.3 NTU?   | YES | CT's met everyday?<br>(see back)   | All Cl2 residual at entry point<br>$\geq$ 0.2 mg/l? |
| All 4-hour turbidity readings $\leq$ 1 NTU?        | YES | YES                                | YES                                                 |
| All turbidity readings < IFE <sup>2</sup> triggers | YES |                                    |                                                     |

|        |                                                                                                 |                |
|--------|-------------------------------------------------------------------------------------------------|----------------|
| Notes: | PRINTED NAME: Marty Ball                                                                        |                |
|        | SIGNATURE:  | DATE 11-1-2025 |
|        | PHONE# 541-880-7794                                                                             | CERT# 6276     |

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Eff. (333-061-0040(1)(e)(B&C))



## OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A

System Name: Lakeside Water District ID#: 41 00463 Month/Year: Oct-25 Disinfection *Giardia* Log Inactly: 0.5

| Date / Time | Minimum Cl <sub>2</sub> Residual at 1st User (C) <sup>3</sup> | Contact Time (T) | Actual CT | Temp  | pH   | Required CT | CT Met? <sup>3</sup> | Peak Hourly Demand Flow |
|-------------|---------------------------------------------------------------|------------------|-----------|-------|------|-------------|----------------------|-------------------------|
|             | [ppm or mg/L]                                                 | [minutes]        | C X T     | [° C] |      | formula     | Yes / No             | [GPM]                   |
| 10/1/15:00  | 1.01                                                          | 55               | 55.6      | 20.0  | 7.18 | 10.4        | YES                  | 450                     |
| 10/2/21:30  | 1.1                                                           | 55               | 60.5      | 20.0  | 7.16 | 10.4        | YES                  | 450                     |
| 10/3/15:30  | 1.18                                                          | 55               | 64.9      | 19.8  | 7.06 | 10.3        | YES                  | 450                     |
| 10/4/15:00  | 1.12                                                          | 55               | 61.6      | 19.6  | 7.09 | 10.5        | YES                  | 450                     |
| 10/5/15:00  | 1.02                                                          | 55               | 58.1      | 19.9  | 7.10 | 10.2        | YES                  | 450                     |
| 10/6/15:00  | 1.08                                                          | 55               | 59.4      | 20.0  | 7.08 | 10.1        | YES                  | 450                     |
| 10/7/15:00  | 1.06                                                          | 55               | 58.3      | 19.2  | 7.05 | 10.5        | YES                  | 450                     |
| 10/8/15:00  | 1.14                                                          | 55               | 62.7      | 19.3  | 7.07 | 10.6        | YES                  | 450                     |
| 10/9/15:00  | 1.11                                                          | 55               | 61.1      | 19.5  | 7.10 | 10.8        | YES                  | 450                     |
| 10/10/15:30 | 1.09                                                          | 55               | 60.0      | 18.9  | 7.12 | 11.1        | YES                  | 450                     |
| 10/11/14:30 | 1.07                                                          | 55               | 58.9      | 18.7  | 7.14 | 11.3        | YES                  | 450                     |
| 10/12/14:00 | 1.14                                                          | 55               | 62.7      | 19.1  | 7.10 | 10.9        | YES                  | 450                     |
| 10/13/15:00 | 1.1                                                           | 55               | 60.5      | 18.9  | 7.14 | 11.2        | YES                  | 450                     |
| 10/14/15:30 | 1.01                                                          | 55               | 55.6      | 18.8  | 7.11 | 11.0        | YES                  | 450                     |
| 10/15/16:00 | 1.28                                                          | 55               | 69.3      | 17.8  | 7.17 | 12.4        | YES                  | 450                     |
| 10/16/15:30 | 1.23                                                          | 55               | 67.7      | 17.6  | 7.09 | 12.2        | YES                  | 450                     |
| 10/17/15:00 | 1.13                                                          | 55               | 62.2      | 17.1  | 7.12 | 12.6        | YES                  | 450                     |
| 10/18/15:00 | 1.12                                                          | 55               | 61.6      | 17.0  | 7.15 | 12.8        | YES                  | 450                     |
| 10/19/14:30 | 1.29                                                          | 55               | 71.0      | 16.9  | 7.19 | 13.3        | YES                  | 450                     |
| 10/20/14:00 | 1.04                                                          | 55               | 57.2      | 17.0  | 7.18 | 12.8        | YES                  | 450                     |
| 10/21/15:00 | 1.19                                                          | 55               | 65.5      | 17.6  | 7.12 | 12.2        | YES                  | 450                     |
| 10/22/15:30 | 1.04                                                          | 55               | 57.2      | 17.8  | 7.16 | 12.0        | YES                  | 450                     |
| 10/23/14:30 | 1.06                                                          | 55               | 58.3      | 17.4  | 7.11 | 12.2        | YES                  | 450                     |
| 10/24/15:00 | 1.1                                                           | 55               | 60.5      | 17.2  | 7.09 | 12.3        | YES                  | 450                     |
| 10/25/14:30 | 1.14                                                          | 55               | 62.7      | 16.8  | 7.07 | 12.6        | YES                  | 450                     |
| 10/26/15:00 | 1.02                                                          | 55               | 58.1      | 15.9  | 7.05 | 13.1        | YES                  | 450                     |
| 10/27/14:30 | 1.07                                                          | 55               | 58.9      | 16.0  | 7.01 | 12.9        | YES                  | 450                     |
| 10/28/14:30 | 1.02                                                          | 55               | 56.1      | 16.6  | 7.09 | 12.7        | YES                  | 450                     |
| 10/29/15:00 | 0.98                                                          | 55               | 53.9      | 17.1  | 7.05 | 12.0        | YES                  | 450                     |
| 10/30/14:30 | 1.13                                                          | 55               | 62.2      | 16.6  | 7.03 | 12.6        | YES                  | 450                     |
| 10/31/15:00 | 1.15                                                          | 55               | 63.3      | 16.3  | 7.05 | 12.9        | YES                  | 450                     |

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2014

PAGE 2 of 2