

OHA - Drinking Water Services -Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: **Coccos**
 Month/Year: **Dec-25**

System Name:	Lakeside Water District			ID# 4100	483	WTP: TP - A	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	OFF	OFF	OFF	OFF	OFF	0.03	0.03
2	OFF	OFF	OFF	OFF	OFF	0.04	0.04
3	OFF	OFF	OFF	OFF	OFF	0.04	0.04
4	OFF	OFF	OFF	OFF	OFF	0.04	0.04
5	OFF	OFF	OFF	OFF	0.03	OFF	0.03
6	OFF	OFF	OFF	OFF	0.04	OFF	0.04
7	OFF	OFF	OFF	OFF	OFF	0.04	0.04
8	OFF	OFF	OFF	OFF	OFF	0.03	0.03
9	OFF	OFF	OFF	OFF	OFF	0.04	0.04
10	OFF	OFF	OFF	OFF	OFF	0.03	0.03
11	OFF	OFF	OFF	OFF	OFF	0.04	0.04
12	OFF	OFF	OFF	OFF	0.04	OFF	0.03
13	OFF	OFF	OFF	OFF	0.04	OFF	0.04
14	OFF	OFF	OFF	OFF	0.04	OFF	0.04
15	OFF	OFF	OFF	OFF	0.04	OFF	0.04
16	OFF	OFF	OFF	OFF	0.04	OFF	0.04
17	OFF	OFF	OFF	OFF	0.04	OFF	0.04
18	OFF	OFF	OFF	0.04	OFF	OFF	0.04
19	OFF	OFF	OFF	OFF	0.04	OFF	0.04
20	OFF	OFF	OFF	OFF	0.04	OFF	0.04
21	OFF	OFF	OFF	OFF	0.04	OFF	0.04
22	OFF	OFF	OFF	OFF	0.04	OFF	0.04
23	OFF	OFF	OFF	0.04	OFF	OFF	0.04
24	OFF	OFF	OFF	OFF	0.04	OFF	0.04
25	OFF	OFF	OFF	OFF	0.03	OFF	0.03
26	OFF	OFF	OFF	OFF	0.04	OFF	0.04
27	OFF	OFF	OFF	OFF	0.04	OFF	0.04
28	OFF	OFF	OFF	0.04	OFF	OFF	0.04
29	OFF	OFF	OFF	OFF	0.04	OFF	0.04
30	OFF	OFF	OFF	0.04	OFF	OFF	0.04
31	OFF	OFF	OFF	0.04	OFF	OFF	0.04

Conventional or Direct Filtration			Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU?	YES		CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All 4-hour turbidity readings ≤ 1 NTU?	YES		YES	YES
All turbidity readings < IFE ² triggers	YES			
Notes:			PRINTED NAME: Marty Ball SIGNATURE:  PHONE# 541-260-7794	
			DATE 1-1-2026 CERT# 6276	

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Indivd. Filter Eff. (333-081-0040(1)(e)(B&C))



OHA - Drinking Water Program - Surface Water Quality Data Form

System Name: Lakeside Water District					ID#: 41	00463	Month/Year: Dec-25	WTP -: A	Disinfection <i>Giardia</i> Log Inactiv: 0.5
--------------------------------------	--	--	--	--	---------	-------	--------------------	----------	--

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³ [ppm or mg/L]	Contact Time (T) [minutes]	Actual CT C X T	Temp [° C]	pH	Required CT formula	CT Met? ³ Yes / No	Peak Hourly Demand Flow [GPM]
12/1/18:00	1.12	55	61.6	13.9	7.09	15.4	YES	450
12/2/18:00	1.18	55	64.9	13.8	7.12	15.7	YES	450
12/3/18:30	1.24	55	68.2	13.5	7.17	16.5	YES	450
12/4/17:45	1.18	55	64.9	13.7	7.14	16.0	YES	450
12/5/17:00	1.24	55	68.2	13.4	7.10	16.2	YES	450
12/6/16:00	1.15	55	63.3	13.6	7.17	16.2	YES	450
12/7/17:30	1.12	55	61.6	13.7	7.15	15.9	YES	450
12/8/17:30	1.1	55	60.5	13.7	7.12	15.7	YES	450
12/9/16:00	1.19	55	65.5	13.8	7.15	15.9	YES	450
12/10/17:30	1.15	55	63.3	13.6	7.08	15.7	YES	450
12/11/17:30	1.18	55	64.9	13.6	7.05	15.6	YES	450
12/12/15:30	1.16	55	63.8	13.7	7.09	15.6	YES	450
12/13/15:30	1.14	55	62.7	13.6	7.12	15.9	YES	450
12/14/15:00	1.02	55	58.1	13.5	7.10	15.7	YES	450
12/15/15:00	1.1	55	60.5	13.6	7.11	15.8	YES	450
12/16/15:30	1.07	55	58.9	13.6	7.12	15.8	YES	450
12/17/15:30	1	55	55.0	13.9	7.03	14.8	YES	450
12/18/14:00	1.1	55	60.5	13.9	7.08	15.3	YES	450
12/19/16:00	1.17	55	64.4	13.8	7.10	15.6	YES	450
12/20/16:30	1.16	55	63.8	13.6	7.15	16.1	YES	450
12/21/15:00	1.15	55	63.3	13.4	7.11	16.1	YES	450
12/22/15:00	1.1	55	60.5	13.3	7.10	16.0	YES	450
12/23/14:30	1.13	55	62.2	13.2	7.09	16.1	YES	450
12/24/15:00	1.15	55	63.3	13.0	7.10	16.4	YES	450
12/25/15:00	1.12	55	61.6	12.8	7.01	16.1	YES	450
12/26/15:30	1.18	55	64.9	12.9	7.10	16.6	YES	450
12/27/16:00	1.19	55	65.5	12.7	7.08	16.7	YES	450
12/28/14:30	1.12	55	61.6	12.7	7.10	16.7	YES	450
12/29/16:00	1.18	55	64.9	12.8	7.06	16.5	YES	450
12/30/14:30	1.08	55	59.4	12.0	7.04	17.3	YES	450
12/31/14:30	1.08	55	59.4	12.6	7.05	16.5	YES	450

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2014