

OHA - Drinking Water Services - Turbidity Monitoring Report Form

County: Coos  
 Month/Year: Jan-26

Conventional or Direct Filtration

System Name: Lakeside Water District ID#4100 463 WTP: TP - A

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]
1	OFF	OFF	OFF	OFF	0.04	OFF	0.04
2	OFF	OFF	OFF	OFF	0.03	OFF	0.03
3	OFF	OFF	OFF	OFF	0.04	OFF	0.04
4	OFF	OFF	OFF	OFF	0.04	OFF	0.04
5	OFF	OFF	OFF	OFF	0.04	OFF	0.04
6	OFF	OFF	OFF	OFF	0.03	OFF	0.03
7	OFF	OFF	OFF	OFF	0.04	OFF	0.04
8	OFF	OFF	OFF	OFF	0.03	OFF	0.03
9	OFF	OFF	OFF	0.04	OFF	OFF	0.04
10	OFF	OFF	OFF	OFF	0.03	OFF	0.03
11	OFF	OFF	OFF	0.03	OFF	OFF	0.03
12	OFF	OFF	OFF	OFF	0.03	OFF	0.03
13	OFF	OFF	OFF	0.04	OFF	OFF	0.04
14	OFF	OFF	OFF	OFF	0.04	OFF	0.04
15	OFF	OFF	OFF	OFF	0.04	OFF	0.04
16	OFF	OFF	OFF	OFF	0.04	OFF	0.04
17	OFF	OFF	OFF	OFF	0.04	OFF	0.04
18	OFF	OFF	OFF	0.04	OFF	OFF	0.04
19	OFF	OFF	OFF	0.04	OFF	OFF	0.04
20	OFF	OFF	OFF	OFF	0.04	0.04	0.04
21		PLANT	OFF		PLANT	OFF	
22	OFF	OFF	OFF	0.04	0.04	OFF	0.04
23	OFF	OFF	OFF	OFF	0.04	OFF	0.04
24	OFF	OFF	OFF	OFF	0.04	OFF	0.04
25	OFF	OFF	OFF	OFF	0.04	OFF	0.04
26	OFF	OFF	OFF	OFF	0.04	OFF	0.04
27	OFF	OFF	OFF	0.04	OFF	OFF	0.04
28	OFF	OFF	OFF	OFF	0.04	OFF	0.04
29	OFF	OFF	OFF	0.04	OFF	OFF	0.04
30	OFF	OFF	OFF	OFF	0.03	OFF	0.03
31	OFF	OFF	OFF	0.04	OFF	OFF	0.04

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings $\leq$ 0.3 NTU? YES	CT's met everyday? (see back) YES	All Cl <sub>2</sub> residual at entry point $\geq$ 0.2 mg/l? YES
All 4-hour turbidity readings $\leq$ 1 NTU? YES		
All turbidity readings $<$ IFE <sup>2</sup> triggers YES		

Notes: PRINTED NAME: Marty Ball  
 SIGNATURE:   
 PHONE# 541-288-7794 DATE 2-1-2026  
 CERT#6276

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Eff. (393-061-0040(1)(e)(B&C))



OHA - Drinking Water Program - Surface Water Quality Data Form

System Name:	Lakeside Water District	ID#: 41	00483	Month/Year:	JAN 1 2026	WTP - : Disinfection <i>Giardia</i> Log Inactivy:	A 0.5
--------------	-------------------------	---------	-------	-------------	------------	---------------------------------------------------------	----------

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1/1/16:00	1.13	55	62.2	11.9	7.03	17.5	YES	450
1/2/15:30	1.05	55	57.8	12.1	7.05	17.2	YES	450
1/3/16:00	1.14	55	62.7	11.9	7.07	17.8	YES	450
1/4/15:00	1.08	55	59.4	12.0	7.12	17.8	YES	450
1/5/15:00	1.1	55	60.5	12.1	7.10	17.6	YES	450
1/6/15:15	1.18	55	64.9	12.6	7.12	17.1	YES	450
1/7/16:30	1.1	55	60.5	13.0	7.18	16.8	YES	450
1/8/15:00	1.11	55	61.1	13.1	7.20	16.9	YES	450
1/9/14:30	1.02	55	56.1	13.0	7.21	16.9	YES	450
1/10/15:00	1.14	55	62.7	13.1	7.13	16.5	YES	450
1/11/14:30	0.99	55	54.5	12.9	7.20	16.9	YES	450
1/12/15:00	1.05	55	57.8	12.8	7.21	17.1	YES	450
1/13/14:30	1.07	55	58.9	13.1	7.13	16.4	YES	450
1/14/16:00	1.07	55	58.9	13.0	7.16	16.6	YES	450
1/15/16:00	1.04	55	57.2	12.5	7.20	17.4	YES	450
1/16/15:30	1.02	65	66.1	12.3	7.12	17.4	YES	450
1/17/15:00	1.07	55	58.9	11.9	7.15	18.1	YES	450
1/18/14:30	1.08	55	59.4	11.7	7.19	18.6	YES	450
1/19/14:30	1.12	55	61.6	11.9	7.08	17.8	YES	450
1/20/16:30	1.09	55	60.0	11.8	7.09	17.9	YES	450
1/21 2026		55	PLANT OFF			PLANT OFF		450
1/22/14:00	1.08	55	59.4	11.9	7.02	17.3	YES	450
1/23/15:00	1.05	55	57.8	10.5	7.04	19.0	YES	450
1/24/15:00	1.1	55	60.5	10.4	7.09	19.6	YES	450
1/25/15:00	1.05	55	57.8	10.2	7.01	19.2	YES	450
1/26/15:00	1.1	55	60.5	10.4	7.10	19.7	YES	450
1/27/14:30	1.08	55	59.4	10.2	7.11	20.0	YES	450
1/28/15:00	1.09	55	60.0	10.3	7.10	19.6	YES	450
1/29/14:30	1.02	55	56.1	10.4	7.11	19.6	YES	450
1/30/16:00	1.1	55	60.5	10.6	7.14	19.7	YES	450
1/31/14:30	1.14	55	62.7	10.7	7.09	19.3	YES	450

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2014