

OHA - Drinking Water Services -Turbidity Monitoring Report Form


County:	COOS
Month/Year:	May-21

Conventional or Direct Filtration

System Name:	Lakeside Water District		ID#4100	463	WTP : TP - A		
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]
1	OFF	OFF	OFF	OFF	0.03	0.03	0.03
2	OFF	OFF	OFF	OFF	0.03	0.03	0.03
3	OFF	OFF	OFF	OFF	0.03	0.03	0.03
4	OFF	OFF	OFF	OFF	0.03	OFF	0.03
5	OFF	OFF	OFF	0.03	0.03	OFF	0.03
6	OFF	OFF	OFF	OFF	0.03	OFF	0.03
7	OFF	OFF	OFF	OFF	0.03	0.03	0.03
8	OFF	OFF	OFF	OFF	0.03	0.03	0.03
9	OFF	OFF	OFF	OFF	0.03	0.03	0.03
10	OFF	OFF	OFF	OFF	0.03	0.04	0.04
11	OFF	OFF	OFF	OFF	0.04	0.04	0.04
12	OFF	OFF	OFF	OFF	0.04	0.04	0.04
13	OFF	OFF	OFF	OFF	0.03	0.03	0.03
14	OFF	OFF	OFF	OFF	0.03	OFF	0.03
15	OFF	OFF	OFF	OFF	0.04	0.04	0.04
16	OFF	OFF	OFF	OFF	0.04	0.04	0.04
17	OFF	OFF	OFF	OFF	0.04	OFF	0.04
18	OFF	OFF	OFF	OFF	0.04	OFF	0.04
19	OFF	OFF	OFF	0.04	OFF	OFF	0.04
20	OFF	OFF	OFF	0.04	0.04	OFF	0.04
21	OFF	OFF	OFF	OFF	0.04	0.04	0.04
22	OFF	OFF	OFF	0.04	0.04	OFF	0.04
23	OFF	OFF	OFF	0.04	0.04	OFF	0.04
24	OFF	OFF	OFF	OFF	0.04	0.04	0.04
25	OFF	OFF	OFF	OFF	0.04	OFF	0.04
26	OFF	OFF	OFF	0.04	0.04	OFF	0.04
27	OFF	OFF	OFF	0.04	OFF	OFF	0.04
28	OFF	OFF	OFF	0.04	0.04	OFF	0.04
29	OFF	OFF	OFF	0.04	0.04	0.04	0.04
30	OFF	OFF	OFF	0.04	0.04	OFF	0.04
31	OFF	OFF	OFF	0.04	0.04	0.04	0.04

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU? <b>YES</b>	CT's met everyday? (see back) <b>YES</b>	All Cl2 residual at entry point ≥ 0.2 mg/l? <b>YES</b>
All 4-hour turbidity readings ≤ 1 NTU? <b>YES</b>		
All turbidity readings < IFE <sup>2</sup> triggers <b>YES</b>		

Notes:

PRINTED NAME: Marty Ball	
SIGNATURE: 	DATE 6-3-21
PHONE# 541-769-3602	CERT#6276

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - :	A
Disinfection <i>Giardia</i> Log Inactiv:	0.5

System Name: Lakeside Water District ID#: 41 00463 Month/Year: May-21

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User (C) <sup>3</sup> [ppm or mg/L]	Contact Time (T) [minutes]	Actual CT C X T	Temp [° C]	pH	Required CT formula	CT Met? <sup>3</sup> Yes / No	Peak Hourly Demand Flow [GPM]
5/1/15:00	1.13	55	62.2	15.9	7.08	13.4	YES	450
5/2/15:00	1.01	55	55.6	15.8	7.07	13.3	YES	450
5/3/15:00	1.01	55	55.6	17.1	7.01	11.9	YES	450
5/4/15:00	1.03	55	56.7	17.5	7.15	12.2	YES	450
5/5/13:30	1.06	55	58.3	17.6	7.14	12.1	YES	450
5/8/15:00	1.13	55	62.2	17.7	7.32	13.0	YES	450
5/7/15:30	1.15	55	63.3	17.6	7.38	13.4	YES	450
5/8/15:00	1.13	55	62.2	17.7	7.29	12.8	YES	450
5/9/15:30	1.06	55	58.3	17.6	7.23	12.5	YES	450
5/10/15:30	1.02	55	56.1	18.2	7.01	11.1	YES	450
5/11/14:30	1.06	55	58.3	18.4	7.06	11.2	YES	450
5/12/15:00	1.14	55	62.7	18.4	7.15	11.6	YES	450
5/13/15:30	1.23	55	67.7	18.5	7.02	11.1	YES	450
5/14/15:30	1.12	55	61.6	18.2	7.10	11.6	YES	450
5/15/16:30	1.15	55	63.3	18.0	7.12	11.8	YES	450
5/16/15:00	1.06	55	58.3	17.9	7.09	11.7	YES	450
5/17/15:30	1.15	55	63.3	18.1	7.16	11.9	YES	450
5/18/15:00	1.04	55	57.2	18.4	7.11	11.3	YES	450
5/19/13:30	1.02	55	56.1	17.9	7.17	12.0	YES	450
5/20/14:00	1.08	55	59.4	17.9	7.07	11.6	YES	450
5/21/16:00	1.08	55	59.4	17.9	7.04	11.5	YES	450
5/22/13:30	1.1	55	60.5	17.7	7.08	11.8	YES	450
5/23/14:30	1.03	55	56.7	17.9	7.06	11.5	YES	450
5/24/15:00	1.04	55	57.2	17.7	7.04	11.6	YES	450
5/25/15:00	1.1	55	60.5	17.8	7.12	11.9	YES	450
5/26/14:30	1.03	55	56.7	18.2	7.12	11.5	YES	450
5/27/14:30	1.03	55	56.7	18.9	7.13	11.0	YES	450
5/28/14:00	1.04	55	57.2	18.8	7.13	11.1	YES	450
5/29/14:00	1.15	55	63.3	18.9	7.00	10.7	YES	450
5/30/14:30	1.09	55	60.0	18.9	7.05	10.8	YES	450
5/31/14:30	1.08	55	59.4	19.1	7.08	10.8	YES	450

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2014