

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: Coos

Conventional or Direct Filtration

Month/Year: Feb-22

System Name:	Lakeside Water District		ID#4100		WTP : TP - A		
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	OFF	OFF	OFF	OFF	OFF	0.03	0.03
2	OFF	OFF	OFF	OFF	0.03	OFF	0.03
3	OFF	OFF	OFF	OFF	0.03	OFF	0.03
4	OFF	OFF	OFF	OFF	0.03	OFF	0.03
5	OFF	OFF	OFF	0.03	OFF	OFF	0.03
6	OFF	OFF	OFF	0.03	OFF	OFF	0.03
7	OFF	OFF	OFF	0.03	OFF	OFF	0.03
8	OFF	OFF	OFF	OFF	0.03	OFF	0.03
9	OFF	OFF	OFF	OFF	0.03	OFF	0.03
10	OFF	OFF	OFF	OFF	0.03	OFF	0.03
11	OFF	OFF	OFF	OFF	0.03	OFF	0.03
12	OFF	OFF	OFF	OFF	0.04	OFF	0.04
13	OFF	OFF	OFF	0.03	OFF	OFF	0.03
14	OFF	OFF	OFF	OFF	0.03	OFF	0.03
15	OFF	OFF	OFF	OFF	0.03	OFF	0.03
16	OFF	OFF	OFF	OFF	0.03	OFF	0.03
17	OFF	OFF	OFF	OFF	0.03	OFF	0.03
18	OFF	OFF	OFF	0.03	OFF	OFF	0.03
19	OFF	OFF	OFF	0.03	OFF	OFF	0.03
20	OFF	OFF	OFF	0.03	OFF	OFF	0.03
21	OFF	OFF	OFF	OFF	0.03	OFF	0.03
22	OFF	OFF	OFF	OFF	0.03	OFF	0.03
23	OFF	OFF	OFF	OFF	0.05	OFF	0.05
24	OFF	OFF	OFF	OFF	0.03	OFF	0.03
25	OFF	OFF	OFF	OFF	0.03	0.03	0.03
26	OFF	OFF	OFF	OFF	0.03	OFF	0.03
27	OFF	OFF	OFF	OFF	0.03	OFF	0.03
28	OFF	OFF	OFF	OFF	0.03	OFF	0.03
29							
30							
31							

Conventional or Direct Filtration

Monthly Summary (Answer Yes or No)

95% of 4-hour turbidity readings \leq 0.3 NTU?

YES

All 4-hour turbidity readings \leq 1 NTU?

YES

All turbidity readings < IFE² triggers

YES

CT's met everyday?
(see back)

YES

All Cl₂ residual at entry point
 \geq 0.2 mg/l?

YES

Notes:

PRINTED NAME: Marty Ball

SIGNATURE:

DATE 3-1-2022

PHONE# 541-759-602

CERT#6276

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A

System Name:	Lakeside Water District	ID#: 41	00463	Month/Year:	Feb-22	Disinfection <i>Giardia</i> Log Inactiv:	0.5
--------------	-------------------------	---------	-------	-------------	--------	---------------------------------------------	-----

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[min/tes]	C X T	[° C]		formula	Yes / No	[GPM]
2/1/18:00	1.02	55	56.1	10.2	7.01	19.2	YES	450
2/2/15:30	1.11	55	61.1	10.4	7.15	20.0	YES	450
2/3/17:00	1.1	55	60.5	10.4	7.10	19.7	YES	450
2/4/15:00	1.06	55	58.3	10.3	6.97	18.9	YES	450
2/5/14:30	1.08	55	59.4	10.4	7.18	20.2	YES	450
2/6/14:30	1.04	55	57.2	10.9	7.20	19.6	YES	450
2/7/14:00	1	55	55.0	10.3	7.22	20.4	YES	450
2/8/15:30	1.11	55	61.1	10.4	7.16	20.1	YES	450
2/9/15:00	1.03	55	56.7	10.9	7.19	19.5	YES	450
2/10/15:30	1.05	55	57.8	11.0	7.10	18.8	YES	450
2/11/15:30	1.06	55	58.3	11.8	7.15	18.2	YES	450
2/12/15:00	1.05	55	57.8	11.7	7.17	18.4	YES	450
2/13/14:30	1.06	55	58.3	11.5	7.02	17.8	YES	450
2/14/16:00	1.09	55	60.0	11.1	7.14	19.0	YES	450
2/15/15:30	1.01	55	55.6	11.4	7.07	18.1	YES	450
2/16/15:00	1	55	55.0	11.8	7.12	17.9	YES	450
2/17/15:00	1.14	55	62.7	11.6	7.10	18.3	YES	450
2/18/14:45	1.08	55	59.4	11.7	7.08	17.9	YES	450
2/19/14:30	1.13	55	62.2	11.5	7.13	18.6	YES	450
2/20/14:45	1.12	55	61.6	11.6	7.07	18.1	YES	450
2/21/15:00	1.1	55	60.5	11.2	7.08	18.6	YES	450
2/22/15:30	1.15	55	63.3	11.2	7.10	18.8	YES	450
2/23/15:30	1.18	55	64.9	12.4	7.23	18.2	YES	450
2/24/15:30	1.1	55	60.5	10.6	7.16	19.8	YES	450
2/25/15:00	1.03	55	56.7	10.5	7.22	20.2	YES	450
2/26/15:30	1.11	55	61.1	9.9	7.17	20.9	YES	450
2/27/15:00	1.1	55	60.5	10.9	7.21	19.8	YES	450
2/28/15:30	1.18	55	64.9	10.6	7.22	20.4	YES	450
29		55					NO	450
30		55					NO	450
31		55					NO	450

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2014