

OHA - Drinking Water Services -Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: Coos
Month/Year: Oct-23

System Name: Lakealde Water District ID#4100 463 WTP : TP - A

Table with 8 columns: Day, 12 AM [NTU], 4 AM [NTU], 8 AM [NTU], NOON [NTU], 4 PM [NTU], 8 PM [NTU], Highest Reading of the Day 1 [NTU]. Rows 1-31 showing turbidity readings.

Summary table with 2 main sections: 'Conventional or Direct Filtration' and 'Monthly Summary (Answer Yes or No)'. Includes rows for 95% of 4-hour turbidity readings, CT's met everyday, and All Cl2 residual at entry point.

Notes: PRINTED NAME: Marty Ball
SIGNATURE: [Signature]
PHONE# 541-280-7794 DATE=11-1-2023
CERT#6276

1 Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. 2 IFE = Indivd. Filter Eff. (333-081-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - :

A

System Name:	Lakeside Water District	ID#: 41	00483	Month/Year:	Oct-23	Disinfection <i>Giardia</i> Log Inactiv:	0.5
--------------	-------------------------	---------	-------	-------------	--------	---	-----

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ^a	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ^a	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
10/1/14:30	1.08	55	59.4	20.0	7.32	11.1	YES	450
10/2/14:30	1.2	55	66.0	20.2	7.34	11.2	YES	450
10/3/14:00	1.1	55	60.5	20.0	7.28	10.9	YES	450
10/4/15:00	1.14	55	62.7	19.2	7.28	11.5	YES	450
10/5/15:00	1.18	55	64.9	20.1	7.31	11.1	YES	450
10/6/15:00	1.08	55	59.4	20.4	7.34	10.9	YES	480
10/7/14:30	1.15	55	63.3	20.4	7.22	10.5	YES	450
10/8/14:00	1.13	55	62.2	20.8	7.28	10.4	YES	450
10/9/15:00	1.07	55	58.9	18.9	7.30	11.8	YES	450
10/10/14:30	1.12	55	61.6	20.5	7.32	10.8	YES	450
10/11/14:30	1.1	55	60.5	19.9	7.33	11.2	YES	450
10/12/12:00	1.11	65	61.1	18.1	7.22	12.2	YES	450
10/13/13:00	1.18	55	64.9	18.0	7.24	12.4	YES	450
10/14/13:00	1.22	55	67.1	18.1	7.23	12.4	YES	450
10/15/13:00	1.09	55	60.0	18.0	7.25	12.4	YES	450
10/16/12:30	1.09	55	60.0	17.8	7.20	12.3	YES	450
10/17/13:30	1.17	65	64.4	18.0	7.23	12.4	YES	450
10/18/14:00	1.14	55	62.7	18.4	7.25	12.1	YES	450
10/19/12:00	1.17	55	64.4	20.8	7.01	9.4	YES	450
10/20/13:30	1.16	55	63.3	19.8	7.27	11.1	YES	450
10/21/12:30	1.14	55	62.7	19.7	7.19	10.8	YES	450
10/22/13:00	1.23	55	67.7	19.5	7.18	11.1	YES	450
10/23/12:30	1.12	55	61.6	18.9	7.33	12.0	YES	450
10/24/13:00	1.19	55	65.5	17.1	7.24	13.2	YES	450
10/25/14:00	1.23	55	67.7	17.9	7.17	12.3	YES	450
10/26/13:00	1.07	55	58.9	17.5	7.26	12.8	YES	450
10/27/12:00	1.05	55	57.8	16.4	7.28	13.8	YES	450
10/28/13:00	1.1	55	60.5	16.7	7.27	13.8	YES	450
10/29/13:00	1.08	55	59.4	17.2	7.07	12.2	YES	450
10/30/14:00	1.26	55	69.3	17.0	7.34	13.9	YES	450
10/31/14:00	1.15	55	63.3	17.8	7.22	12.5	YES	450

^a If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2014

PAGE 2 of 2