

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: **Curry**
 Month/Year: **Jan-21**

Conventional or Direct Filtration

System Name: **Langlois Water District** ID#: **4100466** WTP : **TP - A**

Day	24:00 [NTU]	04:00 [NTU]	08:00 [NTU]	12:00 [NTU]	16:00 [NTU]	20:00 [NTU]	Highest Reading of the Day ¹ [NTU]
1	off	off	0.03	0.03	0.03	off	0.03
2	off	off	0.03	0.05	off	off	0.05
3	off	off	0.03	0.05	off	off	0.05
4	off	off	0.04	0.04	off	off	0.04
5	off	off	0.02	0.02	off	off	0.02
6	off	off	0.02	0.02	off	off	0.02
7	off	off	0.04	0.04	off	off	0.04
8	off	off	0.03	0.03	0.03	off	0.03
9	off	off	0.05	0.03	off	off	0.05
10	off	off	0.03	0.04	off	off	0.04
11	off	off	0.04	0.05	off	off	0.05
12	off	off	0.04	0.04	off	off	0.04
13	off	off	off	0.01	0.02	off	0.02
14	off	off	0.04	0.04	off	off	0.04
15	off	off	0.03	0.05	off	off	0.05
16	off	off	0.03	0.03	off	off	0.03
17	off	off	0.03	0.04	off	off	0.04
18	off	off	0.03	0.03	off	off	0.03
19	off	off	0.04	0.03	off	off	0.04
20	off	off	0.03	0.03	off	off	0.03
21	off	off	0.03	0.03	off	off	0.03
22	off	off	0.04	0.04	off	off	0.04
23	off	off	0.04	0.03	off	off	0.04
24	off	off	0.03	0.04	off	off	0.04
25	off	off	0.04	0.05	off	off	0.05
26	off	off	0.01	0.01	off	off	0.01
27	off	off	0.02	0.02	off	off	0.02
28	off	off	0.04	0.04	off	off	0.04
29	off	off	0.02	0.04	off	off	0.04
30	off	off	0.04	0.04	0.04	off	0.04
31	off	off	0.04	0.05	off	off	0.05

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU? Yes	CT's met everyday? (see back) Yes	All Cl2 residual at entry point ≥ 0.2 mg/l? Yes
All 4-hour turbidity readings ≤ 1 NTU? Yes		
All turbidity readings < IFE ² triggers Yes		

Notes:	PRINTED NAME: Darrel Lockard	
	SIGNATURE submission	
	PHONE #: (503) 222-9997	CERT #: 2853

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A

System Name: Langlois Water District	ID#: 4100466	Month/Year:	Disinfection <i>Giardia</i> Log Inactiv:	1
--------------------------------------	--------------	-------------	--	---

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³ [ppm or mg/L]	Contact Time (T) [minutes]	Actual CT C X T	Temp [° C]	pH	Required CT formula	CT Met? ³ Yes / No	Peak Hourly Demand Flow [GPM]
1	0.48	207	99.4	10.5	6.75	32.4	YES	207
2	0.47	207	97.3	10.2	7.10	37.2	YES	207
3	0.47	207	97.3	10.2	7.06	36.7	YES	207
4	0.4	207	82.8	10.9	7.20	36.5	YES	207
5	0.4	207	82.8	10.6	7.25	37.9	YES	207
6	0.36	207	74.5	11.0	7.27	37.0	YES	207
7	0.37	207	76.6	10.5	7.33	39.0	YES	207
8	0.28	207	58.0	10.6	7.32	38.3	YES	207
9	0.35	207	72.5	10.2	7.80	46.8	YES	207
10	0.3	207	62.1	10.2	7.20	37.8	YES	207
11	0.35	207	72.5	11.1	7.16	35.3	YES	207
12	0.37	207	76.6	11.6	7.28	35.7	YES	207
13	0.35	207	72.5	11.5	7.12	34.0	YES	207
14	0.33	207	68.3	11.4	7.16	34.6	YES	207
15	0.31	207	64.2	11.7	6.93	31.3	YES	207
16	0.34	207	70.4	11.9	6.92	30.9	YES	207
17	0.34	207	70.4	11.9	6.93	31.0	YES	207
18	0.37	207	76.6	11.2	6.97	33.0	YES	207
19	0.41	207	84.9	10.8	7.11	35.7	YES	207
20	0.49	207	101.4	10.9	7.03	34.8	YES	207
21	0.58	207	120.1	11.7	6.93	32.3	YES	207
22	0.59	207	122.1	10.1	6.94	35.9	YES	207
23	0.59	207	122.1	10.1	6.94	35.9	YES	207
24	0.55	207	113.9	10.2	6.95	35.6	YES	207
25	0.51	207	105.6	9.2	7.06	39.3	YES	207
26	0.45	207	93.2	8.8	6.73	35.8	YES	207
27	0.43	207	89.0	8.4	6.89	38.7	YES	207
28	0.43	207	89.0	8.3	6.86	38.5	YES	207
29	0.33	207	68.3	8.0	6.93	39.8	YES	207
30	0.3	207	62.1	8.0	6.88	39.0	YES	207
31	0.31	207	64.2	8.2	6.85	38.1	YES	207

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2016-8 PAX