

OHA - Drinking Water Services -Turbidity Monitoring Report Form

Conventional or Direct Filtration

County:

Curry

Month/Year:

Dec-21

System Name:		Langlois Water District			ID#: 4100466		WTP : TP - A	
Day		24:00 [NTU]	04:00 [NTU]	08:00 [NTU]	12:00 [NTU]	16:00 [NTU]	20:00 [NTU]	Highest Reading of the Day ¹ [NTU]
1	off	off	0.03	0.03	off	off	off	0.03
2	off	off	0.03	0.03	off	off	off	0.03
3	off	off	0.03	0.04	off	off	off	0.04
4	off	off	0.03	0.03	off	off	off	0.03
5	off	off	0.03	0.03	off	off	off	0.03
6	off	off	0.03	0.03	off	off	off	0.03
7	off	off	0.03	0.03	off	off	off	0.03
8	off	off	0.03	0.04	off	off	off	0.04
9	off	off	0.03	0.03	off	off	off	0.03
10	off	off	0.03	0.05	off	off	off	0.05
11	off	off	0.03	0.03	off	off	off	0.03
12	off	off	0.04	0.06	off	off	off	0.06
13	off	off	0.04	0.04	off	off	off	0.04
14	off	off	0.04	0.05	off	off	off	0.05
15	off	off	0.03	0.04	off	off	off	0.04
16	off	off	0.04	0.04	off	off	off	0.04
17	off	off	0.05	0.04	off	off	off	0.05
18	off	off	0.04	0.038	off	off	off	0.04
19	off	off	0.04	0.05	0.03	off	off	0.05
20	off	off	0.04	0.04	off	off	off	0.04
21	off	off	0.03	0.03	off	off	off	0.03
22	off	off	0.03	0.03	off	off	off	0.03
23	off	0.03	0.03	off	off	off	off	0.01
24	off	off	0.04	0.04	0.04	off	off	0.04
25	off	off	0.03	0.04	0.04	off	off	0.04
26	off	off	0.04	0.06	off	off	off	0.06
27	off	off	0.03	0.04	off	off	off	0.04
28	off	off	0.05	0.05	off	off	off	0.05
29	off	off	0.05	0.05	0.05	off	off	0.05
30	off	off	0.01	0.01	off	off	off	0.01
31	off	off	0.01	0.03	off	off	off	0.03
							Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU?				yes	CT's met everyday? (see back)			All Cl ₂ residual at entry point ≥ 0.2 mg/l?
All 4-hour turbidity readings ≤ 1 NTU?				Yes	Yes			Yes
All turbidity readings < IFE ² triggers				Yes				
Notes:							Printed Darrel Lockard	
							SIGNATURE: <i>Darrel Lockard</i>	01/10/22
							Phone# 541-222-9997	CERT# 2853

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A

System Name:	Langlois Water District	ID#:	4100466	Month/Year:	12/21	Disinfection Giardia Log Inactiv:	1
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No
1	0.44	207	91.1	12.0	8.50	53.8	YES
2	0.44	207	91.1	12.0	8.36	51.2	YES
3	0.41	207	84.9	11.7	8.33	51.5	YES
4	0.44	207	91.1	11.7	8.35	52.1	YES
5	0.42	207	86.9	11.6	8.33	51.9	YES
6	0.43	207	89.0	11.4	8.30	52.1	YES
7	0.44	207	91.1	11.0	8.35	54.6	YES
8	0.41	207	84.9	11.1	8.34	53.8	YES
9	0.39	207	80.7	10.4	8.35	56.5	YES
10	0.37	207	76.6	10.2	8.36	57.4	YES
11	0.36	207	74.5	10.2	8.34	56.9	YES
12	0.33	207	68.3	10.1	8.35	57.3	YES
13	0.29	207	60.0	10.1	8.39	57.8	YES
14	0.3	207	62.1	9.0	8.39	62.4	YES
15	0.27	207	55.9	8.8	8.38	62.8	YES
16	0.31	207	64.2	8.9	8.44	64.0	YES
17	0.3	207	62.1	9.1	8.42	62.6	YES
18	0.31	207	64.2	9.3	8.45	62.5	YES
19	0.32	207	66.2	9.8	8.44	60.3	YES
20	0.35	207	72.5	10.1	8.43	59.1	YES
21	0.32	207	66.2	10.5	8.44	57.5	YES
22	0.32	207	66.2	10.5	8.42	57.1	YES
23	0.34	207	70.4	10.5	8.46	58.1	YES
24	0.36	207	74.5	10.0	8.48	60.6	YES
25	0.38	207	78.7	10.0	8.47	60.6	YES
26	0.36	207	74.5	9.8	8.48	61.5	YES
27	0.35	207	72.5	8.5	8.43	65.9	YES
28	0.36	207	74.5	8.5	8.43	66.0	YES
29	0.37	207	76.6	8.8	8.43	64.7	YES
30	0.38	207	78.7	8.3	8.45	67.5	YES
31	0.45	207	93.2	8.1	8.47	69.5	YES

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.