

**OHA - Drinking Water Services -Turbidity Monitoring Report Form**  
**Conventional or Direct Filtration**

County: **Curry**  
 Month/Year: **Jan. 2024**

System Name: <b>Langlois Water District</b>		ID#: <b>410046</b>		WTP : <b>TP - A</b>			
Day	24:00 [NTU]	04:00 [NTU]	08:00 [NTU]	12:00 [NTU]	16:00 [NTU]	20:00 [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]
1			0.10	0.10	0.07	0.06	0.10
2			0.10	0.09	0.10	0.06	0.10
3			0.10	0.08	0.10	0.10	0.10
4			0.09	0.08	0.90	0.10	0.10
5			0.10	0.08	0.07	OFF	0.10
6			0.10	0.10	0.10	OFF	0.10
7			0.10	0.09	OFF	OFF	0.10
8			0.10	0.09	0.10	OFF	0.10
9			0.10	0.05	0.05	0.05	0.10
10			0.20	0.08	0.05	OFF	0.10
11			OFF	OFF	0.05	0.06	0.06
12			0.09	0.09	OFF	OFF	0.10
13			0.10	0.06	OFF	OFF	0.10
14			0.10	0.04	0.09	OFF	0.20
15			0.10	0.07	0.20	OFF	0.20
16			OFF	0.20	0.07	OFF	0.20
17			0.09	0.10	0.07	OFF	0.10
18			0.10	0.10	0.20	OFF	0.20
19			0.10	0.08	0.09	OFF	0.10
20			OFF	0.10	0.05	OFF	0.10
21			0.10	0.90	0.08	0.10	0.10
22			OFF	0.20	0.04	0.09	0.20
23			OFF	OFF	0.05	0.10	0.10
24			0.10	0.10	0.10	0.10	0.10
25			0.10	0.04	OFF	OFF	0.10
26			0.05	0.04	OFF	OFF	0.05
27			0.10	0.04	0.04	0.10	0.10
28			OFF	0.01	0.01	OFF	0.10
29			0.10	0.10	OFF	OFF	0.10
30							
31							

<b>Conventional or Direct Filtration</b>		<b>Monthly Summary (Answer Yes or No)</b>	
95% of 4-hour turbidity readings ≤ 0.3 NTU?	<b>Yes</b>	CT's met everyday?	<b>Yes</b>
All 4-hour turbidity readings ≤ 1 NTU?	<b>Yes</b>	All Cl2 residual at entry	<b>Yes</b>
All turbidity readings < IFE <sup>2</sup> triggers	<b>Yes</b>		
Langlois Water District was on a boil notice from 1-22-24 5:00 pm through 1-30-24 4:00 pm. Clean legal water was made 1-23-24 at 5:00 pm, we had to fill the tank before we could flush system.		Printed Name: <b>Darrell Lockard</b>	
Kent Downs let us send the water out at 0.5 -1.0 NTU for 8 hrs on		SIGNATURE: <i>Darrell Lockard</i>	3/10/2024
		PHONE #: <b>(541) 222-9997</b>	CERT #: <b>2853</b>

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A

System Name: Langlois Water District ID#: 4100466	Month/Year: Feb. 2024	Disinfection Giardia Log Inactiv:	1
---	-----------------------	---	---

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User ( C ) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.83	207	171.8	12.9	6.48	25.3	YES	207
2	0.63	207	130.4	12.0	6.63	28.8	YES	207
3	0.4	207	82.8	11.2	6.56	28.8	YES	207
4	0.83	207	171.8	10.9	6.59	31.1	YES	207
5	0.8	207	165.6	10.4	6.55	31.6	YES	207
6	0.96	207	198.7	11.4	6.69	31.6	YES	207
7	0.59	207	122.1	11.3	6.47	28.4	YES	207
8	0.64	207	132.5	10.6	6.61	31.2	YES	207
9	1.05	207	217.4	10.4	6.83	35.7	YES	207
10	0.51	207	105.6	10.4	6.55	30.6	YES	207
11	0.97	207	200.8	10.4	6.63	33.0	YES	207
12	0.74	207	153.2	10.9	6.62	31.1	YES	207
13	0.73	207	151.1	11.7	6.57	29.1	YES	207
14	0.58	207	120.1	11.5	6.66	29.8	YES	207
15	0.73	207	151.1	13.5	6.43	23.6	YES	207
16	0.7	207	144.9	10.8	6.57	30.6	YES	207
17	0.45	207	93.2	11.5	6.39	26.9	YES	207
18	0.66	207	136.6	11.2	6.78	31.9	YES	207
19	0.7	207	144.9	11.4	6.67	30.5	YES	207
20	1	207	207.0	12.8	6.45	25.7	YES	207
21	1.2	207	248.4	12.0	6.60	30.3	YES	207
22	0.85	207	176.0	10.8	6.65	32.0	YES	207
23	0.62	207	128.3	10.8	6.61	30.8	YES	207
24	1	207	207.0	11.4	6.56	30.4	YES	207
25	1	207	207.0	11.8	6.46	28.7	YES	207
26	0.75	207	155.3	10.4	6.55	31.4	YES	207
27	1.1	207	227.7	11.0	6.43	30.1	YES	207
28	0.68	207	140.8	10.5	6.43	29.7	YES	207
29	0.7	207	144.9	10.3	6.45	30.4	YES	207
30		207		OFF	OFF		NO	207
31		207		OFF	OFF			207

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2016-8 PAX