

OHA - Drinking Water Services -Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: **Curry**
 Month/Year: **Mar-24**

System Nar	Langlois Water District			ID#: 4100466			WTP : TP - A
Day	24:00 [NTU]	04:00 [NTU]	08:00 [NTU]	12:00 [NTU]	16:00 [NTU]	20:00 [NTU]	Highest Reading of the Day ¹ [NTU]
1			OFF	0.20	0.05	OFF	0.20
2			OFF	0.07	0.07	OFF	0.07
3			OFF	0.08	0.05	0.10	0.10
4			0.09	0.10	0.10	0.10	0.10
5			0.09	0.09	0.09	OFF	0.09
6			0.09	0.09	0.09	OFF	0.09
7			0.20	0.10	0.04	OFF	0.20
8			0.07	0.09	0.10	OFF	0.10
9			0.09	0.07	0.10	OFF	0.10
10			OFF	0.07	0.08	OFF	0.08
11			OFF	0.20	0.07	OFF	0.20
12			0.06	0.10	0.10	OFF	0.10
13			0.10	0.06	0.07	0.10	0.10
14			0.10	0.10	OFF	OFF	0.10
15			0.07	0.03	0.04	OFF	0.07
16			0.04	0.03	OFF	OFF	0.04
17			0.08	0.10	0.04	OFF	0.10
18			0.03	0.03	OFF	OFF	0.03
19			0.03	0.04	0.06	OFF	0.06
20			0.05	0.07	0.05	OFF	0.07
21			0.10	0.04	0.04	OFF	0.10
22			0.06	0.04	0.05	OFF	0.06
23			0.06	0.05	OFF	OFF	0.06
24			OFF	0.20	0.10	OFF	0.20
25			0.10	0.10	0.07	OFF	0.10
26			0.10	0.10	0.10	OFF	0.10
27			0.10	0.07	OFF	OFF	0.10
28			0.10	0.10	OFF	OFF	0.10
29			0.20	0.02	0.07	0.07	0.10
30			0.10	0.10	0.10	OFF	0.10
31			0.08	0.08	0.07	OFF	0.08

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU? All 4-hour turbidity readings ≤ 1 NTU? All turbidity readings < IFE ² triggers	Yes Yes Yes	CT's met everyday? Yes	All Cl2 residual at entry Yes
Langlois Water District was on a boil notice from 1-22-24 5:00 pm through 1-30-24 4:00 pm. Clean legal water was made 1-23-24 at 5:00 pm, we had to fill the tank before we could flush system. Kent Downs let us send the water out at 0.5 -1.0 NTU		Printed Name: Darrel Lockard	
		SIGNATURE: <i>Darrel Lockard</i>	4/3/2024
		PHONE #: (541) 222-9997	CERT #: 2853

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through correspond to continuous readings' maximum. ² IFE = Individ. Filter Eff. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A

System Nar Langlois Water District ID#: 4100466	Month/Year: Mar-24	Disinfection Giardia Log Inactiv:	1
---	--------------------	---	---

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.94	207	194.6	10.3	6.57	32.5	YES	207
2	0.94	207	194.6	9.0	6.73	37.3	YES	207
3	0.93	207	192.5	9.2	6.64	35.6	YES	207
4	1.1	207	227.7	9.0	6.53	35.4	YES	207
5	1	207	207.0	10.4	6.73	34.3	YES	207
6	1.2	207	248.4	9.7	6.51	34.0	YES	207
7	0.86	207	178.0	11.5	6.42	28.4	YES	207
8	0.59	207	122.1	11.2	6.64	30.2	YES	207
9	0.68	207	140.8	10.9	6.58	30.5	YES	207
10	0.94	207	194.6	9.1	6.48	34.0	YES	207
11	0.9	207	186.3	9.4	6.46	33.0	YES	207
12	1.1	207	227.7	10.0	6.34	31.1	YES	207
13	1.1	207	227.7	9.9	6.32	31.1	YES	207
14	0.69	207	142.8	10.6	6.47	30.0	YES	207
15	1.2	207	248.4	14.5	6.43	23.3	YES	207
16	0.85	207	176.0	10.8	6.43	29.7	YES	207
17	0.85	207	176.0	10.8	6.57	31.1	YES	207
18	1	207	207.0	12.3	6.45	27.7	YES	207
19	1.1	207	227.7	11.7	6.49	29.4	YES	207
20	0.91	207	188.4	11.6	6.37	27.9	YES	207
21	0.75	207	155.3	12.6	6.56	26.4	YES	207
22	0.78	207	161.5	12.3	6.46	27.1	YES	207
23	0.86	207	178.0	12.8	6.92	30.1	YES	207
24	1	207	207.0	10.8	6.59	31.9	YES	207
25	1.2	207	248.4	11.4	6.50	30.4	YES	207
26	1.5	207	310.5	11.2	6.57	32.6	YES	207
27	0.94	207	194.6	11.8	6.55	29.3	YES	207
28	0.55	207	113.9	11.0	6.61	30.2	YES	207
29	0.51	207	105.6	11.0	6.61	30.0	YES	207
30	0.7	207	144.9	10.7	6.57	30.8	YES	207
31	0.92	207	190.4	11.9	6.63	29.9	YES	207

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.