

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: Curry

Conventional or Direct Filtration

Month/Year: May-25

System Name: Langlois Water District		ID#: 4100466		WTP : TP - A			
Day	24:00 [NTU]	04:00 [NTU]	08:00 [NTU]	12:00 [NTU]	16:00 [NTU]	20:00 [NTU]	Highest Reading of the Day ¹ [NTU]
1	Off	Off	Off	0.07	Off	Off	0.07
2	Off	Off	Off	0.15	Off	Off	0.15
3	Off	Off	Off	0.09	Off	Off	0.09
4	Off	Off	Off	0.06	Off	Off	0.06
5	Off	Off	Off	0.25	Off	Off	0.25
6	Off	Off	Off	0.20	Off	Off	0.20
7	Off	Off	Off	Off	Off	Off	Off
8	Off	Off	Off	Off	Off	Off	Off
9	Off	Off	Off	Off	Off	Off	Off
10	Off	Off	Off	0.20	0.09	0.10	0.20
11	Off	Off	Off	0.07	0.10	Off	0.10
12	Off	Off	Off	0.25	Off	Off	0.25
13	Off	Off	Off	Off	0.10	Off	0.10
14	Off	Off	Off	0.20	Off	Off	0.20
15	Off	Off	Off	Off	Off	Off	Off
16	Off	Off	Off	0.25	0.20	Off	0.25
17	Off	Off	Off	Off	0.16	0.20	0.20
18	Off	Off	Off	0.15	Off	Off	0.15
19	Off	Off	Off	0.15	Off	Off	0.15
20	Off	Off	Off	0.09	Off	Off	0.09
21	Off	Off	Off	0.12	Off	Off	0.12
22	Off	0.25	0.20	0.07	0.08	0.20	0.25
23	0.25	Off	Off	0.07	0.05	0.06	0.25
24	Off	Off	Off	0.20	0.05	Off	0.20
25	Off	Off	Off	0.09	Off	Off	0.09
26	Off	Off	Off	0.70	Off	Off	0.70
27	Off	Off	Off	0.25	Off	Off	0.25
28	Off	Off	Off	0.08	0.09	Off	0.09
29	Off	Off	Off	0.12	0.25	0.28	0.28
30	Off	Off	Off	0.22	Off	Off	0.22
31	Off	Off	Off	0.20	0.07	Off	0.20

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings $\leq$ 0.3 NTU?	Yes	CT's met everyday? (see back)	All Cl2 residual at entry point $\geq$ 0.2 mg/l?
All 4-hour turbidity readings $\leq$ 1 NTU?	Yes	Yes	Yes
All turbidity readings < IFE ² triggers	Yes		

Notes: 43/44/97%	PRINTED NAME: Ryan Sherman	
	SIGNATURE: Electronic submission <i>Ryan A. Sherman</i>	DATE: 6/3/25
	PHONE #: 541 240-2436	CERT #: 9187

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A

System Name:	Langlois Water District	ID#: 4100466	Month/Year:	Feb-18	Disinfection <i>Giardia</i> Log Inactiv:	1
--------------	-------------------------	--------------	-------------	--------	---	---

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.57	207	118.0	13.3	5.77	18.3	YES	207
2	0.53	207	109.7	13.0	6.59	25.3	YES	207
3	0.89	207	184.2	12.1	5.84	22.8	YES	207
4	0.69	207	142.8	13.8	6.36	22.4	YES	207
5	0.67	207	138.7	13.1	6.00	20.5	YES	207
6	0.86	207	178.0	13.1	6.15	22.2	YES	207
7		207					NO	207
8		207					NO	207
9		207					NO	207
10	0.69	207	142.8	13.7	6.72	25.8	YES	207
11	0.73	207	151.1	15.4	6.64	22.5	YES	207
12	0.79	207	163.5	13.8	6.78	26.6	YES	207
13	0.69	207	142.8	14.2	6.90	26.7	YES	207
14	0.72	207	149.0	14.2	6.06	19.6	YES	207
15		207					NO	207
16	0.89	207	184.2	14.5	7.30	31.1	YES	207
17	0.62	207	128.3	13.8	7.39	32.7	YES	207
18	0.61	207	126.3	14.0	6.61	24.1	YES	207
19	0.81	207	167.7	14.3	6.96	27.5	YES	207
20	0.68	207	140.8	14.1	6.23	20.9	YES	207
21	0.75	207	155.3	14.0	6.54	23.8	YES	207
22	0.61	207	126.3	14.5	6.64	23.6	YES	207
23	0.93	207	192.5	14.4	6.29	21.6	YES	207
24	0.83	207	171.8	14.5	6.23	19.9	YES	207
25	0.9	207	186.3	15.1	6.59	23.1	YES	207
26	0.87	207	180.1	15.0	6.02	18.2	YES	207
27	0.5	207	103.5	15.3	6.24	18.3	YES	207
28	0.75	207	155.3	15.8	6.20	16.2	YES	207
29	0.6	207	124.2	17.8	6.26	18.3	YES	207
30	0.66	207	136.6	16.1	7.32	26.5	YES	207
31	0.83	207	171.8	16.6	6.60	#REF!	#REF!	207

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2016-8 PAX