

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: Curry

Conventional or Direct Filtration

Month/Year: Jul-25

System Name:	Langlois Water District			ID#: 41 00466			WTP : TP - A
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	Off	Off	Off	0.18	Off	Off	0.18
2	Off	Off	Off	0.04	Off	Off	0.04
3	Off	Off	Off	Off	Off	Off	Off
4	Off	Off	Off	0.17	0.19	Off	0.19
5	Off	Off	Off	0.19	0.05	Off	0.09
6	Off	Off	Off	0.04	0.04	Off	0.04
7	Off	Off	Off	0.15	Off	Off	0.15
8	Off	Off	Off	0.04	Off	Off	0.04
9	Off	Off	Off	0.06	Off	Off	0.06
10	Off	Off	Off	0.16	Off	Off	0.16
11	Off	Off	Off	0.17	Off	Off	0.17
12	Off	Off	Off	0.04	Off	Off	0.04
13	Off	Off	Off	0.05	Off	Off	0.05
14	Off	Off	Off	0.15	Off	Off	0.15
15	Off	Off	Off	0.17	Off	Off	0.17
16	Off	Off	Off	0.04	Off	Off	0.04
17	Off	Off	0.05	Off	Off	Off	0.05
18	Off	Off	Off	0.04	Off	Off	0.04
19	Off	Off	Off	0.06	Off	Off	0.06
20	Off	Off	Off	0.14	Off	Off	0.14
21	Off	Off	Off	0.04	Off	Off	0.04
22	Off	Off	Off	0.05	Off	Off	0.05
23	Off	Off	Off	0.17	Off	Off	0.17
24	Off	Off	Off	0.04	Off	Off	0.04
25	Off	Off	Off	0.04	Off	Off	0.04
26	Off	Off	Off	0.05	Off	Off	0.05
27	Off	Off	Off	0.12	Off	Off	0.12
28	Off	Off	Off	0.04	Off	Off	0.04
29	Off	Off	Off	0.10	Off	Off	0.10
30	Off	Off	Off	Off	Off	Off	Off
31	Off	Off	Off	Off	Off	Off	Off

Conventional or Direct Filtration

Monthly Summary (Answer Yes or No)

95% of 4-hour turbidity readings $\leq$ 0.3 NTU?

Yes / No

All 4-hour turbidity readings $\leq$ 1 NTU?

Yes / No

All turbidity readings < IFE² triggers

Yes / No

CT's met everyday?
(see back)

Yes / No

All Cl2 residual at entry point
 $\geq$ 0.2 mg/l?

Yes / No

Notes:

PRINTED NAME: Ryan Sherman

SIGNATURE: Ryan A. Sherman

DATE: 8/7/25

PHONE #: (541) 260-2436

CERT #: 9184

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Indiv. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

				WTP - : A	
System Name:	Langlois Water District	ID#: 41 00466	Month/Year:	Jul-25	Disinfection <i>Giardia</i> Log Inactive: 1

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.67	207	138.7	18.8	6.60	17.5	YES	
2	0.73	207	151.1	17.9	6.63	18.9	YES	
3	0.72	207	149.0	17.8	6.21	16.2	YES	
4	0.71	207	147.0	17.7	6.60	18.9	YES	
5	0.86	207	178.0	17.8	7.02	22.4	YES	
6	0.8	207	165.6	18.1	6.87	20.6	YES	
7	0.75	207	155.3	16.7	6.21	17.6	YES	
8	0.73	207	151.1	17.1	6.21	17.0	YES	
9	0.63	207	130.4	18.3	6.31	16.1	YES	
10	0.71	207	147.0	18.1	6.43	17.3	YES	
11	1.1	207	227.7	18.2	6.62	19.3	YES	
12	0.62	207	128.3	18.8	6.50	16.7	YES	
13	0.53	207	109.7	18.8	6.67	17.6	YES	
14	0.66	207	136.6	18.3	6.24	15.8	YES	
15	0.77	207	159.4	18.2	6.67	18.9	YES	
16	0.65	207	134.6	18.2	6.34	16.5	YES	
17	0.7	207	144.9	18.3	6.47	17.3	YES	
18	0.63	207	130.4	18.6	6.39	16.3	YES	
19	0.63	207	130.4	18.8	6.38	16.0	YES	
20	0.7	207	144.9	18.4	6.63	18.2	YES	
21	0.69	207	142.8	19.1	6.37	15.7	YES	
22	0.58	207	120.1	18.6	6.41	16.3	YES	
23	0.56	207	115.9	19.0	6.35	15.5	YES	
24	0.46	207	95.2	18.7	6.37	15.7	YES	
25	0.57	207	118.0	19.1	6.39	15.6	YES	
26	0.61	207	126.3	19.4	6.38	15.3	YES	
27	0.65	207	134.6	19.2	6.79	18.2	YES	
28	0.57	207	118.0	18.6	6.38	16.1	YES	
29	0.56	207	115.9	19.3	6.48	15.9	YES	
30		207						
31		207						

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2022

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@oha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350