

OHA - Drinking Water Services -Turbidity Monitoring Report Form

Conventional or Direct Filtration

County:

Curry

Month/Year:

Aug-25

System Name:		Langlois Water District			ID#: 4100466		WTP : TP - A	
Day	24:00 [NTU]	04:00 [NTU]	08:00 [NTU]	12:00 [NTU]	16:00 [NTU]	20:00 [NTU]	Highest Reading of the Day ¹ [NTU]	
1	Off	Off	Off	0.05	Off	Off	0.05	
2	Off	Off	Off	0.11	Off	Off	0.11	
3	Off	Off	Off	0.04	0.04	Off	0.04	
4	Off	Off	Off	0.05	Off	Off	0.05	
5	Off	Off	Off	0.07	Off	Off	0.07	
6	Off	Off	0.07	Off	Off	Off	0.07	
7	Off	Off	Off	0.05	0.05	Off	0.05	
8	Off	Off	Off	0.07	Off	Off	0.07	
9	Off	Off	Off	0.08	Off	Off	0.08	
10	Off	Off	Off	0.05	0.06	Off	0.06	
11	Off	Off	Off	0.09	0.12	Off	0.12	
12	Off	Off	Off	0.05	Off	Off	0.05	
13	Off	Off	Off	0.04	0.05	Off	0.05	
14	Off	Off	Off	0.05	Off	Off	0.05	
15	Off	Off	0.05	Off	0.05	Off	0.05	
16	Off	Off	Off	0.07	Off	Off	0.07	
17	Off	Off	Off	0.04	0.05	Off	0.05	
18	Off	Off	Off	0.05	Off	Off	0.05	
19	Off	Off	Off	0.21	Off	Off	0.21	
20	Off	Off	Off	0.04	Off	Off	0.04	
21	Off	Off	Off	0.05	Off	Off	0.05	
22	Off	Off	Off	0.05	Off	Off	0.05	
23	Off	Off	Off	0.06	Off	Off	0.06	
24	Off	Off	Off	0.11	Off	Off	0.11	
25	Off	Off	Off	0.22	Off	Off	0.22	
26	Off	Off	Off	0.23	Off	Off	0.23	
27	Off	Off	Off	0.05	Off	Off	0.05	
28	Off	Off	Off	0.05	Off	Off	0.05	
29	Off	Off	Off	0.10	Off	Off	0.10	
30	Off	Off	Off	0.05	Off	Off	0.05	
31	Off	Off	Off	0.05	Off	Off	0.05	

95% of 4-hour turbidity readings $\leq$ 0.3 NTU? Yes All 4-hour turbidity readings $\leq$ 1 NTU? Yes All turbidity readings < IFE² triggers Yes		Monthly Summary (Answer Yes or No) CT's met everyday? (see back) Yes All Cl2 residual at entry point $\geq$ 0.2 mg/l? Yes	
Notes:		Printed Ryan Sherman SIGNATURE: <i>[Signature]</i> Phone# 541-260-2436 CERT# 9184	

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form
WTP - : A 4100466

System Name:	Langlois Water District	OFF	Month/Year:	09/10/25	Disinfection <i>Giardia</i>	Log Inactiv:	1
---------------------	--------------------------------	------------	--------------------	-----------------	------------------------------------	---------------------	----------

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.57	207	118.0	19.1	6.41	15.7	YES	207
2	0.65	207	134.6	20.1	6.74	16.8	YES	207
3	0.64	207	132.5	20.4	6.64	15.8	YES	207
4	0.58	207	120.1	20.5	6.65	15.7	YES	207
5	0.72	207	149.0	19.3	6.45	16.0	YES	207
6	0.61	207	126.3	20.4	6.49	14.9	YES	207
7	0.38	207	78.7	19.8	6.34	14.3	YES	207
8	0.7	207	144.9	20.0	6.63	16.3	YES	207
9	0.68	207	140.8	20.8	6.52	14.8	YES	207
10	0.71	207	147.0	19.5	6.82	18.2	YES	207
11	0.91	207	188.4	19.7	6.28	15.0	YES	207
12	0.64	207	132.5	19.8	6.64	16.5	YES	207
13	0.68	207	140.8	19.9	6.29	14.4	YES	207
14	0.72	207	149.0	19.9	6.32	14.7	YES	207
15	0.61	207	126.3	19.2	6.52	16.4	YES	207
16	0.52	207	107.6	19.9	6.81	17.2	YES	207
17	0.65	207	134.6	19.6	7.39	22.2	YES	207
18	0.6	207	124.2	19.3	7.05	19.8	YES	207
19	0.58	207	120.1	19.1	7.27	20.1	YES	207
20	0.54	207	111.8	19.6	7.27	21.0	YES	207
21	0.63	207	130.4	19.0	7.21	22.1	YES	207
22	0.51	207	105.6	19.1	7.28	21.1	YES	207
23	0.67	207	138.7	18.2	7.34	23.5	YES	207
24	0.66	207	136.6	19.3	7.40	22.3	YES	207
25	0.52	207	107.6	19.4	7.31	22.3	YES	207
26	0.55	207	113.9	19.2	7.31	21.9	YES	207
27	0.49	207	101.4	19.2	7.38	21.7	YES	207
28	0.6	207	124.2	19.0	7.35	22.9	YES	207
29	0.44	207	91.1	19.0	7.30	22.2	YES	207
30	0.66	207	136.6	18.9	7.37	22.5	YES	207
31	0.64	207	132.5	18.9	7.37	23.1	YES	207

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, not