


OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: Curry

Month/Year: Sep-25

Conventional or Direct Filtration

System Name: Langlois Water District		ID#: 4100466		WTP : TP - A			
Day	24:00 [NTU]	04:00 [NTU]	08:00 [NTU]	12:00 [NTU]	16:00 [NTU]	20:00 [NTU]	Highest Reading of the Day ¹ [NTU]
1	Off	Off	Off	0.10	Off	Off	0.10
2	Off	Off	Off	0.20	Off	Off	0.20
3	Off	Off	Off	0.04	Off	Off	0.04
4	Off	Off	Off	0.05	Off	Off	0.05
5	Off	Off	Off	0.04	Off	Off	0.04
6	Off	Off	Off	0.05	Off	Off	0.05
7	Off	Off	Off	0.08	Off	Off	0.08
8	Off	Off	Off	0.05	Off	Off	0.05
9	Off	Off	Off	0.05	Off	Off	0.05
10	Off	Off	Off	0.08	Off	Off	0.08
11	Off	Off	Off	0.14	Off	Off	0.14
12	Off	Off	Off	0.05	Off	Off	0.05
13	Off	Off	Off	0.05	Off	Off	0.05
14	Off	Off	Off	0.13	Off	Off	0.13
15	Off	Off	Off	0.04	Off	Off	0.04
16	Off	Off	Off	0.05	Off	Off	0.05
17	Off	Off	Off	0.09	Off	Off	0.09
18	Off	Off	Off	0.04	Off	Off	0.04
19	Off	Off	Off	0.04	Off	Off	0.04
20	Off	Off	Off	0.07	Off	Off	0.07
21	Off	Off	Off	0.045	Off	Off	0.05
22	Off	Off	Off	0.06	Off	Off	0.06
23	Off	Off	Off	0.11	Off	Off	0.11
24	Off	Off	Off	0.28	Off	Off	0.28
25	Off	Off	Off	0.05	Off	Off	0.05
26	Off	Off	Off	0.07	Off	Off	0.07
27	Off	Off	Off	0.09	Off	Off	0.09
28	Off	Off	Off	0.05	Off	Off	0.05
29	Off	Off	Off	0.05	Off	Off	0.05
30	Off	Off	Off	0.08	Off	Off	0.08
31							
				Monthly Summary (Answer Yes or No)			
95% of 4-hour turbidity readings $\leq$ 0.3 NTU? Yes				CT's met everyday? (see back)		All Cl ₂ residual at entry point $\geq$ 0.2 mg/l?	
All 4-hour turbidity readings $\leq$ 1 NTU? Yes				Yes		Yes	
All turbidity readings < IFE ² triggers Yes							
Notes:				Printed Ryan Sherman SIGNATURE:  Phone# (541) 240-2436 CERT# 9184			

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A

System Name: Langlois Water District

OFF

Month/Year: 09/25/2020

Disinfection *Giardia*
Log Inactiv:

1

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.68	207	140.8	18.6	7.30	23.1	YES	207
2	0.69	207	142.8	18.4	7.32	23.6	YES	207
3	0.56	207	115.9	18.8	7.38	24.2	YES	207
4	0.53	207	109.7	18.1	7.38	24.2	YES	207
5	0.65	207	134.6	18.1	7.30	23.6	YES	207
6	0.58	207	120.1	18.2	7.18	22.5	YES	207
7	0.52	207	107.6	18.1	7.40	24.3	YES	207
8	0.7	207	144.9	18.1	7.10	22.0	YES	207
9	0.59	207	122.1	18.2	7.38	23.8	YES	207
10	0.63	207	130.4	18.4	7.40	24.9	YES	207
11	0.66	207	136.6	17.9	7.40	24.9	YES	207
12	0.61	207	126.3	18.0	7.37	24.8	YES	207
13	0.77	207	159.4	17.8	7.47	25.8	YES	207
14	0.75	207	155.3	18.0	7.44	26.2	YES	207
15	0.79	207	163.5	17.6	7.02	21.8	YES	207
16	0.75	207	155.3	18.1	7.44	25.3	YES	207
17	0.8	207	165.6	18.1	7.47	26.1	YES	207
18	0.73	207	151.1	17.9	7.37	25.1	YES	207
19	0.81	207	167.7	17.8	7.41	26.4	YES	207
20	0.71	207	147.0	17.4	7.48	26.6	YES	207
21	0.99	207	204.9	17.5	7.53	28.8	YES	207
22	0.87	207	180.1	17.1	7.40	26.7	YES	207
23	0.94	207	194.6	17.3	7.43	27.0	YES	207
24	0.85	207	176.0	17.4	7.44	27.6	YES	207
25	0.93	207	192.5	17.0	7.47	28.7	YES	207
26	0.91	207	188.4	16.7	7.47	28.3	YES	207
27	0.72	207	149.0	16.9	7.54	28.4	YES	207
28	0.79	207	163.5	16.9	7.55	28.5	YES	207
29	0.73	207	151.1	17.0	7.48	28.2	YES	207
30	0.8	207	165.6	16.7	7.52	28.8	YES	207
31		207						207

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, no