

OHA - Drinking Water Services -Turbidity Monitoring Report Form

Conventional or Direct Filtration

County: Curry

Month/Year: Nov-25

System Name: Langlois Water District		ID#: 4100466		WTP: TP - A			
Day	24:00 [NTU]	04:00 [NTU]	08:00 [NTU]	12:00 [NTU]	16:00 [NTU]	20:00 [NTU]	Highest Reading of the Day ¹ [NTU]
1	Off	Off	Off	0.12	Off	Off	0.12
2	Off	Off	Off	0.18	Off	Off	0.18
3	Off	Off	Off	0.14	Off	Off	0.14
4	Off	Off	Off	0.18	0.16	Off	0.18
5	Off	Off	Off	0.22	Off	Off	0.22
6	Off	Off	Off	0.21	Off	Off	0.21
7	Off	Off	Off	Off	Off	Off	0.00
8	Off	Off	0.07	0.09	Off	Off	0.09
9	Off	Off	Off	0.12	0.18	Off	0.18
10	Off	Off	Off	0.23	Off	Off	0.23
11	Off	Off	Off	0.11	Off	Off	0.11
12	Off	Off	Off	0.12	Off	Off	0.12
13	Off	Off	0.09	0.12	Off	Off	0.12
14	Off	Off	Off	0.19	Off	Off	0.19
15	Off	Off	Off	0.18	Off	Off	0.18
16	Off	Off	0.16	0.20	Off	Off	0.20
17	Off	Off	Off	0.12	Off	Off	0.12
18	Off	Off	Off	0.24	Off	Off	0.24
19	Off	Off	Off	0.21	Off	Off	0.21
20	Off	Off	Off	Off	Off	Off	0.00
21	Off	Off	Off	Off	Off	Off	0.00
22	Off	Off	Off	0.22	Off	Off	0.22
23	Off	Off	0.12	0.12	Off	Off	0.12
24	Off	Off	Off	0.27	Off	Off	0.27
25	Off	Off	Off	0.28	Off	Off	0.28
26	Off	Off	0.06	0.07	Off	Off	0.07
27	Off	Off	Off	0.10	Off	Off	0.10
28	Off	Off	Off	0.21	0.23	Off	0.23
29	Off	Off	Off	0.14	Off	Off	0.14
30	Off	Off	Off	0.21	Off	Off	0.21
31							

Monthly Summary (Answer Yes or No)		
95% of 4-hour turbidity readings $\leq$ 0.3 NTU?	☒ Yes	CT's met everyday? (see back)
All 4-hour turbidity readings $\leq$ 1 NTU?	☒ Yes	All Cl ₂ residual at entry point $\geq$ 0.2 mg/l?
All turbidity readings < IFE ² triggers	☒ Yes	☒ Yes

Notes: <i>Keep Working on Consistent Formulas on the Sheets. We corrected them Monthly</i>	Printed Ryan Sherman
SIGNATURE: <i>Brian A. St...</i>	12/09/25
Phone# <i>(541) 260-2936</i>	CERT# 9184

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A

System Name: Langlois Water District

OFF

Month/Year: 11/01/25

Disinfection *Giardia*
Log Inactiv:

1

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.81	207	167.7	13.6	7.79	39.2	YES	207
2	0.83	207	171.8	13.6	7.82	39.7	YES	207
3	0.51	207	105.6	13.5	7.74	37.4	YES	207
4	0.39	207	80.7	13.8	7.80	37.0	YES	207
5	0.6	207	124.2	13.8	7.87	38.9	YES	207
6	0.72	207	149.0	13.1	7.83	40.7	YES	207
7		207						207
8	0.65	207	134.6	13.3	7.82	39.7	YES	207
9	0.7	207	144.9	13.2	7.91	41.5	YES	207
10	0.75	207	155.3	13.5	7.69	37.8	YES	207
11	0.65	207	134.6	13.4	7.79	39.0	YES	207
12	0.76	207	157.3	13.5	7.65	37.3	YES	207
13	0.73	207	151.1	13.5	7.63	36.9	YES	207
14	0.72	207	149.0	13.5	7.67	37.4	YES	207
15	0.88	207	182.2	13.5	7.68	38.2	YES	207
16	0.92	207	190.4	13.3	7.62	38.0	YES	207
17	0.87	207	180.1	13.3	7.54	36.7	YES	207
18	0.85	207	176.0	13.0	7.61	38.3	YES	207
19	0.92	207	190.4	12.5	7.67	40.8	YES	207
20		207						207
21		207						207
22	0.82	207	169.7	11.2	7.73	45.1	YES	207
23	0.78	207	161.5	11.5	7.79	45.0	YES	207
24	0.92	207	190.4	11.8	7.84	45.6	YES	207
25	0.82	207	169.7	11.5	7.85	46.1	YES	207
26	0.63	207	130.4	11.5	7.85	45.2	YES	207
27	1.1	207	227.7	11.5	8.01	50.4	YES	207
28	1.1	207	227.7	11.5	8.09	51.9	YES	207
29	0.74	207	153.2	11.2	8.12	51.3	YES	207
30	1	207	207.0	11.2	8.20	54.4	YES	207
31		207						207

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, no