

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: Curry

Conventional or Direct Filtration

Month/Year: February-2026

System Name: Langlois Water District ID#: 41-00466

WTP: TP-A

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1				0.212 ¹²¹⁵			0.212 ¹²¹⁵
2				0.06			0.06
3				0.10			0.10
4				0.18			0.18
5				0.05			0.05
6				0.08	0.16		0.16
7				0.13			0.13
8				0.20	0.20		0.20
9				0.068 ¹²¹⁵	0.14		0.068 ¹²¹⁵
10				0.08			0.08
11				0.28			0.28
12				0.21			0.21
13				0.07			0.07
14				0.13			0.13
15				0.09			0.09
16				0.17			0.17
17				0.14			0.14
18				0.20			0.20
19				0.19			0.19
20				0.21			0.21
21				0.21			0.21
22				0.11	0.18		0.18
23				0.28	0.14		0.28
24				0.18			0.18
25				0.09			0.09
26				0.09			0.09
27				0.23			0.23
28				0.11			0.11
29				NA			0.00
30				NA			0.00
31				NA			0.00

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU?	<input checked="" type="radio"/> Yes <input type="radio"/> No	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All 4-hour turbidity readings ≤ 1 NTU?	<input checked="" type="radio"/> Yes <input type="radio"/> No	<input checked="" type="radio"/> Yes <input type="radio"/> No	<input checked="" type="radio"/> Yes <input type="radio"/> No
All turbidity readings < IFE ² triggers	<input checked="" type="radio"/> Yes <input type="radio"/> No		

Notes: contacted water operator and verified data over the phone was advised data on 1st and 9th was incorrect. White Outry

PRINTED NAME: Ryan A. Sherman
 SIGNATURE: [Signature] DATE: 3/10/26
 PHONE #: (591) 260-2436 CERT #: 9184

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP -- **A**

System Name: **Langlois Water District** ID#: **41-00466**

Month/Year: **2/2020**

Disinfection *Giardia*
Log Inactive:

1

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.78	207	161.5	11.0	7.37	40.1	YES	
2	0.72	207	149.0	11.1	7.24	37.8	YES	
3	0.67	207	138.7	10.7	7.24	38.6	YES	
4	0.95	207	196.7	11.2	7.40	40.8	YES	
5	0.77	207	159.4	11.0	7.37	40.1	YES	
6	0.85	207	176.0	10.7	7.24	39.4	YES	
7	0.97	207	200.8	10.5	7.39	42.6	YES	
8	0.89	207	184.2	10.9	7.42	41.6	YES	
9	0.7	207	144.9	10.9	7.37	40.0	YES	
10	0.51	207	105.6	11.1	7.25	37.1	YES	
11	0.97	207	200.8	10.5	7.46	43.7	YES	
12	0.68	207	140.8	10.5	7.34	40.6	YES	
13	0.67	207	138.7	10.6	7.32	40.0	YES	
14	0.96	207	198.7	10.2	7.62	47.1	YES	
15	1.02	207	211.1	9.9	7.32	43.5	YES	
16	0.83	207	171.8	10.3	7.17	39.4	YES	
17	1.02	207	211.1	9.7	7.31	44.0	YES	
18	0.53	207	109.7	9.3	7.34	43.2	YES	
19	0.96	207	198.7	9.2	7.12	42.2	YES	
20	0.65	207	134.6	8.7	7.50	48.2	YES	
21	0.79	207	163.5	8.7	7.30	45.6	YES	
22	0.76	207	157.3	9.6	7.38	44.0	YES	
23	0.72	207	149.0	9.6	7.45	44.9	YES	
24	0.52	207	107.6	10.6	7.48	41.6	YES	
25	0.48	207	99.4	10.6	7.48	41.4	YES	
26	0.74	207	153.2	10.8	7.31	39.6	YES	
27	0.88	207	182.2	10.4	7.49	44.0	YES	
28	0.78	207	161.5	10.2	7.37	42.3	YES	
29	0	207	0.0	0.0	0.00	8.4		
30	0	207	0.0	0.0	0.00	8.4		
31	0	207	0.0	0.0	0.00	8.4		

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2022

Return by 10th of following month by email, fax, or mail to:

dwp_dmce@oha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350