

OHA - Drinking Water Program - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: **Linn**
 Month/Year: **2/2023**
Membrane

System Name: Lebanon, City of			ID#: 41-00473				Highest Reading of the day ¹ [NTU]	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]		
1	0.017	0.017	0.017	0.017	0.017	0.017	0.022	
2	0.017	0.015	0.017	OFF	OFF	OFF	0.019	
3	OFF	OFF	OFF	0.016	0.016	0.016	0.040	
4	0.016	0.018	0.018	0.018	0.018	OFF	0.018	
5	OFF	0.016	OFF	OFF	OFF	OFF	0.025	
6	OFF	OFF	0.015	0.016	0.016	OFF	0.032	
7	OFF	OFF	0.016	0.016	0.016	0.016	0.029	
8	0.016	0.018	0.018	0.014	0.018	OFF	0.018	
9	OFF	OFF	0.016	0.018	OFF	OFF	0.031	
10	OFF	OFF	OFF	OFF	0.018	0.018	0.038	
11	0.018	0.018	0.018	0.018	0.018	0.018	0.018	
12	OFF	OFF	OFF	OFF	OFF	OFF	0.000	
13	OFF	OFF	0.014	0.018	0.018	0.018	0.040	
14	OFF	OFF	0.014	0.018	0.018	0.018	0.025	
15	0.017	0.017	0.014	0.018	0.018	0.018	0.027	
16	0.019	0.017	0.019	0.019	0.019	0.019	0.019	
17	0.019	0.019	0.019	0.019	0.019	0.019	0.021	
18	0.019	0.019	0.019	0.021	0.021	0.021	0.021	
19	OFF	OFF	OFF	OFF	OFF	OFF	0.000	
20	OFF	0.029	0.018	0.019	0.019	0.021	0.049	
21	0.021	0.021	0.021	0.018	0.021	0.021	0.021	
22	0.021	0.018	0.021	0.023	0.023	0.023	0.023	
23	0.023	0.023	0.023	0.023	0.023	0.023	0.023	
24	0.023	0.023	0.019	0.025	0.025	0.025	0.025	
25	0.025	0.025	0.025	0.025	0.019	0.025	0.027	
26	OFF	OFF	OFF	OFF	OFF	0.023	0.025	
27	0.025	0.025	0.025	0.025	0.014	OFF	0.025	
28	OFF	OFF	0.014	0.014	0.014	0.014	0.030	

Slow Sand/Membrane/DE Filtration/Unfiltered		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? ²	<input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday?	All Cl2 residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No
Notes: OFF = PLANT OFF		PRINTED NAME: Chris Germond	
		SIGNATURE: Chris Germond	DATE: 3/7/23
		PHONE #: 541-258-4274	CERT #: T-08682

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP: **WTP-B**

System Name: **Lebanon, CITY OF**

ID#: **41-00473**

Month/Year: **2/2023**

Disinfection
Giardia Log

Inactive: **0.5**

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
2/1/2023 9:27	1.2	120	143	7	8.2	37	Yes	1828
2/2/2023 4:45	1.2	79	92	7	7.9	33	Yes	2605
2/3/2023 19:42	1.1	77	83	8	7.5	27	Yes	2851
2/4/2023 5:38	1.0	68	70	8	7.7	29	Yes	2881
2/5/2023 5:18	1.1	92	102	9	7.9	29	Yes	2114
2/6/2023 11:13	1.1	66	70	9	7.7	26	Yes	3100
2/7/2023 8:05	1.1	76	81	9	7.9	29	Yes	3040
2/8/2023 11:49	1.1	82	93	8	7.8	30	Yes	2381
2/9/2023 12:48	1.1	71	77	9	7.8	28	Yes	3245
2/10/2023 15:13	1.0	76	79	9	7.9	29	Yes	2877
2/11/2023 9:56	1.1	77	83	9	8.0	30	Yes	3163
2/12/2023 0:00					8.1			
2/13/2023 6:28	1.0	70	72	9	8.0	29	Yes	3181
2/14/2023 7:12	1.1	71	77	9	8.1	30	Yes	3252
2/15/2023 16:34	1.2	110	130	8	8.0	33	Yes	2042
2/16/2023 23:01	1.1	124	140	8	8.0	33	Yes	1627
2/17/2023 23:51	1.1	121	134	8	8.1	34	Yes	1756
2/18/2023 10:59	1.1	72	77	8	8.3	36	Yes	3070
2/19/2023 0:00								
2/20/2023 6:22	1.0	84	84	9	8.3	33	Yes	2417
2/21/2023 9:51	0.7	73	51	9	8.1	29	Yes	2877
2/22/2023 8:42	1.0	145	140	9	8.2	33	Yes	1497
2/23/2023 2:03	0.9	91	86	8	8.2	34	Yes	2523
2/24/2023 18:18	1.0	132	127	8	8.2	35	Yes	1508
2/25/2023 19:48	1.0	124	118	7	8.2	36	Yes	1747
2/26/2023 17:07	0.9	115	104	8	8.2	34	Yes	1822
2/27/2023 11:14	1.0	78	78	7	8.1	34	Yes	3180
2/28/2023 8:33	0.9	76	65	8	8.1	31	Yes	3031

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Department of Human Services - Drinking Water Section
Fluoride Report Form

Notes:

2/24/2023 Low concentration caused by chemical line air locking due to a low chemical tote.

