

OHA - DWS

Membrane Filter Monthly Operating Report

County: Linn

System Name: Lebanon, City of

Month/Year: Dec-2025

PWS ID#: 41 - 00473

Minimum test pressure applied: 18.3 psi

Plant ID: WTP - WTP-B

Minimum test pressure req'd: 18.3 psi

(e.g., "A")

DIT = Direct Integrity Test on filter(s) [Yes, No, or "off" if all filters are offline] ⇔

PDR = Pressure Decay Rate

LRC = Log Removal Credit

PDR _{Max} [psi/min]	LRC [log removal]
0.100	4.00

**DIT
Daily**

Day	CFE Daily Turbidity [NTU]	Highest CFE* [NTU]	Highest IFE [NTU]	Highest PDR of day [psi/min]	Lowest LRV _{ambient} of day [log removal]	[Y/N] or "off"
1	0.000	0	0.058	0.01	5.30	Y
2	0.000	0	0.031	0.00	5.30	Y
3	0.000	0	0.033	0.01	5.30	Y
4	0.000	0	0.024	0.01	5.30	Y
5	0.000	0	0.091	0.01	5.30	Y
6	0.000	0	0.019	0.01	5.30	Y
7	0.000	0	0.018	0.01	5.28	Y
8	0.000	0	0.019	0.03	4.77	Y
9	0.000	0	0.031	0.02	5.07	Y
10	0.000	0	0.018	0.00	5.30	Y
11	0.000	0	0.016	0.01	5.30	Y
12	0.000	0	0.025	0.00	5.30	Y
13	0.000	0	0.024	0.02	5.14	Y
14	0.000	0	0.000	0.01	5.30	Off
15	0.000	0	0.055	0.01	5.30	Y
16	0.000	0	0.016	0.01	5.30	Y
17	0.000	0	0.015	0.01	5.17	Y
18	0.000	0	0.014	0.01	5.30	Y
19	0.000	0	0.019	0.00	5.30	Y
20	0.000	0	0.016	0.00	5.30	Y
21	0.000	0	0.014	0.01	5.30	Y
22	0.000	0	0.013	0.01	5.30	Y
23	0.000	0	0.014	0.01	5.25	Y
24	0.000	0	0.015	0.01	5.30	Y
25	0.000	0	0.013	0.01	4.98	Y
26	0.000	0	0.014	0.01	5.30	Y
27	0.000	0	0.013	0.02	5.02	Y
28	0.000	0	0.016	0.02	5.00	Y
29	0.000	0	0.018	0.01	5.04	Y
30	0.000	0	0.016	0.01	5.26	Y
31	0.000	0	0.063	0.01	5.30	Y

Compliance summary (operator to complete any blank fields)

95% of daily turbidity readings ≤ 1 NTU? [Y/N]	All turbidity readings ≤ 5 NTU? [Y/N]	All IFE turbidity readings ≤ 0.15 NTU? [Y/N]	Performance std met? [Y/N] (PDR ≤ PDR _{Max} , LRV ≥ LRC)	DIT Daily?
Yes	Yes	Yes	Yes	Yes
CT's met daily? (p. 2)	All Cl ₂ residual at EP ≥ 0.2 mg/L?	PDR ≤ PDR _{Max} ?	LRV _{ambient} ≥ LRC?	
Yes	Yes	Yes	Yes	

PRINTED NAME: Tyson Keene
 SIGNATURE: 
 Notes:

DATE: 1-8-26
 WT CERT #: T09109
 PHONE #: 541-258-4273

OHA-DWS

Disinfection Monthly Operating Report

System Name: Lebanon, City of

PWS ID#: 41 - 00473

Plant ID : WTP - WTP-B

0.5

↔ Log
Inactivation
Required via
Disinfection

Day	Minimum Cl ₂ Residual at 1 st User (C) * [^{mg} /L = ppm]	Contact Time (T) [minutes]	Actual CT C x T (Formula)	Temp [° C]	pH	Required CT (Formula)	CT Met? * [Yes / No] (Formula)	Peak Hourly Demand Flow [GPM]	Notes (e.g. "Plant Off")
1	0.847	43.0809	36.5	11.6	8.08	24.9	YES	5,462	
2	0.981	39.2337	38.5	10.2	7.89	26.0	YES	5,527	
3	1.049	47.1907	49.5	9.8	7.81	26.1	YES	4,692	
4	1.033	66.8444	69.1	9.6	7.86	26.9	YES	3,409	
5	0.950	78.3593	74.5	9.6	7.65	24.8	YES	3,213	
6	0.932	169.362	157.9	9.7	7.56	23.7	YES	1,275	
7	0.926	121.225	112.2	9.5	7.58	24.2	YES	1,762	
8	0.986	68.1084	67.2	9.7	7.59	24.2	YES	3,290	
9	0.744	70.3332	52.3	10.2	7.62	22.9	YES	3,142	
10	0.870	118.86	103.4	10.6	7.52	21.9	YES	1,708	
11	1.293	188.915	244.2	11.0	7.65	23.5	YES	1,115	
12	1.236	105.539	130.5	10.9	7.78	24.5	YES	2,285	
13	1.378	68.9892	95.1	10.3	7.81	26.2	YES	3,155	
14	999.990	#DIV/0!	#DIV/0!	9.9	7.76	#####	#DIV/0!	-	Plant Off
15	1.061	141.73	150.3	11.0	7.73	23.4	YES	1,581	
16	1.247	102.07	127.3	10.3	7.63	24.3	YES	2,182	
17	1.287	128.149	164.9	10.3	7.81	26.0	YES	1,547	
18	1.273	155.15	197.5	9.6	7.79	27.0	YES	1,410	
19	1.082	146.32	158.4	10.1	7.72	24.9	YES	1,582	
20	1.321	131.476	173.6	9.8	7.61	25.1	YES	1,704	
21	1.480	154.142	228.1	9.4	7.81	28.2	YES	1,386	
22	1.385	118.898	164.7	9.3	7.75	27.5	YES	1,777	
23	1.454	95.8916	139.5	9.2	7.84	29.0	YES	2,112	
24	1.478	164.966	243.9	9.0	7.87	29.7	YES	1,497	
25	1.409	139.008	195.8	9.1	7.63	26.9	YES	1,480	
26	1.465	81.6336	119.6	9.0	7.72	28.0	YES	2,531	
27	1.424	120.829	172.1	9.0	7.74	28.2	YES	1,626	
28	1.420	148.841	211.4	8.8	7.78	28.8	YES	1,433	
29	1.399	144.125	201.6	8.2	7.78	30.0	YES	1,472	
30	1.467	127.956	187.7	8.2	7.68	29.2	YES	1,680	
31	1.435	86.2819	123.8	8.6	7.76	29.0	YES	2,663	

* If chlorine concentration at entry point < 0.2 ^{mg}/L, or CT not met, notify DWS within 24 hours.

Submit this monthly report by the 10th of following month by

mail: Drinking Water Services
PO Box 14350
Portland, OR 97293-0350

email: dwp.dmce@odhsoha.oregon.gov

fax: 971-673-0458

p. 2 of 2