

**OHA - Drinking Water Program - Surface Water Quality Data Form**  
**Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**

County: **Linn**  
 Month/Year: **6/2021**

System Name: <b>Lebanon, City of</b>		ID#: <b>41-00473</b>					Membrane	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day <sup>1</sup> [NTU]	
1	0.022	0.022	0.029	0.027	0.029	OFF	0.054	
2	OFF	OFF	0.031	0.026	0.027	0.040	0.081	
3	0.024	0.022	0.031	0.027	0.029	OFF	0.090	
4	OFF	OFF	OFF	0.020	0.018	0.022	0.039	
5	0.018	0.018	0.024	0.019	0.024	0.020	0.100	
6	0.020	0.019	0.019	0.019	0.024	OFF	0.030	
7	OFF	OFF	0.036	0.031	0.020	0.027	0.103	
8	0.020	0.018	0.019	OFF	OFF	OFF	0.025	
9	OFF	OFF	0.024	0.020	0.020	0.020	0.058	
10	0.029	0.020	0.022	0.042	OFF	OFF	0.049	
11	OFF	OFF	OFF	0.018	0.019	0.018	0.031	
12	0.018	0.018	0.018	0.018	0.018	0.020	0.027	
13	0.018	0.018	0.018	0.018	OFF	OFF	0.060	
14	OFF	OFF	0.018	0.072	0.020	0.018	0.101	
15	0.018	0.018	0.018	0.024	OFF	OFF	0.097	
16	OFF	OFF	OFF	0.038	0.054	0.020	0.081	
17	0.017	0.017	0.015	0.072	OFF	OFF	0.103	
18	OFF	OFF	0.020	0.020	0.033	0.020	0.052	
19	0.020	0.017	0.036	0.018	0.020	0.029	0.106	
20	OFF	0.018	0.018	0.017	0.017	0.022	0.033	
21	0.022	0.015	0.016	0.070	0.017	0.017	0.085	
22	0.015	0.015	0.018	0.020	OFF	OFF	0.106	
23	OFF	OFF	0.015	0.017	0.016	0.017	0.026	
24	0.017	0.018	0.017	0.018	0.020	OFF	0.071	
25	OFF	OFF	OFF	0.022	0.022	0.018	0.086	
26	0.017	0.018	0.017	0.018	0.016	0.018	0.047	
27	0.022	0.018	0.017	0.024	0.018	OFF	0.049	
28	OFF	OFF	0.017	0.083	0.033	0.025	0.092	
29	0.020	0.029	0.017	0.024	0.022	0.018	0.064	
30	OFF	OFF	0.024	0.026	0.018	0.017	0.101	
31	No Data	No Data	No Data	No Data	No Data	No Data	No Data	

Slow Sand/Membrane/DE Filtration/Unfiltered	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings $\leq$ 1 NTU? <sup>2</sup> <b>Yes / No</b>	CT's met everyday? <b>Yes / No</b>	All Cl <sub>2</sub> residual at entry point $\geq$ 0.2 mg/l? <b>Yes / No</b>
All daily turbidity readings $\leq$ 5 NTU? <b>Yes / No</b>	<b>Yes / No</b>	<b>Yes / No</b>
Notes: OFF = PLANT OFF	PRINTED NAME: <i>Chris Germond</i>	
	SIGNATURE: <i>Chris Germond</i>	DATE: <i>7/6/21</i>
	PHONE #: <i>541-405-5970</i>	CERT #: <i>T-0868</i>

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM correspond to continuous readings' maximum. <sup>2</sup> Filtered systems only.

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP: WTP-B

System Name: Lebanon, CITY OF

ID#: 41-00473

Month/Year: 6/2021

Disinfection  
Giardia Log  
Inactive:

0.5

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User ( C ) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
6/1/2021 0:44	1.0	73	71	18	7.9	16	Yes	3406
6/2/2021 6:55	0.8	73	57	16	7.8	17	Yes	3378
6/3/2021 0:43	1.0	74	70	18	7.9	15	Yes	3338
6/4/2021 11:20	0.7	71	49	16	7.8	16	Yes	3478
6/5/2021 8:22	0.9	71	68	17	7.9	17	Yes	3432
6/6/2021 0:49	1.0	74	74	15	8.0	20	Yes	3346
6/7/2021 8:19	0.8	73	60	14	7.9	20	Yes	3428
6/8/2021 1:17	1.0	75	75	15	8.0	19	Yes	3315
6/9/2021 7:03	0.8	70	57	14	7.7	18	Yes	3521
6/10/2021 2:45	1.0	73	73	16	7.9	18	Yes	3401
6/11/2021 11:54	0.8	72	56	14	7.8	19	Yes	3405
6/12/2021 23:54	1.0	73	71	15	8.0	20	Yes	3354
6/13/2021 0:49	0.9	77	71	17	8.0	17	Yes	3204
6/14/2021 7:05	0.8	74	57	15	7.8	17	Yes	3336
6/15/2021 1:09	0.9	75	71	15	8.1	20	Yes	3298
6/16/2021 10:37	0.7	73	54	15	7.8	18	Yes	3374
6/17/2021 1:47	1.0	74	71	18	8.0	17	Yes	3387
6/18/2021 5:25	0.8	71	57	16	7.9	17	Yes	3446
6/19/2021 3:20	0.9	68	62	18	8.1	16	Yes	3690
6/20/2021 1:51	0.9	71	62	18	8.1	16	Yes	3484
6/21/2021 0:31	0.9	73	66	19	8.1	15	Yes	3366
6/22/2021 8:07	0.9	73	63	19	8.1	15	Yes	3383
6/23/2021 6:21	0.7	73	53	17	8.0	17	Yes	3367
6/24/2021 2:06	0.9	73	66	18	8.1	16	Yes	3358
6/25/2021 9:54	0.7	68	48	17	8.0	17	Yes	3604
6/26/2021 23:54	0.9	68	59	20	8.1	15	Yes	3595
6/27/2021 2:37	0.8	71	60	20	8.0	14	Yes	3464
6/28/2021 7:48	0.7	74	48	20	8.1	14	Yes	3380
6/29/2021 0:33	0.9	72	66	21	8.2	15	Yes	3451
6/30/2021 6:27	0.9	72	62	19	8.2	16	Yes	3386
31	#N/A		#N/A	#N/A	#N/A	#N/A		#N/A

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

## OHA - Drinking Water Program - Surface Water Quality Data Form

Notes:

	During the summer months the plant is required to run at max speed. When this membrane plant runs at max speed it generates air and causes combined filtrate turbidity spikes. We are trying our best to troubleshoot and find a permanent solution.
6/1:	Plant shutdown from combined filtrate NTU at 0.101 NTU at 10:50 caused by air generated from MC generated from MC returning to production. Filtrate grab sample was 0.206 NTU, lots of air in sample. After sample sat for 30 minutes it read 0.054 NTU. Train turbidities at the time were: UF1 0.020, UF2 0.015, UF3 0.015, UF4 0.013.
6/5:	Plant shutdown from combined Filtrate NTU at 0.100 NTU at 06:56 caused by air generated from MC returning to production. Train turbidities at the time were: UF1 0.021, UF2 0.020, UF3 0.017, UF4 0.013.
6/14:	Plant shutdown from combined filtrate NTU at 0.101 NTU at 09:17 caused by UF2 coming out of MC into production. Train turbidities at the time were: UF1 0.021, UF2 0.018, UF3 0.019, UF4 0.013.
6/16:	Combined filtrate turbidity spike at 0.617 NTU at 15:25 caused by air generated from MC returning to production. Grab sample was 0.081 NTU. Train turbidities at the time were: UF1 0.021, UF2 in MIT, UF3 0.019, UF4 0.013.
6/17:	Plant shutdown from combined filtrate NTU at 0.103 NTU at 09:28 caused by air generated from MC returning to production. Train turbidities at the time were: UF1 0.021, UF2 0.019, UF3 0.021, UF4 0.013.
6/19:	Plant shutdown from combined filtrate NTU at 0.106 NTU at 01:30 caused by bubble in filtrate line. Turbidity beforehand was 0.017 NTU. Train turbidities at the time were: UF1 0.021, UF2 0.018, UF3 0.022, UF4 0.013.
	Plant shutdown from combined filtrate NTU at 0.106 NTU at 06:48 caused by air generated by MC returning to production. Train turbidities at the time were: UF1 0.021, UF2 0.018, UF3 0.022, UF4 0.013.
6/22:	Plant shutdown from combined filtrate NTU at 0.106 NTU at 06:51 caused by air generated from MC returning to production. Train turbidities at the time were: UF1 0.022, UF2 0.018, UF3 0.024, UF4 0.013.
6/30:	Plant shutdown from combined filtrate NTU at 0.101 NTU at 15:35 caused by air generated from MC returning to production. Train turbidities at the time were: UF1 0.020, UF2 0.015, UF3 0.033, UF4 0.013.



## Lebanon WTP MIT / LRV Test Results Report UF 1

Notes:

Fluctuating LRV values are caused by valves not closing air tight. We have been working on which valves are causing this to happen. Expected LRV on UF1 should be 5.30 as the membranes show no bubbling during the MIT.





