

# OHA - DWS

## Membrane Filter Monthly Operating Report

County: **Lincoln**

System Name: **Bear Creek**

Month/Year: **Jan-2026**

PWS ID#: 41 - **00482**

Minimum test pressure **applied**: **22.76** psi

Plant ID: WTP - \_\_\_\_\_  
(e.g., "A")

Minimum test pressure **req'd**: **22** psi

DIT = Direct Integrity Test on filter(s) [Yes, No, or "off" if all filters are offline] ⇌

PDR = Pressure Decay Rate

LRC = Log Removal Credit

PDR <sub>Max</sub> [psi/min]	LRC [log removal]	DIT Daily
4.00	4.00	

Day	CFE Daily Turbidity [NTU]	Highest CFE* [NTU]	Highest IFE [NTU] (>15 minutes)	Highest PDR of day [psi/min]	Lowest LRV <sub>ambient</sub> of day [log removal]	[Y/N] or "off"
1	0.004		0.004	<0.145		Y
2	0.004		0.004	<0.145		Y
3	0.004		0.004	<0.145		Y
4	0.004		0.004	<0.145		Y
5	0.004		0.004	<0.145		Y
6	0.004		0.004	<0.145		Y
7	0.004		0.004	<0.145		Y
8	0.004		0.004	<0.145		Y
9	0.004		0.004	<0.145		Y
10	0.004		0.004	<0.145		Y
11	0.004		0.004	<0.145		Y
12	0.004		0.004	<0.145		Y
13	0.004		0.004	<0.145		Y
14	0.004		0.004	<0.145		Y
15	0.004		0.004	<0.145		Y
16	0.004		0.004	<0.145		Y
17	0.004		0.004	<0.145		Y
18	0.004		0.004	<0.145		Y
19	0.004		0.004	<0.145		Y
20	0.004		0.004	<0.145		Y
21	0.004		0.004	<0.145		Y
22	0.004		0.004	<0.145		Y
23	0.004		0.004	<0.145		Y
24	0.004		0.004	<0.145		Y
25	0.004		0.004	<0.145		Y
26	0.004		0.004	<0.145		Y
27	0.004		0.004	<0.145		Y
28	0.004		0.004	<0.145		Y
29	0.004		0.004	<0.145		Y
30	0.004		0.004	<0.145		Y
31	0.004		0.004	<0.145		Y

**Compliance summary (operator to complete any blank fields)**

95% of daily turbidity readings ≤ 1 NTU? [Y/N]	All turbidity readings ≤ 5 NTU? [Y/N]	All IFE turbidity readings ≤ 0.15 NTU? [Y/N]	Performance std met? [Y/N] (PDR ≤ PDR <sub>Max</sub> , LRV ≥ LRC)	DIT Daily?
<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>
CT's met daily? (p. 2)	All Cl <sub>2</sub> residual at EP ≥ 0.2 mg/L?	PDR ≤ PDR <sub>Max</sub> ?	LRV <sub>ambient</sub> ≥ LRC?	
<b>Yes</b>	<b>Yes</b>	<b>Yes</b>		

**PRINTED NAME:** Curtis Olson      **DATE:** 02/10/26  
**SIGNATURE:** *Curtis Olson*      **WT CERT #:** 216644  
**Notes:**      **PHONE #:** 503-554-8333

\* Used for optimization purposes only.

