

OHA - Drinking Water Services -Turbidity Monitoring Report Form
 Conventional or Direct Filtration

County: LINCOLN
 Month/Year: Mar-21

System Name: LINCOLN CITY WATER DISTRICT ID#: 41 00483 WTP : TP - A

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/ANYTIME
2	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/ANYTIME
3	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/ANYTIME
4	PLT OFF	PLT OFF	PLT OFF	0.03	PLT OFF	PLT OFF	0.03/ANYTIME
5	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/ANYTIME
6	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	0.03	0.03/ANYTIME
7	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/ANYTIME
8	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/ANYTIME
9	PLT OFF	PLT OFF	PLT OFF	0.03	PLT OFF	PLT OFF	0.03/ANYTIME
10	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/ANYTIME
11	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/ANYTIME
12	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/ANYTIME
13	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	0.03	0.03/ANYTIME
14	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/ANYTIME
15	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/ANYTIME
16	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/ANYTIME
17	PLT OFF	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	0.03/ANYTIME
18	PLT OFF	PLT OFF	PLT OFF	0.02	0.02	PLT OFF	0.02/ANYTIME
19	PLT OFF	PLT OFF	PLT OFF	0.02	0.02	PLT OFF	0.04/1017
20	PLT OFF	PLT OFF	PLT OFF	0.02	0.02	0.02	0.02/ANYTIME
21	PLT OFF	PLT OFF	PLT OFF	0.02	0.02	PLT OFF	0.02/ANYTIME
22	PLT OFF	PLT OFF	PLT OFF	0.02	0.02	PLT OFF	0.02/ANYTIME
23	PLT OFF	PLT OFF	PLT OFF	0.02	0.02	0.02	0.02/ANYTIME
24	PLT OFF	PLT OFF	PLT OFF	0.02	0.03	PLT OFF	0.03/1600
25	PLT OFF	PLT OFF	PLT OFF	0.03	0.02	PLT OFF	0.03/NOON
26	PLT OFF	PLT OFF	PLT OFF	0.02	0.02	PLT OFF	0.02/ANYTIME
27	PLT OFF	PLT OFF	PLT OFF	0.02	0.02	0.02	0.02/ANYTIME
28	PLT OFF	PLT OFF	PLT OFF	0.02	0.02	PLT OFF	0.02/ANYTIME
29	PLT OFF	PLT OFF	PLT OFF	0.02	0.02	PLT OFF	0.02/ANYTIME
30	PLT OFF	PLT OFF	PLT OFF	0.02	0.02	PLT OFF	0.02/ANYTIME
31	PLT OFF	PLT OFF	PLT OFF	0.02	0.02	PLT OFF	0.02/ANYTIME

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No	All Cl2 residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No
All 4-hour turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No		
All turbidity readings < IFE ² triggers <input checked="" type="radio"/> Yes / <input type="radio"/> No		

Notes:	PRINTED NAME: LANI HANKINS	
	SIGNATURE: <i>Lani Hankins</i>	DATE: 4.5-21
	PHONE #: (541) 996-2987	CERT #: T-3293

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A

System Name: LINCOLN CITY WATER DISTRICT ID#: 41 00483	Month/Year: Mar-21	Disinfection <i>Giardia</i> Log Inactive:	0.5
--	--------------------	---	-----

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1/1000	1.1	54.6	60.0	11.1	7.2	19.5	YES	2789
2/1000	1.0	54.2	54.2	11.0	7.2	19.4	YES	2808
3/1000	1.0	53.5	53.5	10.7	7.2	19.8	YES	2846
4/0900	1.0	54.3	54.3	10.9	7.3	20.2	YES	2805
5/0800	0.9	56.5	50.8	10.5	7.3	20.5	YES	2697
6/1000	0.9	57.3	51.6	10.1	7.3	21.0	YES	2658
7/1000	1.0	55.7	55.7	10.1	7.0	19.2	YES	2733
8/1000	0.9	47.2	42.5	10.0	7.2	20.5	YES	2841
9/0900	1.0	53.9	53.9	10.4	7.2	20.2	YES	2825
10/0900	0.9	51.6	46.4	9.8	7.2	20.7	YES	2953
11/0900	0.9	52.4	47.1	10.0	7.2	20.5	YES	2874
12/0900	0.9	53.6	48.3	10.4	7.2	19.9	YES	2838
13/1000	0.9	53.6	48.3	9.9	7.2	20.6	YES	2839
14/1000	1.1	53.3	58.7	10.7	7.1	19.3	YES	2838
15/0900	0.9	52.1	46.9	11.1	7.2	19.0	YES	2903
16/0900	0.9	54.7	49.2	10.0	7.3	21.2	YES	2785
17/1200	1.0	53.8	53.8	10.1	7.3	21.3	YES	2815
18/1300	1.0	55.9	55.9	9.5	7.3	22.1	YES	2741
19/0900	1.0	55.8	55.8	9.8	7.2	21.0	YES	2727
20/1000	0.9	55.8	50.2	10.1	7.2	20.3	YES	2730
21/1100	0.9	55.6	50.0	10.2	7.3	20.9	YES	2740
22/1000	1.0	52.0	52.0	9.8	7.2	21.0	YES	2880
23/1000	1.0	53.5	53.5	10.2	7.2	20.4	YES	2829
24/1000	1.0	52.4	52.4	10.2	7.2	20.4	YES	2906
25/0900	0.9	52.4	47.2	10.3	7.2	20.1	YES	2870
26/0900	1.0	52.6	52.6	10.6	7.3	20.6	YES	2864
27/1000	1.1	52.0	57.2	10.6	7.3	20.8	YES	2930
28/1000	1.1	51.2	56.4	11.0	7.2	19.6	YES	2954
29/1000	1.1	54.7	60.2	10.4	7.3	21.1	YES	2783
30/1000	1.0	54.2	54.2	10.8	7.2	19.6	YES	2826
31/1000	1.0	53.2	53.2	10.8	7.2	19.6	YES	2879

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:
dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350