

OHA - Drinking Water Services -Turbidity Monitoring Report Form  
 Conventional or Direct Filtration

County: LINCOLN  
 Month/Year: Mar-22

System Name: LINCOLN CITY WATER DISTRICT ID#: 41 00483 WTP : TP - A

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]
1	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/Anytime
2	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/Anytime
3	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/Anytime
4	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/Anytime
5	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/Anytime
6	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/Anytime
7	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/Anytime
8	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/Anytime
9	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/Anytime
10	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/Anytime
11	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/Anytime
12	PLT OFF	PLT OFF	0.03	0.03	0.03	PLT OFF	0.03/Anytime
13	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	0.03	0.03/Anytime
14	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/Anytime
15	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/Anytime
16	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/Anytime
17	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/Anytime
18	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/Anytime
19	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	0.03	0.03/Anytime
20	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/Anytime
21	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/Anytime
22	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/Anytime
23	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/Anytime
24	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/Anytime
25	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/Anytime
26	PLT OFF	PLT OFF	PLT OFF	0.02	0.02	PLT OFF	0.02/Anytime
27	PLT OFF	PLT OFF	PLT OFF	0.02	0.02	PLT OFF	0.02/Anytime
28	PLT OFF	PLT OFF	PLT OFF	0.02	0.02	PLT OFF	0.02/Anytime
29	PLT OFF	PLT OFF	PLT OFF	0.02	0.02	PLT OFF	0.02/Anytime
30	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/Anytime
31	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/Anytime

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No	All Cl2 residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No
All 4-hour turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No		
All turbidity readings < IFE <sup>2</sup> triggers <input checked="" type="radio"/> Yes / <input type="radio"/> No		

Notes:	PRINTED NAME: LANI HANKINS	
	SIGNATURE: 	DATE: 4-1-22
	PHONE #: (541) 996-2987	CERT #: T-3293

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A

System Name: LINCOLN CITY WATER DISTRICT ID#: 41 00483

Month/Year: Mar-22

Disinfection *Giardia*  
Log Inactive:

0.5

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User ( C ) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1/1600	1.2	59.5	71.4	10.6	6.9	18.3	Yes	2546
2/0900	0.9	58.3	52.5	11.3	7.2	18.8	Yes	2595
3/0900	1.0	58.4	58.4	11.1	7.2	19.3	Yes	2592
4/1000	1.0	58.4	58.4	10.5	7.3	20.7	Yes	2594
5/1000	1.0	57.9	57.9	10.3	7.0	18.9	Yes	2555
6/1000	1.0	58.1	58.1	10.5	7.2	20.0	Yes	2604
7/1000	1.0	55.4	55.4	10.6	7.2	19.9	Yes	2735
8/0900	1.1	55.3	60.8	10.2	7.2	20.6	Yes	2740
9/0900	0.9	55.1	49.6	11.5	7.3	19.2	Yes	2749
10/1000	0.9	55.9	50.3	10.7	7.3	20.2	Yes	2709
11/0900	1.0	56.7	56.7	9.1	7.2	21.9	Yes	2672
12/0900	0.9	61.0	54.9	8.7	7.3	23.1	Yes	2452
13/1000	1.0	56.7	56.7	9.4	7.1	20.8	Yes	2654
14/1000	1.0	57.9	57.9	10.2	7.0	19.0	Yes	2614
15/0900	1.2	58.2	69.8	10.5	6.7	17.2	Yes	2602
16/0900	1.0	58.3	58.3	11.3	7.3	19.7	Yes	2597
17/1000	1.0	57.8	57.8	10.9	7.1	18.8	Yes	2619
18/1900	1.1	58.6	64.4	11.3	7.2	19.2	Yes	2600
19/0900	1.0	55.6	55.6	11.1	7.2	19.3	Yes	2722
20/1000	1.1	58.0	63.8	10.5	7.1	19.6	Yes	2610
21/1000	1.1	56.0	61.6	10.4	7.2	20.4	Yes	2703
22/0900	1.0	57.6	57.6	11.0	7.0	18.1	Yes	2630
23/0900	1.0	57.5	57.5	12.3	7.0	16.6	Yes	2635
24/0900	1.0	55.9	55.9	11.9	7.0	17.1	Yes	2707
25/0900	1.0	56.5	56.5	11.5	7.2	18.8	Yes	2681
26/1000	1.1	57.7	63.4	13.1	7.3	17.5	Yes	2610
27/1000	1.1	57.8	63.6	13.1	7.2	16.8	Yes	2602
28/1000	1.1	58.1	63.9	13.2	7.2	16.7	Yes	2607
29/1000	1.0	58.1	58.1	12.6	7.2	17.2	Yes	2607
30/1000	1.0	58.1	58.1	11.9	7.1	17.7	Yes	2604
31/0900	0.9	57.9	52.1	12.0	7.2	18.0	Yes	2615

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:

[dwp.dmce@state.or.us](mailto:dwp.dmce@state.or.us); 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350