

OHA - Drinking Water Services -Turbidity Monitoring Report Form

Conventional or Direct Filtration

County: LINCOLN

Month/Year: Mar-25

System Name: LINCOLN CITY WATER DISTRICT ID#: 41 00483

WTP : TP - A

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	0.03	0.03/Anytime
2	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/Anytime
3	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/Anytime
4	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/Anytime
5	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/Anytime
6	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/Anytime
7	PLT OFF	PLT OFF	PLT OFF	0.03	0.04	PLT OFF	0.04/1600
8	PLT OFF	PLT OFF	PLT OFF	0.04	0.04	PLT OFF	0.04/Anytime
9	PLT OFF	PLT OFF	PLT OFF	0.04	0.04	PLT OFF	0.04/Anytime
10	PLT OFF	PLT OFF	PLT OFF	0.04	0.04	PLT OFF	0.04/Anytime
11	PLT OFF	PLT OFF	PLT OFF	0.04	0.04	PLT OFF	0.04/Anytime
12	PLT OFF	PLT OFF	PLT OFF	0.04	0.04	PLT OFF	0.04/Anytime
13	PLT OFF	PLT OFF	PLT OFF	0.04	0.04	PLT OFF	0.04/Anytime
14	PLT OFF	PLT OFF	PLT OFF	0.04	0.04	PLT OFF	0.04/Anytime
15	PLT OFF	PLT OFF	PLT OFF	0.04	0.04	PLT OFF	0.04/Anytime
16	PLT OFF	PLT OFF	PLT OFF	0.04	0.04	0.04	0.04/Anytime
17	PLT OFF	PLT OFF	PLT OFF	0.04	0.04	PLT OFF	0.04/Anytime
18	PLT OFF	PLT OFF	PLT OFF	0.04	0.04	PLT OFF	0.04/Anytime
19	PLT OFF	PLT OFF	0.04	0.04	0.04	PLT OFF	0.04/Anytime
20	PLT OFF	PLT OFF	PLT OFF	0.04	0.04	PLT OFF	0.04/Anytime
21	PLT OFF	PLT OFF	PLT OFF	0.04	0.04	0.04	0.04/Anytime
22	PLT OFF	PLT OFF	PLT OFF	0.04	0.04	PLT OFF	0.04/Anytime
23	PLT OFF	PLT OFF	PLT OFF	0.04	0.04	0.04	0.04/Anytime
24	PLT OFF	PLT OFF	PLT OFF	0.04	0.04	PLT OFF	0.04/Anytime
25	PLT OFF	PLT OFF	PLT OFF	0.04	0.04	PLT OFF	0.04/Anytime
26	PLT OFF	PLT OFF	PLT OFF	0.04	0.04	PLT OFF	0.04/Anytime
27	PLT OFF	PLT OFF	PLT OFF	0.04	0.04	PLT OFF	0.04/Anytime
28	PLT OFF	PLT OFF	PLT OFF	0.04	0.04	PLT OFF	0.04/Anytime
29	PLT OFF	PLT OFF	PLT OFF	0.04	0.04	0.04	0.04/Anytime
30	PLT OFF	PLT OFF	PLT OFF	0.04	0.04	PLT OFF	0.04/Anytime
31	PLT OFF	PLT OFF	PLT OFF	0.04	0.04	PLT OFF	0.04/Anytime

Conventional or Direct Filtration

95% of 4-hour turbidity readings $\leq$ 0.3 NTU? ☒ Yes/ ☐ No

All 4-hour turbidity readings $\leq$ 1 NTU? ☒ Yes/ ☐ No

All turbidity readings < IFE² triggers ☒ Yes/ ☐ No

Monthly Summary (Answer Yes or No)

CT's met everyday?
(see back)

☒ Yes/ ☐ No

All Cl₂ residual at entry point
 $\geq$ 0.2 mg/l?

☒ Yes/ ☐ No

Notes:

PRINTED NAME: LANI HANKINS

SIGNATURE: 

DATE: 4-1-25

PHONE #: (541) 996-2987

CERT #: T-3293

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - :

A

System Name: LINCOLN CITY WATER DISTRICT ID#: 41 00483

Month/Year: Mar-25

Disinfection *Giardia*
Log Inactive:

0.5

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1/1100	1.1	57.1	62.8	11.8	7.2	18.6	Yes	2666
2/1100	1.1	55.5	61.1	11.1	7.2	19.5	Yes	2741
3/0900	1.1	56.5	62.2	11.7	7.3	19.4	Yes	2693
4/0900	1.0	57.1	57.1	11.6	7.2	18.6	Yes	2668
5/0900	1.0	56.8	56.8	10.7	7.1	19.1	Yes	2682
6/0900	1.0	57.0	57.0	9.9	7.3	21.6	Yes	2672
7/0900	1.0	57.4	57.4	10.2	7.1	19.7	Yes	2651
8/1000	1.0	57.2	57.2	10.9	7.2	19.5	Yes	2664
9/1000	1.1	56.9	62.6	10.9	7.2	19.7	Yes	2674
10/0900	1.0	56.8	56.8	11.0	7.2	19.4	Yes	2665
11/0900	0.9	56.8	51.1	10.4	7.2	19.9	Yes	2665
12/0900	0.9	56.7	51.1	10.6	7.2	19.7	Yes	2668
13/0900	0.9	56.6	50.9	10.5	7.1	19.1	Yes	2675
14/0900	0.8	70.7	56.6	10.4	7.1	19.0	Yes	2092
15/1100	1.0	57.3	57.3	10.3	7.1	19.6	Yes	2641
16/1100	1.0	55.9	55.9	9.5	7.0	19.9	Yes	2709
17/1000	1.0	61.9	61.9	11.0	7.1	18.7	Yes	2375
18/0900	0.9	57.1	51.4	10.1	7.1	19.6	Yes	2668
19/0800	0.8	56.8	45.4	10.0	7.0	18.9	Yes	2651
20/0900	0.9	56.6	50.9	10.0	7.2	20.5	Yes	2677
21/0900	1.0	57.1	57.1	10.4	7.1	19.5	Yes	2638
22/1000	1.1	53.6	58.9	10.6	7.2	20.1	Yes	2841
23/0900	1.1	56.7	62.4	11.0	7.2	19.6	Yes	2669
24/1000	1.0	56.6	56.6	11.2	7.1	18.5	Yes	2677
25/0900	1.0	54.5	54.5	12.1	7.1	17.4	Yes	2777
26/1100	1.0	55.9	55.9	13.0	7.1	16.2	Yes	2706
27/0900	1.0	56.0	56.0	12.8	7.2	17.0	Yes	2702
28/0900	0.9	55.6	50.1	12.4	7.1	16.9	Yes	2722
29/1100	0.9	55.9	50.3	12.0	7.0	16.8	Yes	2708
30/1100	1.0	56.3	56.3	12.0	7.1	17.6	Yes	2690
31/0900	1.1	57.8	63.6	11.1	7.1	18.8	Yes	2617

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:

dwp.dnce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350