

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: LINCOLN

Conventional or Direct Filtration

Month/Year: Apr-25

System Name: LINCOLN CITY WATER DISTRICT		ID#: 41 00483		WTP : TP - A			
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	PLT OFF	PLT OFF	PLT OFF	0.04	0.04	PLT OFF	0.04/Anytime
2	PLT OFF	PLT OFF	PLT OFF	0.04	0.04	PLT OFF	0.04/Anytime
3	PLT OFF	PLT OFF	PLT OFF	0.04	0.04	PLT OFF	0.04/Anytime
4	PLT OFF	PLT OFF	PLT OFF	0.04	0.04	PLT OFF	0.04/Anytime
5	PLT OFF	PLT OFF	PLT OFF	0.04	0.04	PLT OFF	0.04/Anytime
6	PLT OFF	PLT OFF	PLT OFF	0.04	0.04	0.04	0.04/Anytime
7	PLT OFF	PLT OFF	PLT OFF	0.04	0.04	PLT OFF	0.04/Anytime
8	PLT OFF	PLT OFF	PLT OFF	0.04	0.04	PLT OFF	0.04/Anytime
9	PLT OFF	PLT OFF	PLT OFF	0.04	0.04	PLT OFF	0.04/Anytime
10	PLT OFF	PLT OFF	PLT OFF	0.04	0.04	PLT OFF	0.04/Anytime
11	PLT OFF	PLT OFF	PLT OFF	0.04	0.04	PLT OFF	0.04/Anytime
12	PLT OFF	PLT OFF	PLT OFF	0.04	0.04	PLT OFF	0.04/Anytime
13	PLT OFF	PLT OFF	PLT OFF	0.04	0.04	PLT OFF	0.04/Anytime
14	PLT OFF	PLT OFF	PLT OFF	0.04	0.04	PLT OFF	0.04/Anytime
15	PLT OFF	PLT OFF	PLT OFF	0.04	0.04	PLT OFF	0.04/Anytime
16	PLT OFF	PLT OFF	PLT OFF	0.04	0.04	PLT OFF	0.04/Anytime
17	PLT OFF	PLT OFF	PLT OFF	0.04	0.04	PLT OFF	0.04/Anytime
18	PLT OFF	PLT OFF	PLT OFF	0.04	0.04	0.04	0.04/Anytime
19	PLT OFF	PLT OFF	PLT OFF	0.04	0.04	0.04	0.04/Anytime
20	PLT OFF	PLT OFF	PLT OFF	0.04	0.04	PLT OFF	0.04/Anytime
21	PLT OFF	PLT OFF	PLT OFF	0.04	0.04	PLT OFF	0.04/Anytime
22	PLT OFF	PLT OFF	PLT OFF	0.04	0.04	PLT OFF	0.04/Anytime
23	PLT OFF	PLT OFF	PLT OFF	0.04	0.04	PLT OFF	0.04/Anytime
24	PLT OFF	PLT OFF	PLT OFF	0.04	0.04	PLT OFF	0.04/Anytime
25	PLT OFF	PLT OFF	PLT OFF	0.04	0.04	PLT OFF	0.04/Anytime
26	PLT OFF	PLT OFF	PLT OFF	0.04	0.04	PLT OFF	0.04/Anytime
27	PLT OFF	PLT OFF	PLT OFF	0.04	0.04	PLT OFF	0.04/Anytime
28	PLT OFF	PLT OFF	PLT OFF	0.04	0.04	PLT OFF	0.04/Anytime
29	PLT OFF	PLT OFF	PLT OFF	0.04	0.04	PLT OFF	0.04/Anytime
30	PLT OFF	PLT OFF	PLT OFF	0.04	0.04	PLT OFF	0.04/Anytime

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU?	☒ Yes ☐ No	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All 4-hour turbidity readings ≤ 1 NTU?	☒ Yes ☐ No	☒ Yes ☐ No	☒ Yes ☐ No
All turbidity readings < IFE ² triggers	☒ Yes ☐ No		
		PRINTED NAME: LANI HANKINS	
		SIGNATURE: <i>Lani Hankins</i>	DATE: 5/1/25
		PHONE #: (541) 996-2987	CERT #: T-3293

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

System Name: LINCOLN CITY WATER DISTRICT ID#: 41 00483							Month/Year: Apr-25	
Disinfection <i>Giardia</i> Log Inactive:							WTP - : A 0.5	
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1/0900	0.8	57.6	46.1	10.5	7.0	18.3	Yes	2628
2/1000	1.0	56.9	56.9	11.3	7.2	19.0	Yes	2661
3/0900	0.9	56.8	51.1	11.0	7.2	19.2	Yes	2666
4/1000	1.0	57.2	57.2	11.3	7.3	19.7	Yes	2663
5/1000	1.1	57.0	62.7	11.3	7.2	19.2	Yes	2670
6/1000	1.0	54.8	54.8	12.0	7.2	18.2	Yes	2761
7/1000	1.0	57.1	57.1	11.6	7.2	18.6	Yes	2653
8/0900	0.9	56.8	51.1	11.5	7.2	18.6	Yes	2665
9/1000	0.8	57.0	45.6	11.6	7.2	18.2	Yes	2657
10/0900	1.0	57.0	57.0	12.5	7.3	18.0	Yes	2658
11/0900	0.9	57.4	51.6	11.6	7.3	19.1	Yes	2638
12/1000	1.1	52.5	57.7	10.6	7.2	20.1	Yes	2836
13/1000	1.0	52.5	52.5	10.6	7.2	19.9	Yes	2836
14/1000	1.0	59.2	59.2	11.9	7.2	18.3	Yes	2573
15/1000	1.0	57.5	57.5	12.9	7.2	16.9	Yes	2647
16/1000	1.0	56.9	56.9	13.0	7.2	16.8	Yes	2678
17/1000	1.0	57.0	57.0	12.7	7.2	17.1	Yes	2670
18/1000	1.0	56.9	56.9	12.4	7.2	17.7	Yes	2677
19/1100	1.0	57.1	57.1	13.2	7.2	16.5	Yes	2666
20/1100	1.1	56.7	62.4	13.5	7.3	17.0	Yes	2683
21/1000	1.0	56.8	56.8	12.2	7.2	17.9	Yes	2682
22/0900	0.9	54.8	49.3	12.2	7.2	17.7	Yes	2761
23/0900	1.0	57.0	57.0	12.4	7.2	17.7	Yes	2673
24/0900	0.8	56.8	45.4	12.2	7.3	18.2	Yes	2682
25/1000	1.0	54.4	54.4	12.3	7.2	17.8	Yes	2815
26/1000	1.0	55.8	55.8	12.0	7.1	17.6	Yes	2728
27/0900	0.9	54.9	49.4	12.0	7.3	18.6	Yes	2775
28/1000	1.0	48.9	48.9	12.5	7.2	17.3	Yes	3113
29/0900	0.9	52.6	47.4	12.5	7.1	16.5	Yes	2910
30/1000	0.8	52.1	41.7	12.2	7.1	17.0	Yes	2924

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350