

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: LINCOLN

Conventional or Direct Filtration

Month/Year: May-25

System Name:	LINCOLN CITY WATER DISTRICT			ID#: 41 00483	WTP : TP - A		
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	PLT OFF	PLT OFF	PLT OFF	0.04	0.04	PLT OFF	0.04/Anytime
2	PLT OFF	PLT OFF	PLT OFF	0.04	0.04	PLT OFF	0.04/Anytime
3	PLT OFF	PLT OFF	PLT OFF	0.04	0.04	PLT OFF	0.04/Anytime
4	PLT OFF	PLT OFF	PLT OFF	0.04	0.04	PLT OFF	0.04/Anytime
5	PLT OFF	PLT OFF	PLT OFF	0.04	0.04	PLT OFF	0.04/Anytime
6	PLT OFF	PLT OFF	PLT OFF	0.04	0.04	PLT OFF	0.04/Anytime
7	PLT OFF	PLT OFF	PLT OFF	0.04	0.04	PLT OFF	0.04/Anytime
8	PLT OFF	PLT OFF	PLT OFF	0.04	0.04	PLT OFF	0.04/Anytime
9	PLT OFF	PLT OFF	PLT OFF	0.04	0.04	PLT OFF	0.04/Anytime
10	PLT OFF	PLT OFF	PLT OFF	0.04	0.04	0.04	0.04/Anytime
11	PLT OFF	PLT OFF	PLT OFF	0.04	0.04	PLT OFF	0.04/Anytime
12	PLT OFF	PLT OFF	PLT OFF	0.04	0.04	PLT OFF	0.04/Anytime
13	PLT OFF	PLT OFF	PLT OFF	0.04	0.04	PLT OFF	0.04/Anytime
14	PLT OFF	PLT OFF	0.04	0.04	PLT OFF	PLT OFF	0.04/Anytime
15	PLT OFF	PLT OFF	0.04	0.04	0.04	PLT OFF	0.04/Anytime
16	PLT OFF	PLT OFF	PLT OFF	0.04	0.04	PLT OFF	0.04/Anytime
17	PLT OFF	PLT OFF	PLT OFF	0.04	0.04	PLT OFF	0.04/Anytime
18	PLT OFF	PLT OFF	PLT OFF	0.04	0.04	PLT OFF	0.04/Anytime
19	PLT OFF	PLT OFF	PLT OFF	0.04	0.04	PLT OFF	0.04/Anytime
20	PLT OFF	PLT OFF	PLT OFF	0.04	0.04	PLT OFF	0.04/Anytime
21	PLT OFF	PLT OFF	PLT OFF	0.04	0.04	PLT OFF	0.04/Anytime
22	PLT OFF	PLT OFF	PLT OFF	0.04	0.04	PLT OFF	0.04/Anytime
23	PLT OFF	PLT OFF	PLT OFF	0.04	0.04	PLT OFF	0.04/Anytime
24	PLT OFF	PLT OFF	PLT OFF	0.04	0.04	0.04	0.04/Anytime
25	PLT OFF	PLT OFF	PLT OFF	0.04	0.04	0.04	0.04/Anytime
26	PLT OFF	PLT OFF	PLT OFF	0.04	0.04	PLT OFF	0.04/Anytime
27	PLT OFF	PLT OFF	PLT OFF	0.04	0.04	PLT OFF	0.04/Anytime
28	PLT OFF	PLT OFF	PLT OFF	0.04	0.04	PLT OFF	0.04/Anytime
29	PLT OFF	PLT OFF	PLT OFF	0.04	0.04	PLT OFF	0.04/Anytime
30	PLT OFF	PLT OFF	PLT OFF	0.04	0.04	PLT OFF	0.04/Anytime
31	PLT OFF	PLT OFF	PLT OFF	0.04	0.04	PLT OFF	0.04/Anytime


Conventional or Direct Filtration

Monthly Summary (Answer Yes or No)

95% of 4-hour turbidity readings $\leq$ 0.3 NTU?☒ Yes ☐ NoAll 4-hour turbidity readings $\leq$ 1 NTU?☒ Yes ☐ NoAll turbidity readings < IFE² triggers☒ Yes ☐ NoCT's met everyday?
(see back)☒ Yes ☐ NoAll Cl₂ residual at entry point
 $\geq$ 0.2 mg/l?☒ Yes ☐ No

Notes:

PRINTED NAME: BEN PENA

SIGNATURE:  DATE:

PHONE #: (541) 364-1169

CERT #: T-09441

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A

System Name: CITY OF LINCOLN CITY		ID#: 41 00482	Month/Year: MAY 2025		Disinfection Giardia Log Inactive:		0.5	
Date / Time	Minimum Cl2 Residual at 1st User (C) 3	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? 3	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1/0900	0.9	52.5	47.3	12.6	7.1	16.4	Yes	2882
2/0900	0.9	55.3	49.8	13.0	7.1	16.0	Yes	2737
3/0900	1.0	52.8	52.8	12.4	7.1	17.1	Yes	2865
4/1000	0.8	52.5	42.0	12.9	7.1	15.9	Yes	2919
5/0900	1.0	55.3	55.3	12.9	7.1	16.3	Yes	2740
6/0900	0.9	55.0	49.5	13.3	7.1	15.7	Yes	2754
7/0900	0.8	56.3	45.0	14.4	7.3	15.5	Yes	2689
8/0900	1.0	57.1	57.1	12.3	7.1	17.2	Yes	2668
9/1000	0.8	62.3	49.8	12.9	7.1	15.9	Yes	2402
10/1200	0.9	57.2	51.5	13.4	7.2	16.1	Yes	2618
11/1100	1.0	54.9	54.9	13.3	7.3	17.0	Yes	2772
12/1000	1.0	61.6	61.6	12.2	7.1	17.3	Yes	2458
13/0900	1.0	55.8	55.8	12.6	7.2	17.2	Yes	2727
14/0800	1.0	55.1	55.1	12.4	7.1	17.1	Yes	2761
15/0800	0.8	54.6	43.7	12.4	7.2	17.3	Yes	2789
16/1000	0.9	53.4	48.0	12.4	7.2	17.5	Yes	2853
17/1000	0.9	56.2	50.6	12.6	7.2	17.0	Yes	2695
18/1100	1.0	54.6	54.6	13.5	7.2	16.2	Yes	2786
19/1000	1.0	55.3	55.3	13.4	7.2	16.3	Yes	2752
20/0900	0.9	57.1	51.4	12.9	7.2	16.7	Yes	2668
21/1000	0.8	55.7	44.5	12.9	7.1	15.9	Yes	2734
22/0900	0.9	57.1	51.4	13.9	7.2	15.6	Yes	2668
23/1000	0.7	56.9	39.8	13.0	7.2	16.2	Yes	2676
24/1000	0.9	53.0	47.7	14.4	7.2	15.1	Yes	2678
25/1100	1.1	56.9	62.6	14.1	7.1	15.2	Yes	2676
26/1000	1.2	54.7	65.7	14.0	7.3	16.6	Yes	2766
27/1000	1.1	57.0	62.7	14.5	7.5	17.1	Yes	2658
28/0900	0.9	56.8	51.1	15.4	7.2	14.1	Yes	2666
29/0900	0.9	55.3	49.8	15.0	7.2	14.5	Yes	2738
30/0900	0.7	56.8	39.8	14.2	7.2	15.0	Yes	2664
31/0900	0.9	56.3	50.7	15.6	7.1	13.4	Yes	2687

3 If Cl2 at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350