

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: LINCOLN

Conventional or Direct Filtration

Month/Year: Jun-25

System Name: LINCOLN CITY WATER DISTRICT		ID#: 41 00483		WTP : TP - A			
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	PLT OFF	PLT OFF	PLT OFF	0.04	0.04	0.04	0.04/ANYTIME
2	PLT OFF	PLT OFF	PLT OFF	0.04	0.04	PLT OFF	0.04/ANYTIME
3	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/ANYTIME
4	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	0.03	0.03/ANYTIME
5	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	0.03	0.04/1317
6	PLT OFF	PLT OFF	PLT OFF	0.03	0.04	PLT OFF	0.04/1600
7	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/ANYTIME
8	PLT OFF	PLT OFF	0.03	0.03	0.03	0.03	0.03/ANYTIME
9	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.05/1142
10	PLT OFF	PLT OFF	PLT OFF	0.02	0.02	0.02	0.02/ANYTIME
11	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/ANYTIME
12	PLT OFF	PLT OFF	PLT OFF	0.02	0.02	PLT OFF	0.02/ANYTIME
13	PLT OFF	PLT OFF	PLT OFF	0.02	0.02	PLT OFF	0.02/ANYTIME
14	PLT OFF	PLT OFF	PLT OFF	0.02	0.02	0.02	0.02/ANYTIME
15	PLT OFF	PLT OFF	PLT OFF	0.02	0.02	0.02	0.02/ANYTIME
16	PLT OFF	PLT OFF	PLT OFF	0.02	0.02	PLT OFF	0.02/ANYTIME
17	PLT OFF	PLT OFF	PLT OFF	0.02	0.02	PLT OFF	0.02/ANYTIME
18	PLT OFF	PLT OFF	0.04	0.04	0.04	PLT OFF	0.05/1000
19	PLT OFF	PLT OFF	PLT OFF	0.04	0.04	PLT OFF	0.04/ANYTIME
20	PLT OFF	PLT OFF	PLT OFF	0.02	0.02	0.02	0.02/ANYTIME
21	PLT OFF	PLT OFF	PLT OFF	0.02	0.02	0.02	0.02/ANYTIME
22	0.02	PLT OFF	PLT OFF	0.03	0.03	0.03	0.05/1201
23	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.07/0958
24	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/ANYTIME
25	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.05/1008
26	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	0.03	0.06/1106
27	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	0.03	0.04/1458
28	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	0.03	0.05/1340
29	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	0.03	0.03/ANYTIME
30	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	0.03	0.05/0955

Conventional or Direct Filtration

Monthly Summary (Answer Yes or No)

95% of 4-hour turbidity readings $\leq$ 0.3 NTU?☒ Yes ☐ NoAll 4-hour turbidity readings $\leq$ 1 NTU?☒ Yes ☐ NoAll turbidity readings < IFE² triggers☒ Yes ☐ NoCT's met everyday?
(see back)☒ Yes ☐ NoAll Cl₂ residual at entry point
 $\geq$ 0.2 mg/l?☒ Yes ☐ No

Notes:

PRINTED NAME: BEN PENA JR

SIGNATURE

DATE: 7/2/25

PHONE #: (541) 364-1169

CERT #: T-09441

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A

System Name: CITY OF LINCOLN CITY ID#: 41 00483 Month/Year: Jun-25							Disinfection <i>Giardia</i> Log Inactive:	0.5
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1/0900	0.9	55.5	50.0	14.5	7.2	15.0	Yes	2680
2/0900	1.1	56.5	62.2	15.1	7.0	13.7	Yes	2678
3/0900	0.7	56.9	39.8	15.1	7.2	14.1	Yes	2676
4/1200	0.8	55.1	44.1	15.9	7.2	13.5	Yes	2762
5/0900	1.1	55.4	60.9	15.6	7.3	14.8	Yes	2748
6/0900	1.0	56.5	56.5	16.3	7.2	13.4	Yes	2681
7/0900	1.0	56.6	56.6	16.6	7.2	13.2	Yes	2691
8/0800	0.8	56.8	45.4	16.3	7.2	13.1	Yes	2666
9/1000	1.1	55.6	61.1	16.6	7.2	13.3	Yes	2725
10/1100	1.0	55.3	55.3	16.6	7.1	12.7	Yes	2739
11/0900	1.1	53.9	59.3	16.4	7.2	13.5	Yes	2810
12/0900	0.9	56.4	50.8	15.5	7.2	14.0	Yes	2683
13/0900	1.0	55.5	55.5	15.9	7.1	13.3	Yes	2713
14/0900	1.0	55.2	55.2	15.0	7.1	14.1	Yes	2712
15/0900	1.0	55.1	55.1	15.2	7.1	13.9	Yes	2731
16/0900	1.0	54.9	54.9	15.4	7.1	13.8	Yes	2760
17/0900	0.9	56.8	51.1	15.3	7.1	13.7	Yes	2680
18/0800	0.9	55.2	49.7	15.9	7.1	13.2	Yes	2756
19/0900	0.9	57.1	51.4	16.3	7.3	13.8	Yes	2665
20/1000	1.0	56.7	56.7	16.0	7.2	13.7	Yes	2684
21/0900	0.9	57.2	51.4	14.5	7.1	14.4	Yes	2664
22/1100	0.9	57.2	51.5	13.8	6.9	14.1	Yes	2647
23/0900	0.9	55.1	49.6	14.4	7.2	15.1	Yes	2749
24/1000	0.9	55.3	49.8	15.8	7.3	14.3	Yes	2738
25/0900	1.0	56.3	56.3	14.8	7.1	14.3	Yes	2672
26/1100	0.9	56.1	50.5	15.4	7.2	14.1	Yes	2683
27/1000	0.9	57.0	51.3	14.6	7.2	14.9	Yes	2658
28/1000	1.0	58.3	58.3	16.3	7.2	13.4	Yes	2584
29/1000	1.0	55.3	55.3	17.0	7.1	12.4	Yes	2736
30/0900	1.1	57.1	62.8	17.5	7.2	12.6	Yes	2667

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018