

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: LINCOLN

Conventional or Direct Filtration

Month/Year: Aug-25

System Name: LINCOLN CITY WATER DISTRICT		ID#: 41 00483		WTP : TP - A			
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	0.05	0.05/2000
2	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	0.03	0.03/Anytime
3	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	0.04	0.04/2000
4	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/Anytime
5	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	0.03	0.03/Anytime
6	PLT OFF	PLT OFF	PLT OFF	0.05	0.04	PLT OFF	0.05/NOON
7	PLT OFF	PLT OFF	PLT OFF	0.05	0.03	0.03	0.07/1100
8	PLT OFF	PLT OFF	PLT OFF	0.04	0.03	0.03	0.08/0952
9	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	0.03	0.03/Anytime
10	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	0.03	0.06/2149
11	0.03	PLT OFF	PLT OFF	0.03	0.03	0.03	0.04/1000
12	PLT OFF	PLT OFF	PLT OFF	0.04	0.04	0.04	0.08/1107
13	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	0.03	0.03/Anytime
14	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	0.03	0.03/Anytime
15	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	0.03	0.05/1442
16	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	0.03	0.05/1115
17	0.03	PLT OFF	PLT OFF	0.03	0.03	0.03	0.03/Anytime
18	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/Anytime
19	PLT OFF	PLT OFF	0.03	0.03	0.03	0.03	0.07/0911
20	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.07/1414
21	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	0.03	0.06/1005
22	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	0.03	0.07/0838
23	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	0.03	0.04/1413
24	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	0.03	0.06/2029
25	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	0.03	0.06/1831
26	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.04/0900
27	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	0.03	0.03/Anytime
28	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/Anytime
29	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	0.03	0.03/Anytime
30	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	0.03	0.03/Anytime
31	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	0.03	0.03/Anytime

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings $\leq$ 0.3 NTU?	☒ Yes / ☐ No	CT's met everyday? (see back)	All Cl ₂ residual at entry point $\geq$ 0.2 mg/l?
All 4-hour turbidity readings $\leq$ 1 NTU?	☒ Yes / ☐ No	☒ Yes / ☐ No	☒ Yes / ☐ No
All turbidity readings < IFE ² triggers	☒ Yes / ☐ No		

Notes:	PRINTED NAME: BEN PENA JR	
	SIGNATURE: <i>[Signature]</i>	DATE: 8/2/25
	PHONE #: (541) 996-2987	CERT #: T-09441

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Eff. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A

System Name: LINCOLN CITY WATER DISTRICT ID#: 41 00483 Month/Year: 25-Aug							Disinfection Giardia Log Inactive:	0.5
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1/0900	1.1	56.8	62.5	18.1	7.1	11.6	Yes	2666
2/1000	1.2	57.0	68.4	18.0	7.1	11.8	Yes	2671
3/0900	1.2	56.6	68.0	17.8	7.2	12.4	Yes	2673
4/0900	1.2	56.8	68.2	16.8	7.1	12.8	Yes	2664
5/0900	0.9	55.2	49.7	16.6	7.1	12.6	Yes	2744
6/0900	1.2	56.6	67.9	17.5	7.2	12.7	Yes	2674
7/0900	0.9	54.5	49.0	16.4	7.1	12.7	Yes	2762
8/0900	1.0	56.5	56.5	16.9	7.1	12.4	Yes	2679
9/1000	1.0	55.1	55.1	17.0	7.1	12.4	Yes	2749
10/1200	0.8	56.8	45.4	18.0	7.2	11.7	Yes	2665
11/1000	1.1	56.8	62.5	18.0	7.1	11.7	Yes	2666
12/0900	1.1	56.2	61.8	18.6	7.2	11.7	Yes	2693
13/1000	1.1	54.3	59.7	19.2	7.1	10.8	Yes	2803
14/1100	1.0	57.0	57.0	18.5	7.0	10.8	Yes	2654
15/0900	1.1	56.9	62.5	18.2	7.1	11.5	Yes	2602
16/1000	0.8	68.9	55.1	17.4	7.0	11.3	Yes	2135
17/1100	0.9	55.5	50.0	17.2	7.1	12.1	Yes	2649
18/0900	1.0	57.1	57.1	17.4	7.1	12.0	Yes	2649
19/0900	0.9	57.1	51.4	17.2	7.0	11.6	Yes	2651
20/0900	1.0	56.2	56.2	18.0	7.1	11.6	Yes	2661
21/0900	1.1	56.7	62.3	17.5	7.1	12.1	Yes	2672
22/0900	1.2	57.9	69.5	17.3	7.2	12.9	Yes	2615
23/0900	1.1	55.3	60.8	17.2	7.1	12.3	Yes	2740
24/1000	1.1	54.9	60.3	16.6	7.1	12.8	Yes	2760
25/1000	1.1	56.0	61.6	17.4	7.1	12.2	Yes	2720
26/0900	1.1	56.8	62.4	18.0	7.2	12.1	Yes	2682
27/0900	1.0	56.8	56.8	16.9	7.1	12.4	Yes	2679
28/0900	1.1	56.7	62.4	16.6	7.2	13.3	Yes	2684
29/0900	1.0	56.9	56.9	16.5	7.2	13.3	Yes	2677
30/1000	1.1	56.5	62.1	16.5	7.1	12.9	Yes	2680
31/1000	1.1	55.8	61.4	16.0	7.0	12.9	Yes	2712

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.