

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: LINCOLN

Conventional or Direct Filtration

Month/Year: Sep-25

System Name: LINCOLN CITY WATER DISTRICT		ID#: 4100483		WTP : TP - A			
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	0.03	0.03/Anytime
2	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/Anytime
3	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/Anytime
4	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.09/1402
5	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/Anytime
6	PLT OFF	PLT OFF	PLT OFF	0.04	0.04	0.04	0.05/1430
7	PLT OFF	PLT OFF	PLT OFF	0.04	0.04	PLT OFF	0.04/Anytime
8	PLT OFF	PLT OFF	PLT OFF	0.04	0.04	0.04	0.04/Anytime
9	PLT OFF	PLT OFF	PLT OFF	0.04	0.04	PLT OFF	0.04/Anytime
10	PLT OFF	PLT OFF	0.04	0.04	0.04	PLT OFF	0.04/Anytime
11	PLT OFF	PLT OFF	PLT OFF	0.04	0.04	PLT OFF	0.04/Anytime
12	PLT OFF	PLT OFF	PLT OFF	0.04	0.04	0.04	0.04/Anytime
13	PLT OFF	PLT OFF	PLT OFF	0.04	0.04	PLT OFF	0.04/Anytime
14	PLT OFF	PLT OFF	PLT OFF	0.06	0.06	0.06	0.06/Anytime
15	PLT OFF	PLT OFF	PLT OFF	0.04	0.04	PLT OFF	0.04/Anytime
16	PLT OFF	PLT OFF	PLT OFF	0.04	0.04	PLT OFF	0.04/Anytime
17	PLT OFF	PLT OFF	PLT OFF	PLT OFF	0.04	0.04	0.04/Anytime
18	PLT OFF	PLT OFF	PLT OFF	0.04	0.04	PLT OFF	0.07/0937
19	PLT OFF	PLT OFF	PLT OFF	0.04	PLT OFF	PLT OFF	0.08/2334
20	0.07	0.05	PLT OFF	0.03	0.03	0.03	0.07/0005
21	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/Anytime
22	PLT OFF	PLT OFF	PLT OFF	0.03	0.04	0.03	0.05/1555
23	PLT OFF	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	0.03/Anytime
24	PLT OFF	PLT OFF	PLT OFF	PLT OFF	PLT OFF	0.03	0.03/Anytime
25	0.03	0.03	0.03	0.03	0.03	PLT OFF	0.07/1407
26	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.07/1341
27	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	0.03	0.03/Anytime
28	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/Anytime
29	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	0.03	0.03/Anytime
30	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/Anytime

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings $\leq$ 0.3 NTU?	<u>Yes / No</u>	CT's met everyday? (see back)	All Cl2 residual at entry point $\geq$ 0.2 mg/l?
All 4-hour turbidity readings $\leq$ 1 NTU?	<u>Yes / No</u>	<u>Yes / No</u>	<u>Yes / No</u>
All turbidity readings < IFE ² triggers	<u>Yes / No</u>		

Notes:	PRINTED NAME: BEN PENA JR	
	SIGNATURE: <i>[Signature]</i>	DATE: 10/2/25
	PHONE #: (541) 996-2987	CERT #: T-09441

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A

System Name: LINCOLN CITY WATER DISTRICT ID#: 41 00483 Month/Year: Sep-25							Disinfection Giardia Log Inactive:	0.5
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1/1000	1.1	56.6	62.3	16.8	7.1	12.7	Yes	2675
2/1000	1.2	59.3	71.2	16.6	7.0	12.5	Yes	2552
3/0900	1.0	56.6	56.6	16.9	7.1	12.4	Yes	2674
4/0900	1.0	56.7	56.7	16.7	7.1	12.6	Yes	2668
5/1000	1.0	56.8	56.8	17.2	7.1	12.2	Yes	2666
6/1100	1.0	55.8	55.8	17.1	7.1	12.3	Yes	2730
7/1100	1.1	56.6	62.3	16.6	7.2	13.3	Yes	2674
8/1000	1.0	56.9	56.9	17.5	7.1	12.0	Yes	2659
9/0900	1.1	56.3	61.9	16.5	7.1	12.9	Yes	2706
10/0800	0.8	56.9	45.5	16.5	7.1	12.5	Yes	2675
11/0800	1.0	56.7	56.7	16.1	7.0	12.7	Yes	2668
12/0900	1.0	57.2	57.2	15.9	7.0	12.8	Yes	2663
13/0900	1.0	57.4	57.4	16.4	7.0	12.4	Yes	2652
14/1000	0.9	57.1	51.4	16.4	7.1	12.7	Yes	2668
15/0900	0.8	56.5	45.2	15.2	6.9	12.7	Yes	2678
16/0900	0.7	56.0	39.2	14.7	7.1	13.9	Yes	2701
17/1000	0.8	55.6	44.5	16.3	7.2	13.1	Yes	2722
18/1600	1.2	54.3	65.1	17.4	7.1	12.3	Yes	2805
19/0900	1.0	56.4	56.4	12.4	7.2	17.7	Yes	2682
20/1000	1.3	54.6	71.0	13.8	7.1	15.8	Yes	2773
21/1000	1.1	56.4	62.1	14.7	7.1	14.6	Yes	2682
22/0900	0.9	56.8	51.1	15.5	7.2	14.0	Yes	2679
23/1300	0.8	53.5	42.8	15.0	7.1	13.8	Yes	2717
24/2000	0.8	47.8	38.3	14.7	7.0	13.6	Yes	2769
25/1200	1.1	58.6	64.4	13.3	7.0	15.4	Yes	2599
26/1000	1.1	57.1	62.8	14.2	7.0	14.5	Yes	2652
27/1100	1.1	57.2	63.0	14.5	7.0	14.2	Yes	2630
28/1100	1.0	56.4	56.4	15.0	7.1	14.1	Yes	2683
29/0900	1.0	54.8	54.8	15.6	7.0	13.1	Yes	2713
30/0900	0.9	56.4	50.8	14.7	6.9	13.2	Yes	2682

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.