


OHA - Drinking Water Services -Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: **LINCOLN**
 Month/Year: **Nov-25**

System Name:	LINCOLN CITY WATER DISTRICT			ID#: 41 00483	WTP : TP - A		
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	PLT OFF	PLT OFF	PLT OFF	0.03	0.04	0.04	0.05/1830
2	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/Anytime
3	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/Anytime
4	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/Anytime
5	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/Anytime
6	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/Anytime
7	PLT OFF	PLT OFF	PLT OFF	PLT OFF	0.04	0.04	0.04/Anytime
8	PLT OFF	PLT OFF	PLT OFF	0.03	0.04	PLT OFF	0.04/1400
9	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	0.03	0.03/Anytime
10	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/Anytime
11	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/Anytime
12	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/Anytime
13	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/Anytime
14	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/Anytime
15	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/Anytime
16	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/Anytime
17	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/Anytime
18	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/Anytime
19	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/Anytime
20	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	0.03	0.03/Anytime
21	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/Anytime
22	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	0.03	0.03/Anytime
23	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/Anytime
24	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/Anytime
25	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/Anytime
26	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/Anytime
27	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/Anytime
28	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	0.03	0.04/1716
29	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/Anytime
30	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/Anytime

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings $\leq$ 0.3 NTU?	☒ Yes / ☐ No	CT's met everyday? (see back)	All Cl ₂ residual at entry point $\geq$ 0.2 mg/l?
All 4-hour turbidity readings $\leq$ 1 NTU?	☒ Yes / ☐ No	☒ Yes / ☐ No	☒ Yes / ☐ No
All turbidity readings < IFE ² triggers	☒ Yes / ☐ No		
Notes:		PRINTED NAME: BEN PENA JR	
		SIGNATURE: 	DATE: 12-4-25
		PHONE #: (541) 996-2987	CERT #: T-09441

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form
WTP - : A

System Name: LINCOLN CITY WATER DISTRICT			ID#: 41 00483		Month/Year: 25-Nov		Disinfection Giardia Log Inactive:	0.5
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1/1800	0.9	93.1	83.8	12.7	6.9	15.1	Yes	1608
2/1000	1.1	56.6	62.3	12.5	7.0	16.3	Yes	2673
3/0900	1.0	55.8	55.8	12.5	6.8	14.9	Yes	2683
4/1100	0.9	56.8	51.1	12.2	7.0	16.6	Yes	2664
5/1000	1.2	58.6	70.3	12.9	6.9	15.4	Yes	2583
6/1000	1.0	56.9	56.9	13.3	7.0	15.3	Yes	2662
7/1300	0.9	58.5	52.6	13.1	7.2	16.5	Yes	2588
8/1100	1.1	57.1	62.8	11.8	7.2	18.6	Yes	2652
9/1000	1.1	57.1	62.8	11.8	6.9	16.8	Yes	2650
10/0900	1.1	55.6	61.1	12.3	7.0	16.8	Yes	2724
11/1000	1.0	56.2	56.2	12.5	7.3	18.0	Yes	2694
12/0900	1.1	54.9	60.4	12.0	7.2	18.4	Yes	2759
13/0900	1.0	56.4	56.4	12.6	7.1	16.6	Yes	2685
14/1000	1.0	56.4	56.4	12.9	7.0	15.7	Yes	2686
15/1000	1.0	56.7	56.7	12.9	7.1	16.3	Yes	2669
16/1000	0.9	54.2	48.8	13.0	7.0	15.4	Yes	2791
17/1000	0.9	57.0	51.3	12.9	7.1	16.1	Yes	2655
18/1000	1.0	57.0	57.0	12.0	7.1	17.6	Yes	2672
19/1000	1.1	57.1	62.8	10.9	7.0	18.4	Yes	2665
20/1000	1.2	57.0	68.5	11.0	7.0	18.5	Yes	2669
21/1100	0.8	56.8	45.4	11.7	7.1	17.5	Yes	2680
22/1100	1.0	56.8	56.8	9.8	7.3	21.7	Yes	2663
23/1100	1.0	56.6	56.6	10.6	7.3	20.6	Yes	2689
24/1000	0.9	56.6	50.9	11.1	7.1	18.4	Yes	2675
25/1000	1.1	56.7	62.3	10.3	7.1	19.8	Yes	2671
26/1000	1.1	56.8	62.5	10.3	7.1	19.8	Yes	2666
27/1000	0.9	56.5	50.9	12.2	7.0	16.6	Yes	2679
28/1100	0.9	56.8	51.2	12.5	7.0	15.9	Yes	2663
29/1100	1.0	56.7	56.7	12.1	6.9	16.3	Yes	2670
30/1100	1.0	57.0	57.0	12.0	7.1	17.6	Yes	2656

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.