

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: LINCOLN

Conventional or Direct Filtration

Month/Year: Dec-25

System Name: LINCOLN CITY WATER DISTRICT ID#: 4100483 WTP : TP - A

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/Anytime
2	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/Anytime
3	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/Anytime
4	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/Anytime
5	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	0.03	0.03/Anytime
6	PLT OFF	PLT OFF	0.00	0.03	0.03	PLT OFF	0.03/Anytime
7	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	0.03	0.03/Anytime
8	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	0.03	0.03/Anytime
9	PLT OFF	PLT OFF	PLT OFF	0.03	0.04	0.07	0.07/2000
10	0.05	0.04	PLT OFF	0.05	0.03	0.03	0.09/1231
11	PLT OFF	PLT OFF	PLT OFF	0.05	0.05	PLT OFF	0.19/1300
12	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/Anytime
13	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	0.03	0.08/1808
14	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.05/1510
15	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.05/1545
16	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/Anytime
17	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	0.03	0.03/Anytime
18	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/Anytime
19	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	0.03	0.05/1130
20	0.03	0.03	PLT OFF	PLT OFF	0.03	0.03	0.03/Anytime
21	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	0.03	0.06/1148
22	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/Anytime
23	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/Anytime
24	PLT OFF	PLT OFF	0.03	0.03	0.03	PLT OFF	0.03/Anytime
25	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/Anytime
26	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	0.03	0.03/Anytime
27	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	0.03	0.03/Anytime
28	PLT OFF	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	0.03/Anytime
29	0.03	PLT OFF	PLT OFF	PLT OFF	PLT OFF	0.03	0.03/Anytime
30	0.03	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/Anytime
31	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/Anytime

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No	All Cl2 residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No
All 4-hour turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No		
All turbidity readings < IFE ² triggers <input checked="" type="radio"/> Yes / <input type="radio"/> No		

Notes:	PRINTED NAME: BEN PENA JR.	
	SIGNATURE: <i>[Signature]</i>	DATE: 1/6/26
	PHONE #: (541) 996-2987	CERT #T-09441

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - :	A
Disinfection Giardia Log Inactive:	0.5

System Name: | LINCOLN CITY WATER DISTRICT ID#: 4100483 Month/Year: 25-Dec

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1/1000	1.1	57.0	62.7	11.2	7.3	20.0	Yes	2671
2/1000	1.1	57.0	62.7	10.3	7.1	19.8	Yes	2670
3/1000	1.1	57.4	63.2	10.7	7.1	19.3	Yes	2651
4/1000	1.0	57.2	57.2	10.7	7.1	19.1	Yes	2663
5/1000	1.0	105.6	105.6	11.5	7.8	23.1	Yes	1409
6/1000	0.9	58.7	52.8	11.6	6.9	16.6	Yes	2537
7/1000	1.0	59.7	59.7	12.0	7.3	18.8	Yes	2509
8/1100	1.1	57.9	63.7	12.9	7.1	16.4	Yes	2583
9/0900	1.0	122.8	122.8	12.4	7.0	16.5	Yes	1198
10/1300	1.2	84.3	101.1	12.7	7.2	17.5	Yes	1796
11/1000	1.1	50.8	55.8	12.6	7.1	16.8	Yes	3033
12/1100	1.2	54.5	65.4	12.4	7.1	17.5	Yes	2778
13/1000	1.1	56.4	62.1	11.5	7.2	19.0	Yes	2682
14/1000	1.1	56.6	62.2	11.1	7.2	19.5	Yes	2676
15/1000	1.1	57.2	63.0	12.3	7.1	17.4	Yes	2645
16/1000	1.1	56.1	61.7	12.9	7.1	16.4	Yes	2699
17/1000	1.0	56.8	56.8	12.4	6.9	16.0	Yes	2667
18/1000	1.1	52.8	58.1	11.7	7.0	17.5	Yes	2866
19/1000	1.1	110.7	121.8	12.1	7.0	17.0	Yes	1336
20/0000	1.4	104.4	146.2	12.0	6.9	17.1	Yes	1417
21/1100	1.3	53.8	70.0	11.8	7.0	17.8	Yes	2685
22/1000	1.2	56.6	67.9	11.4	7.2	19.3	Yes	2645
23/0900	1.1	58.4	64.3	11.8	7.1	18.0	Yes	2577
24/0800	1.1	57.4	63.2	11.4	7.1	18.4	Yes	2621
25/1000	1.0	56.0	56.0	10.4	7.3	20.9	Yes	2701
26/1000	1.0	56.6	56.6	10.9	7.1	18.8	Yes	2658
27/1100	1.1	56.0	61.6	10.2	7.1	19.9	Yes	2688
28/1300	1.0	56.0	56.0	9.5	7.2	21.4	Yes	2687
29/1800	1.0	56.2	56.2	9.3	7.2	21.7	Yes	2694
30/1000	1.2	56.3	67.6	9.3	7.0	20.7	Yes	2672
31/1000	1.1	53.6	58.9	8.9	7.0	21.0	Yes	2826

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:

dwp_dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350