

OHA - Drinking Water Services -Turbidity Monitoring Report Form


County: LINCOLN

Conventional or Direct Filtration

Month/Year: JAN 2026

System Name: LINCOLN CITY WATER DISTRICT ID#: 41 00483							WTP : TP - A
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	0.03	0.03/Anytime
2	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	0.03	0.03/Anytime
3	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	0.03	0.03/Anytime
4	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/Anytime
5	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/Anytime
6	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/Anytime
7	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/Anytime
8	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/Anytime
9	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/Anytime
10	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/Anytime
11	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	0.03	0.03/Anytime
12	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/Anytime
13	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/Anytime
14	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/Anytime
15	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/Anytime
16	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/Anytime
17	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	0.03	0.03/Anytime
18	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/Anytime
19	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	0.03	0.03/Anytime
20	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/Anytime
21	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/Anytime
22	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/Anytime
23	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/Anytime
24	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/Anytime
25	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/Anytime
26	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/Anytime
27	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/Anytime
28	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/Anytime
29	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/Anytime
30	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	0.03	0.03/Anytime
31	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/Anytime

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All 4-hour turbidity readings ≤ 1 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No
All turbidity readings < IFE ² triggers	<input checked="" type="radio"/> Yes / <input type="radio"/> No		

Notes:	PRINTED NAME: Ben J Pena Jr	
	SIGNATURE: 	DATE:
	PHONE #: (541) 996-2987	CERT #: 09441

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A

System Name: LINCOLN CITY WATER DISTRICT **ID#:** 41 00483 **Month/Year:** JAN 2026

**Disinfection
Giardia Log
Inactive:** 0.5

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1/1000	1.1	57.1	62.8	9.0	7.1	21.6	Yes	2652
2/1000	1.0	56.6	56.6	10.2	7.1	19.7	Yes	2674
3/1000	1.0	57.5	57.5	11.4	7.0	17.6	Yes	2635
4/1000	1.0	57.4	57.4	11.5	7.0	17.5	Yes	2637
5/1100	0.9	57.7	51.9	10.8	7.0	18.1	Yes	2624
6/1000	1.0	57.5	57.5	10.1	7.0	19.2	Yes	2618
7/0900	1.0	56.4	56.4	10.3	7.0	18.9	Yes	2670
8/1000	1.2	57.4	68.9	11.3	7.0	18.1	Yes	2638
9/1100	1.2	57.1	68.6	10.2	7.0	19.5	Yes	2649
10/1000	1.1	56.8	62.5	10.4	7.1	19.7	Yes	2665
11/1100	1.1	56.5	62.1	10.6	7.0	18.8	Yes	2681
12/1000	1.1	57.6	63.4	11.1	7.2	19.5	Yes	2626
13/1000	1.0	56.4	56.4	11.1	7.1	18.6	Yes	2682
14/1000	1.1	56.0	61.6	10.3	7.2	20.5	Yes	2703
15/0900	1.2	57.1	68.5	10.8	7.3	20.8	Yes	2652
16/1000	1.1	57.5	63.2	9.9	7.0	19.6	Yes	2634
17/1000	1.1	57.1	62.8	9.1	7.3	23.0	Yes	2650
18/1000	1.1	56.4	62.1	9.1	7.1	21.4	Yes	2682
19/1100	1.1	57.0	62.7	8.5	7.1	22.3	Yes	2657
20/1000	1.1	57.2	62.9	8.4	7.1	22.4	Yes	2647
21/1000	1.1	57.1	62.8	8.4	7.1	22.4	Yes	2652
22/1000	1.1	56.7	62.4	7.7	7.0	22.7	Yes	2668
23/1000	1.1	57.3	63.0	8.0	7.1	23.0	Yes	2644
24/1000	1.1	57.2	63.0	7.7	7.1	23.5	Yes	2645
25/0900	1.2	56.8	68.2	6.7	7.1	25.4	Yes	2664
26/1000	1.1	56.5	62.2	7.8	7.1	23.4	Yes	2678
27/1000	1.1	56.7	62.3	9.2	7.2	22.0	Yes	2671
28/0900	1.1	56.7	62.4	10.7	7.1	19.3	Yes	2668
29/0900	1.0	56.8	56.8	11.0	7.0	18.1	Yes	2650
30/1000	0.9	58.1	52.3	12.1	7.3	18.5	Yes	2607
31/1000	0.6	57.9	34.7	10.8	7.0	17.5	Yes	2600

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350