


OHA - Drinking Water Services -Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: **LINCOLN**
 Month/Year: **Mar-26**

System Name: LINCOLN CITY WATER DISTRICT ID#: 41 00483 **WTP : TP - A**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/Anytime
2	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/Anytime
3	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/Anytime
4	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/Anytime
5	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/Anytime
6	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/Anytime
7	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/Anytime
8	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/Anytime
9	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/Anytime
10	PLT OFF	PLT OFF	PLT OFF	0.04	0.04	PLT OFF	0.04/Anytime
11	PLT OFF	PLT OFF	PLT OFF	0.04	0.04	0.04	0.04/Anytime
12	PLT OFF	PLT OFF	PLT OFF	0.04	0.04	0.04	0.04/Anytime
13	PLT OFF	PLT OFF	PLT OFF	0.04	0.04	PLT OFF	0.04/Anytime
14	PLT OFF	PLT OFF	PLT OFF	0.04	0.04	0.04	0.04/Anytime
15	PLT OFF	PLT OFF	PLT OFF	0.04	0.04	PLT OFF	0.04/Anytime
16	PLT OFF	PLT OFF	PLT OFF	0.04	0.04	PLT OFF	0.04/Anytime
17	PLT OFF	PLT OFF	PLT OFF	0.04	0.04	PLT OFF	0.04/Anytime
18	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/Anytime
19	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	0.03	0.03/Anytime
20	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/Anytime
21	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	0.03	0.03/Anytime
22	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	0.03	0.03/Anytime
23	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/Anytime
24	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/Anytime
25	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/Anytime
26	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/Anytime
27	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	0.03	0.03/Anytime
28	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/Anytime
29	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	0.03	0.03/Anytime
30	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.03/Anytime
31	PLT OFF	PLT OFF	PLT OFF	0.03	0.03	PLT OFF	0.04/1550

Conventional or Direct Filtration			Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No		CT's met everyday? (see back)	All Cl ₂ residual at entry point ≥ 0.2 mg/l?
All 4-hour turbidity readings ≤ 1 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No		<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No
All turbidity readings < IFE ² triggers	<input checked="" type="radio"/> Yes / <input type="radio"/> No			
Notes:			PRINTED NAME: BEN PENA JR	
			SIGNATURE: 	
			DATE: 4/7/26	
			PHONE #: (541) 996-2987	
			CERT #: T-09441	

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A

System Name: LINCOLN CITY WATER DISTRICT ID#: 41 00483	Month/Year: Mar-26	Disinfection <i>Giardia</i> Log Inactive:	0.5
---	---------------------------	--	-----

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1/1000	1.0	56.9	56.9	10.4	7.1	19.5	Yes	2661
2/1000	1.1	57.8	63.6	11.5	7.1	18.3	Yes	2620
3/1000	1.0	57.7	57.7	11.7	7.1	17.9	Yes	2610
4/1000	1.0	57.7	57.7	11.4	7.1	18.2	Yes	2624
5/1000	0.9	56.6	50.9	11.0	7.1	18.5	Yes	2660
6/1000	1.0	56.6	56.6	10.8	7.0	18.3	Yes	2661
7/1000	1.1	57.3	63.0	11.2	7.1	18.7	Yes	2628
8/1000	1.1	56.2	61.9	11.6	7.1	18.2	Yes	2677
9/1000	0.9	56.5	50.9	11.4	7.0	17.4	Yes	2648
10/1100	1.1	56.5	62.2	10.5	7.0	18.9	Yes	2647
11/0900	1.1	56.8	62.5	9.9	7.5	23.4	Yes	2559
12/1000	1.2	91.9	110.3	10.7	6.9	18.2	Yes	1629
13/1000	1.2	57.4	68.9	11.2	6.9	17.6	Yes	2607
14/1100	1.2	59.3	71.2	11.5	7.0	17.9	Yes	2522
15/1000	1.1	55.8	61.3	10.7	7.3	20.7	Yes	2684
16/1000	1.1	56.6	62.3	11.6	7.2	18.8	Yes	2658
17/1000	1.0	57.3	57.3	11.9	7.2	18.3	Yes	2628
18/1000	1.1	57.0	62.6	11.6	7.1	18.2	Yes	2643
19/1100	1.0	56.5	56.5	12.1	7.0	16.9	Yes	2662
20/1000	1.1	56.4	62.0	12.1	7.0	17.0	Yes	2685
21/1000	1.0	55.7	55.7	11.6	7.2	18.6	Yes	2701
22/1100	1.1	55.7	61.2	10.3	7.1	19.8	Yes	2720
23/1000	1.1	56.4	62.0	11.0	7.1	18.9	Yes	2670
24/1100	1.1	57.7	63.5	11.3	7.0	17.9	Yes	2608
25/1000	1.0	57.8	57.8	11.2	7.0	17.9	Yes	2606
26/1000	1.0	58.1	58.1	11.3	7.0	17.7	Yes	2591
27/1100	1.0	56.5	56.5	10.6	6.8	17.3	Yes	2664
28/1000	1.1	56.3	61.9	11.1	7.0	18.2	Yes	2676
29/1000	1.0	54.6	54.6	11.8	7.0	17.2	Yes	2757
30/1000	1.2	56.5	67.8	11.2	7.0	18.3	Yes	2664
31/1100	1.0	56.4	56.4	11.3	7.0	17.7	Yes	2668

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:

dwp_dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350