

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: Lane

Conventional or Direct Filtration

Month/Year: Nov-25

System Name: Lowell, City Of ID#: 4100492 WTP : WTP - B

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1							
2					0.06	0.06	0.09
3			0.06	0.06	0.05	0.05	0.07
4				0.05	0.05		0.06
5				0.06	0.05		0.08
6					0.05		0.08
7			0.05	0.05			0.12
8			0.05	0.05	0.05	0.05	0.06
9							
10				0.05	0.06	0.06	0.08
11				0.06	0.06	0.06	0.09
12	0.05	0.05			0.06	0.06	0.11
13							
14			0.06		0.06	0.05	0.09
15				0.05	0.07	0.06	0.08
16							
17					0.05	0.05	0.10
18				0.05	0.05	0.05	0.07
19				0.06			0.08
20				0.06			0.12
21				0.05	0.05		0.10
22				0.05	0.05	0.05	0.07
23			0.10	0.05	0.05	0.05	0.10
24							0.06
25				0.05	0.05	0.05	0.07
26				0.05			0.10
27							
28			0.05	0.06	0.05		0.07
29				0.06	0.06	0.05	0.10
30							

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU? Yes/ No	CT's met everyday? (see back) Yes/ No	All Cl2 residual at entry point ≥ 0.2 mg/l? Yes/ No
All 4-hour turbidity readings ≤ 1 NTU? Yes/ No		
All turbidity readings < IFE ² triggers Yes/ No		

Notes:

PRINTED NAME: Hunter Harris

SIGNATURE: *Hunter Harris* DATE: 12/2/25

PHONE #: 541-937-2776 CERT #: 08801FE

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : WTP-B

System Name:	Lowell, City of	ID#: 4100492	Month/Year:	Nov-25	Disinfection <i>Giardia</i> Log Inactiv:	0.5
--------------	-----------------	--------------	-------------	--------	--	-----

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	
1								
2	0.77	66	50.8	15.2	7.24	14.3	Y	175
3	0.59	66	38.9	14.9	7.17	13.9	Y	165
4	0.58	66	38.3	15.0	7.18	13.9	Y	165
5	0.66	66	43.6	15.0	7.22	14.2	Y	165
6	0.79	66	52.1	15.1	7.20	14.2	Y	165
7	0.74	66	48.8	14.9	7.17	14.2	Y	165
8	0.82	66	54.1	14.4	7.18	14.8	Y	165
9								
10	0.63	66	41.6	14.5	7.26	14.9	Y	165
11	0.63	66	41.6	14.2	7.05	14.0	Y	165
12	0.7	66	46.2	14.5	7.15	14.4	Y	165
13								
14	0.56	66	37.0	14.2	7.16	14.5	Y	165
15	0.83	66	54.8	13.9	7.15	15.2	Y	165
16								
17	0.71	66	46.9	13.8	7.17	15.2	Y	165
18	0.66	66	43.6	13.5	7.18	15.5	Y	165
19	0.58	66	38.3	13.3	7.29	16.2	Y	165
20	0.51	66	33.7	13.2	7.24	15.9	Y	165
21	0.58	66	38.3	12.8	7.14	15.8	Y	165
22	0.57	66	37.6	12.6	7.28	16.9	Y	165
23	0.65	66	42.9	12.3	7.19	17.1	Y	165
24	0.71	66	46.9	12.1	7.29	18.0	Y	165
25	0.59	66	38.9	11.9	7.26	17.8	Y	165
26	0.63	66	41.6	11.6	7.35	18.8	Y	165
27								
28	0.68	66	44.9	11.9	7.26	18.0	Y	165
29	0.56	66	37.0	11.7	7.25	17.9	Y	165
30								

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2013