



DHS-Drinking Water Program

Turbidity Monitoring Report Form

YAMHILL CO.

System Name: McMinnville Water and Light

Id#: 4100497-A Month/Year: January, 2026

DAY	0000	0400	0800	1200	1600	2000	Highest 15 min Reading		
	NTU	NTU	NTU	NTU	NTU	NTU	Time	NTU	
01/01/26	0.03	0.03	0.03	0.03	0.03	0.03	00:00	0.03	
01/02/26	0.03	0.03	0.03	0.03	0.03	0.03	00:00	0.03	
01/03/26	0.03	0.03	0.03	0.03	0.03	0.03	00:00	0.03	
01/04/26	0.03	0.03	0.03	0.03	0.03	0.03	00:00	0.03	
01/05/26	0.03	0.03	0.03	0.03	0.03	0.03	00:00	0.03	
01/06/26	0.03	0.03	0.03	0.03	0.03	0.03	00:00	0.03	
01/07/26	0.03	0.03	0.03	0.03	0.03	0.03	00:00	0.03	
01/08/26	0.03	0.03	0.03	0.04	0.03	0.03	11:30	0.04	
01/09/26	0.03	0.03	0.03	0.03	0.03	0.03	10:00	0.04	
01/10/26	0.03	0.03	0.03	0.03	0.03	0.03	11:15	0.04	
01/11/26	0.03	0.03	0.03	0.03	0.03	0.03	00:00	0.03	
01/12/26	0.03	0.03	0.03	0.03	0.03	0.03	00:00	0.03	
01/13/26	0.03	0.03	0.03	0.03	0.03	0.03	00:00	0.03	
01/14/26	0.03	0.03	0.03	0.03	0.03	0.03	00:00	0.03	
01/15/26	0.03	0.03	0.03	0.03	0.03	0.03	00:00	0.03	
01/16/26	0.03	0.03	0.03	0.03	0.03	0.03	09:30	0.04	
01/17/26	0.03	0.03	0.03	0.03	0.03	0.03	11:00	0.04	
01/18/26	0.03	0.03	0.03	0.03	0.03	0.03	00:00	0.03	
01/19/26	0.03	0.03	0.03	0.03	0.03	0.03	00:00	0.03	
01/20/26	0.03	0.03	0.03	0.03	0.03	0.03	00:00	0.03	
01/21/26	0.03	0.03	0.03	0.02	0.02	0.02	00:00	0.03	
01/22/26	0.02	0.02	0.02	0.02	0.02	0.02	00:00	0.02	
01/23/26	0.02	0.02	0.02	0.02	0.02	0.02	00:00	0.02	
01/24/26	0.02	0.02	0.02	0.02	0.02	0.02	00:00	0.02	
01/25/26	0.02	0.02	0.02	0.02	0.02	0.02	00:00	0.02	
01/26/26	0.02	0.02	0.02	0.02	0.02	0.02	00:00	0.02	
01/27/26	0.02	0.02	0.02	0.02	0.02	0.02	00:00	0.02	
01/28/26	0.02	0.02	0.02	0.02	0.02	0.02	00:00	0.02	
01/29/26	0.02	0.02	0.02	0.02	0.02	0.02	00:00	0.02	
01/30/26	0.02	0.02	0.02	0.02	0.02	0.02	00:00	0.02	
01/31/26	0.02	0.02	0.02	0.02	0.02	0.02	00:00	0.02	
Highest NTU 4 hr. reading				0.04		Highest 15 min Read		0.04	

Monthly Summary

95% of turbidity readings <= 0.3 NTU? Yes, No CT's met everyday? All Cl2 residual at entry Cl2 residual measured in 95%
 All turbidity readings < 1 NTU? Yes, No point always >= 0.2 mg/l? of distribution samples?
 All turbidity readings < IFE triggers? Yes, No Yes, No Yes, No Yes, No

Treatment Techniques are: 0.3 NTU 95% of all readings and never to exceed 1 NTU.

IFE = Individual Filter Effluent

Printed Name: Nicholas Wirth

Signature: Nicholas Wirth

Phone #: (503) 472-6158 Cert #: T-08567

Date: Monday, February 2, 2026

**Department of Human Services- Drinking Water Section
Surface Water Quality Data**

System Name: McMinnville Water & Light

Id#- 4100497

Month/Yr: January 2026

Day	Time	Peak Hourly Flow MGD	Cl2 Residual at 1st User (C) mg/l	Contact Time (T) minutes	Actual CT C x T	Temp °C	pH pH	Required CT Calc	Inactivation Act CT/ Req CT	CT Met Yes / No
1/1/2026	09:00	3.83	1.37	71.0	97.3	7	7.40	31	3.14	Yes
1/2/2026	09:00	3.78	1.33	71.0	94.4	7	7.39	31	3.05	Yes
1/3/2026	03:00	3.71	1.39	71.0	98.7	7	7.37	31	3.18	Yes
1/4/2026	10:00	3.63	1.37	71.0	97.3	7	7.48	31	3.14	Yes
1/5/2026	10:00	3.60	1.35	71.0	95.9	7	7.32	31	3.09	Yes
1/6/2026	11:00	3.60	1.32	71.0	93.7	7	7.27	31	3.02	Yes
1/7/2026	10:00	3.66	1.36	71.0	96.6	7	7.46	31	3.11	Yes
1/8/2026	10:00	3.70	1.34	71.0	95.1	7	7.46	31	3.07	Yes
1/9/2026	10:00	3.76	1.31	71.0	93.0	7	7.57	38	2.45	Yes
1/10/2026	11:00	3.70	1.32	71.0	93.7	7	7.47	31	3.02	Yes
1/11/2026	11:00	3.73	1.31	71.0	93.0	7	7.48	31	3.00	Yes
1/12/2026	09:00	3.72	1.32	71.0	93.7	7	7.39	31	3.02	Yes
1/13/2026	09:00	3.66	1.33	71.0	94.4	8	7.25	31	3.05	Yes
1/14/2026	10:00	3.69	1.30	71.0	92.3	8	7.25	31	2.98	Yes
1/15/2026	10:00	3.60	1.27	71.0	90.2	8	7.28	31	2.91	Yes
1/16/2026	08:00	3.56	1.23	71.0	87.3	7	7.38	31	2.82	Yes
1/17/2026	08:00	3.50	1.25	71.0	88.8	7	7.38	31	2.86	Yes
1/18/2026	08:00	3.57	1.30	71.0	92.3	7	7.31	31	2.98	Yes
1/19/2026	16:00	3.79	1.30	71.0	92.3	7	7.37	31	2.98	Yes
1/20/2026	18:00	4.27	1.35	71.0	95.9	7	7.36	31	3.09	Yes
1/21/2026	10:00	4.34	1.40	71.0	99.4	7	7.36	31	3.21	Yes
1/22/2026	10:00	4.35	1.41	71.0	100.1	6	7.35	32	3.13	Yes
1/23/2026	09:00	4.36	1.48	71.0	105.1	6	7.28	32	3.28	Yes
1/24/2026	09:00	4.31	1.47	71.0	104.4	6	7.29	32	3.26	Yes
1/25/2026	09:00	4.30	1.49	71.0	105.8	6	7.27	32	3.31	Yes
1/26/2026	11:00	4.29	1.45	71.0	103.0	5	7.33	32	3.22	Yes
1/27/2026	11:00	4.27	1.41	71.0	100.1	5	7.28	32	3.13	Yes
1/28/2026	09:00	3.99	1.26	71.0	89.5	5	7.35	31	2.89	Yes
1/29/2026	11:00	4.00	1.29	71.0	91.6	5	7.34	31	2.95	Yes
1/30/2026	09:00	3.95	1.33	71.0	94.4	6	7.44	31	3.05	Yes
1/31/2026	09:00	3.94	1.30	71.0	92.3	6	7.31	31	2.98	Yes