



DHS-Drinking Water Program

Turbidity Monitoring Report Form

YAMHILL CO.

System Name: McMinnville Water and Light

Id#: 4100497-A Month/Year: February, 2026

DAY	0000	0400	0800	1200	1600	2000	Highest 15 min Reading		
	NTU	NTU	NTU	NTU	NTU	NTU	Time	NTU	
02/01/26	0.02	0.02	0.02	0.02	0.02	0.02	00:00	0.02	
02/02/26	0.02	0.02	0.02	0.02	0.02	0.02	00:00	0.02	
02/03/26	0.02	0.02	0.02	0.02	0.03	0.02	12:15	0.03	
02/04/26	0.02	0.02	0.02	0.03	0.03	0.03	09:45	0.03	
02/05/26	0.02	0.02	0.03	0.03	0.02	0.02	07:45	0.03	
02/06/26	0.02	0.02	0.02	0.02	0.02	0.02	10:30	0.03	
02/07/26	0.02	0.02	0.02	0.02	0.02	0.02	00:00	0.02	
02/08/26	0.02	0.02	0.02	0.03	0.03	0.03	08:30	0.03	
02/09/26	0.03	0.02	0.02	0.02	0.03	0.02	00:00	0.03	
02/10/26	0.02	0.02	0.02	0.03	0.02	0.02	11:45	0.03	
02/11/26	0.02	0.02	0.02	0.02	0.02	0.02	00:00	0.02	
02/12/26	0.02	0.02	0.02	0.02	0.02	0.02	14:30	0.03	
02/13/26	0.02	0.02	0.02	0.02	0.02	0.02	00:00	0.02	
02/14/26	0.02	0.02	0.02	0.02	0.02	0.02	00:00	0.02	
02/15/26	0.02	0.02	0.02	0.02	0.02	0.02	00:00	0.02	
02/16/26	0.02	0.02	0.02	0.02	0.02	0.02	00:00	0.02	
02/17/26	0.02	0.02	0.02	0.02	0.02	0.02	10:15	0.03	
02/18/26	0.02	0.02	0.02	0.02	0.02	0.02	16:30	0.03	
02/19/26	0.02	0.02	0.02	0.03	0.02	0.02	11:15	0.03	
02/20/26	0.02	0.02	0.02	0.02	0.02	0.02	09:30	0.03	
02/21/26	0.02	0.02	0.02	0.02	0.02	0.02	09:15	0.03	
02/22/26	0.02	0.02	0.02	0.02	0.02	0.02	10:15	0.03	
02/23/26	0.02	0.02	0.02	0.03	0.02	0.02	09:30	0.03	
02/24/26	0.02	0.02	0.02	0.03	0.03	0.02	09:30	0.03	
02/25/26	0.02	0.02	0.02	0.02	0.02	0.02	11:45	0.03	
02/26/26	0.02	0.02	0.02	0.02	0.11	0.03	14:15	0.23	
02/27/26	0.02	0.02	0.02	0.03	0.02	0.02	11:30	0.03	
02/28/26	0.02	0.02	0.02	0.02	0.02	0.02	00:00	0.02	
Highest NTU 4 hr. reading						0.11	Highest 15 min Read		0.23

Monthly Summary

95% of turbidity readings <= 0.3 NTU? Yes, No CT's met everyday? All Cl2 residual at entry Cl2 residual measured in 95%
 All turbidity readings < 1 NTU? Yes, No point always >= 0.2 mg/l? of distribution samples?
 All turbidity readings < IFE triggers? Yes, No Yes, No Yes, No Yes, No

Treatment Techniques are: 0.3 NTU 95% of all readings and never to exceed 1 NTU.

IFE = Individual Filter Effluent

Printed Name: Nicholas Wirth

Signature: Nicholas Wirth

Phone #: (503) 472-6158 Cert #: T-08567

Date: Tuesday, March 3, 2026

Department of Human Services- Drinking Water Section
Surface Water Quality Data

System Name: McMinnville Water & Light

Id#- 4100497

Month/Yr: February 2026

Day	Time	Peak Hourly Flow MGD	Cl2 Residual at 1st User (C) mg/l	Contact Time (T) minutes	Actual CT C x T	Temp °C	pH pH	Required CT Calc	Inactivation Act CT/ Req CT	CT Met Yes / No
2/1/2026	10:00	3.94	1.22	71.0	86.6	6	7.35	31	2.79	Yes
2/2/2026	08:00	3.35	1.25	71.0	88.8	7	7.34	31	2.86	Yes
2/3/2026	16:00	3.33	1.13	71.0	80.2	7	7.41	31	2.59	Yes
2/4/2026	10:00	3.25	1.34	71.0	95.1	7	7.43	31	3.07	Yes
2/5/2026	10:00	3.71	1.25	71.0	88.8	7	7.39	31	2.86	Yes
2/6/2026	09:00	3.23	1.35	71.0	95.9	8	7.44	31	3.09	Yes
2/7/2026	09:00	3.20	1.32	71.0	93.7	8	7.45	31	3.02	Yes
2/8/2026	09:00	3.52	1.32	71.0	93.7	8	7.39	31	3.02	Yes
2/9/2026	23:00	3.58	1.22	71.0	86.6	8	7.27	31	2.79	Yes
2/10/2026	09:00	3.69	1.26	71.0	89.5	9	7.26	31	2.89	Yes
2/11/2026	16:00	3.94	1.35	71.0	95.9	7	7.31	31	3.09	Yes
2/12/2026	14:00	4.09	1.38	71.0	98.0	7	7.28	31	3.16	Yes
2/13/2026	08:00	4.07	1.35	71.0	95.9	7	7.32	31	3.09	Yes
2/14/2026	09:00	4.01	1.29	71.0	91.6	8	7.29	31	2.95	Yes
2/15/2026	09:00	3.97	1.34	71.0	95.1	7	7.27	31	3.07	Yes
2/16/2026	10:00	3.97	1.31	71.0	93.0	7	7.32	31	3.00	Yes
2/17/2026	08:00	4.00	1.38	71.0	98.0	6	7.39	31	3.16	Yes
2/18/2026	15:00	3.90	1.29	71.0	91.6	6	7.34	31	2.95	Yes
2/19/2026	10:00	3.93	1.37	71.0	97.3	5	7.36	31	3.14	Yes
2/20/2026	07:00	3.89	1.41	71.0	100.1	5	7.35	32	3.13	Yes
2/21/2026	09:00	3.92	1.45	71.0	103.0	6	7.39	32	3.22	Yes
2/22/2026	08:00	3.95	1.40	71.0	99.4	6	7.25	31	3.21	Yes
2/23/2026	10:00	3.99	1.40	71.0	99.4	7	7.23	31	3.21	Yes
2/24/2026	11:00	4.09	1.29	71.0	91.6	7	7.25	31	2.95	Yes
2/25/2026	11:00	4.08	1.41	71.0	100.1	7	7.41	32	3.13	Yes
2/26/2026	03:00	4.00	1.36	71.0	96.6	7	7.42	31	3.11	Yes
2/27/2026	07:00	4.07	1.43	71.0	101.5	7	7.63	39	2.60	Yes
2/28/2026	10:00	4.09	1.36	71.0	96.6	7	7.46	31	3.11	Yes