

**OHA - Drinking Water Program -Turbidity Monitoring Report Form**  
**Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**

County: **Lane**  
 Month/Year: **Jun-23**

System Name: **Mapleton Water District** ID#: **41 00507** WTP : **WTP-A**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]
1	0.030	0.030	0.030	0.030	0.030	0.040	0.040
2	0.030	0.030	0.030	0.030	OFF	OFF	0.030
3	OFF	OFF	OFF	OFF	0.030	0.030	0.030
4	0.030	0.030	0.030	OFF	OFF	OFF	0.030
5	OFF	OFF	OFF	OFF	OFF	OFF	N/A
6	OFF	OFF	OFF	OFF	OFF	OFF	N/A
7	OFF	OFF	OFF	0.030	0.030	0.030	0.030
8	0.030	0.030	0.030	0.030	0.030	OFF	0.030
9	OFF	OFF	OFF	OFF	OFF	OFF	N/A
10	OFF	OFF	OFF	0.030	0.030	0.030	0.030
11	0.030	0.030	0.030	0.030	OFF	OFF	0.030
12	OFF	OFF	OFF	OFF	OFF	OFF	N/A
13	OFF	OFF	OFF	OFF	OFF	OFF	N/A
14	OFF	OFF	OFF	0.030	0.040	0.030	0.040
15	0.030	0.030	0.030	0.030	OFF	OFF	0.030
16	OFF	OFF	OFF	OFF	OFF	OFF	N/A
17	OFF	OFF	OFF	0.030	0.030	0.030	0.030
18	0.030	0.030	0.030	0.030	0.030	0.030	0.030
19	0.030	0.030	0.030	0.030	OFF	OFF	0.030
20	OFF	OFF	OFF	OFF	OFF	OFF	N/A
21	OFF	OFF	0.030	0.030	0.030	0.030	0.030
22	0.030	0.030	0.040	0.030	OFF	OFF	0.040
23	OFF	OFF	OFF	OFF	OFF	OFF	N/A
24	OFF	OFF	0.030	0.030	0.030	0.030	0.030
25	0.030	0.030	0.030	0.030	0.030	0.030	0.030
26	0.030	0.030	0.030	0.030	OFF	OFF	0.030
27	OFF	OFF	OFF	OFF	OFF	OFF	N/A
28	OFF	OFF	OFF	OFF	0.030	OFF	0.030
29	OFF	OFF	OFF	OFF	0.030	0.030	0.030
30	0.030	0.030	0.030	0.030	OFF	OFF	0.030
31							

<b>Slow Sand/Membrane/DE Filtration/Unfiltered</b>		<b>Monthly Summary (Answer Yes or No)</b>	
95% of daily turbidity readings ≤ 1 NTU?	<b>✓ Yes / No</b>	CT's met everyday? (see back)	All Cl <sub>2</sub> residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU?	<b>✓ Yes / No</b>	<b>✓ Yes / No</b>	<b>✓ Yes / No</b>

<b>Notes:</b>	<b>PRINTED NAME: Dave Terrusa</b>	
	<b>SIGNATURE: Digitally signed</b>	<b>DATE: 7/10/23</b>
	<b>PHONE #: (541) 253-7556</b>	<b>CERT #: 6930</b>

<sup>1</sup> Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. <sup>2</sup> Filtered systems only.

**OHA - Drinking Water Program - Surface Water Quality Data Form**

**WTP - : WTP-D**

**System Name: Mapleton Water DistricID#: 41 00507**

**Month/Year: Jun-23**

**Disinfection  
Giardia Log  
Inactiv:**

**0.5**

Date	Time	Minimum Cl <sub>2</sub> Residual at 1st User (C) <sup>3</sup>	Contact Time (T)	Actual CT C x T	Temp	pH	Required CT	CT Met? <sup>3</sup> Yes or No	Peak Hourly Demand Flow
		[ppm or mg/L]	[minutes]	formula	[° C]		formula	formula	[GPM]
1	10:00 AM	1.5	70	105.0	13.0	7.3	18.4	Yes	150
2	10:00 AM	1.5	70	105.0	13.0	7.3	18.4	Yes	150
3	10:00 AM	1.5	70	105.0	13.0	7.3	18.4	Yes	150
4	10:00 AM	1.3	70	91.0	13.0	7.3	18.0	Yes	N/A
5	10:00 AM	1.5	70	105.0	13.0	7.3	18.4	Yes	150
6	10:00 AM	1.6	70	112.0	12.0	7.3	20.1	Yes	150
7	10:00 AM	1.7	70	119.0	12.0	7.3	20.3	Yes	150
8	10:00 AM	1.6	70	112.0	12.0	7.4	20.8	Yes	150
9	10:00 AM	1.5	70	105.0	12.0	7.4	20.6	Yes	150
10	10:00 AM	1.5	70	105.0	12.0	7.4	20.6	Yes	150
11	10:00 AM	1.5	70	105.0	12.0	7.4	20.6	Yes	150
12	10:00 AM	1.7	70	119.0	12.0	7.3	20.3	Yes	150
13	10:00 AM	1.6	70	112.0	12.0	7.4	20.8	Yes	150
14	10:00 AM	1.6	70	112.0	12.0	7.4	20.8	Yes	150
15	10:00 AM	1.7	70	119.0	12.0	7.4	21.0	Yes	150
16	10:00 AM	1.7	70	119.0	12.0	7.4	21.0	Yes	150
17	10:00 AM	1.7	70	119.0	12.0	7.3	20.3	Yes	150
18	10:00 AM	1.4	70	98.0	13.0	7.3	18.2	Yes	150
19	10:00 AM	1.4	70	98.0	12.0	7.4	20.4	Yes	150
20	10:00 AM	1.4	70	98.0	12.0	7.3	19.7	Yes	150
21	10:00 AM	1.6	70	112.0	12.0	7.3	20.1	Yes	150
22	10:00 AM	1.8	70	126.0	11.0	7.4	22.7	Yes	150
23	10:00 AM	1.6	70	112.0	11.0	7.3	21.5	Yes	150
24	10:00 AM	1.6	70	112.0	11.0	7.3	21.5	Yes	150
25	10:00 AM	1.6	70	112.0	11.0	7.3	21.5	Yes	150
26	10:00 AM	1.6	70	112.0	11.0	7.3	21.5	Yes	150
27	10:00 AM	1.5	70	105.0	11.0	7.3	21.2	Yes	150
28	10:00 AM	1.4	70	98.0	11.0	7.4	21.7	Yes	150
29	10:00 AM	1.7	70	119.0	11.0	7.4	22.5	Yes	150
30	10:00 AM	1.6	70	112.0	11.0	7.3	21.5	Yes	150
31	10:00 AM								

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2013